



NOS.	DESCRIPTION
①	TERMINALS-CONNECTED TO 1a1,2a1,3a1 LEADS
②	I.D STRIP
③	GLAND PLATE(122x147 mm)
④	TERMINAL BLOCK
⑤	OIL TO AIR SEAL PLATE
⑥	FUSES HOLDER C/W 10A FUSE (3X)
⑦	SURGE PROTECTOR
⑧	RUBBER GORMET

SR	NOTE
01	DOOR REMOVED FOR CLARITY
02	TERMINAL BOX CONFIRM AS PER IP55
03	20 % SPARE TERMINAL WILL BE PROVIDED (ST)

Date: 1... Contractor: BIHAR STATE POWER TRANSMISSION COMPANY LIMITED.  
 Prep. ... Project: 2X  
 Ckd. ...  
 Norm. Original/Replaced By: -

Descr : 245KV,Outdoor,oil cooled  
 hermetically sealed Capacitive  
 Voltage Transformer.  
 Details: Svc. Box GA Drawing.

Sales Order no : 100 Qty : 03x

NOT TO SCALE  
 All dimensions are in mm

Drwg. No:- 245-KV-CVT-GA-I

SH 1  
 1 SH