



- B1-THERMOSTAT
- S16:Limit switch of Spring Charging motor
- E2:Illumination Lamp
- K10: Density Monitor Contacts Multiplier
- K75: Anti-pumping Contactor
- F19:DC MCB
- F20:AC MCB
- F11: On/Off Switch for Illuminating Lamp
- X20: Plug Socket with Switch
- F16:MCB for Spring Charging Motor
- S20/S21:ON/OFF PB (Elect)
- S13:Local/remote selector switch
- P1:operation counter
- R1: Space heater

EQUIPMENT LAYOUT-FRONT

Date		Customer: Bihar State Power Transmission Corporation Limited.		Dwg No : 145KV,40KA,3150A,SF6 CB		SAP No :		Qty :-25Nos		ALL DIMENSION ARE IN mm	
Prep		Project :		Details : Equipment Layout-Rear						NOT TO SCALE	
Ckd.		Original/Replacement for/Replaced by :-						Drg. No:-		Sh. 1	
Remarks								145-KV-3150-CB-EL		2 Sh.	