



B4 : Density Monitor
 Y1: Mechanical Closing PB/Coil
 Y3/Y4: Mechanical Trip PB/Coil
 M1:Spring Charging Motor
 S1:Breaker Aux Switch

EQUIPMENT LAYOUT-REAR

Issue	Remarks	Date	Name	Norm	Original/Replacement for/Replaced by :-	Desor : 145KV,40KA,3150A SF6 CB Detail: Equipment Layout Front	SAP No : Qty :-25Nos	ALL DIMENSION ARE IN mm NOT TO SCALE
					Customer: Bihar State Power Transmission Corporation Limited, Project :			
							Drq. No:- 145-KV-3150-CB-ELF	

145KV-3150A-SF6-15-46