



HANGER ROD DETAIL

NOTES:-

1. ALL DIMENSIONS ARE IN MM.
2. MATERIAL MILD STEEL TO IS -2062 FOR HANGER BODY.
3. TO BE GALVD. AS PER IS 2629:1966 AFTER MANUFACTURE.
4. THREADS TO BE UNDER CUT FOR GALVANIZING.
5. ABOVE DIMENSION TOBE FOLLOWED FOR FABRICATION.
6. WELDING TO STD.IS 823 OF 1964 OR BS 1856.
7. WELDING TOBE DONE AFTER MANUFACTURE OF HANGER BODY.

BIHAR STATE POWER TRANSMISSION COMPANY LTD

DRAWN BY		DESCRIPTION	132 KV D/C TOWER DETAILS OF HANGER		SCALE	-
CHECKED BY		DRG NO	132KV-Hanger-07	SHEET NO 1-1	REV.	0