



- NOTES:-**
1. ALL DIMENSIONS ARE IN M.M.
  2. ALL HOLES ARE 17.5MM DIA TO SUIT 16MM DIA BOLTS.
  3. BLANK HOLES AT GATE ARE TO RECEIVE BARBED WIRE.
  4. ONE 3 MM SPRING WASHER TO BE PROVIDED UNDER EACH NUT.
  5. BARBED WIRE SHALL BE CONFORM TO IS-278-1978.
  6. STEEL WT. 31.08 KG.
  7. B/N WT. 3.7 KG.

**SECTION B-B**  
(METHOD OF WRAPPING BARBED WIRE)

**GATE DETAILS PLAN AT 'AA'**

<b>BIHAR STATE POWER TRANSMISSION COMPANY LTD</b>				
		<b>220KV D/C TOWER DETAILS OF ANTICLIMBING DEVICE</b>	SCALE -	
		<b>DRG NO</b>	220KV-Anticlimb-01	SHEET NO 1-1
			REV.	0

DRAWN BY	
CHECKED BY	
APPROVED BY	