



**NOTES:-**

1. ALL DIMENSIONS ARE IN MM.
2. M.S PALTE 1.6 MM THICK (MIN)
3. WHITE ENAMELLED BACK GROUND AND RED ENAMELLED LETTERING
4. EQUAL NO.OF CKT.PLATES FOR EACH CKTS ARE TO BE SUPPLIED
5. 2 NOS. 16 MM DIA HRH BOLTS X35 MM LONG TO BE SUPPLIED ALONG WITH EACH PLATE
6. 2 NOS. 2MM THK.LEAD WASHERS TOBE PROVIDED WITH EACH PLATE
7. CORNERS SHOULD BE ROUNDED OFF
8. REQUIREMENT 2 PCS/TOWER

**BIHAR STATE POWER TRANSMISSION COMPANY LTD**

DRAWN BY		DESCRIPTION	220KV D/C TOWER DETAILS OF CIRCUIT PLATE	SCALE	
CHECKED BY				-	
APPROVED BY		DRG NO	220KV-Circuit-plate-03	SHEET NO 1-1	REV. 0