

## NOTES:-

- 1. ALL DIMENSIONS ARE IN MM.
- 2. MATERIAL MILD STEEL TO IS -2062 FOR HANGER BODY.
- 3. TO BE GALVD. AS PER IS 2629:1966 AFTER MANUFACTURE.
- 4. THREADS TO BE UNDER CUT FOR GALVANIZING.
- 5. ABOVE DIMENSION TOBE FOLLOWED FOR FABRICATION.
- 6. WELDING TO STD.IS 823 OF 1964 OR BS 1856.
- 7. WELDING TOBE DONE AFTER MANUFACTURE OF HANGER BODY.

BIHAR	STATE	POWER	<b>TRANSMISSION</b>	COMPANY	LTI
DIHAN	SIAIL	LOMEN	INTIGOTON	COMPANI	

DRAWN BY		DESCRIPTION	220 ET D/C TOWED DETAILS OF HANCED		SCALE	
CHECKED BY			220 KV D/C TOWER DETAILS OF HANGER			-
APPROVED BY		DRG NO	220KV-Hanger-07	SHEET NO 1-1	REV.	0