



BAR BENDING SCHEDULE FOR FOUNDATION							
MARK No.	SHAPE OF THE BAR	DIA (mm)	LENGHT (mm)	Nos. Leg	Unit Wt. (Kg/m)	Wt./Leg. (Kg)	Wt./Tower (Kg)
A		10	2390	24	0.617	35.391	141.564
B		10	1380	6	0.617	5.108	20.432
C		10	2814	14	0.617	22.579	90.316
D		20	3350	8	2.466	66.088	264.352
E		8	1550	13	0.390	7.86	31.434
F		8	1166	13	0.390	5.912	23.646
TOTAL REINFORCEMENT							571.74



QUANTITIES/TOWER	
EXCAVATION VOLUME	= 93.409 Cu.M
CONCRETE (1:1.5:3)	= 9.153 Cu.M
CONCRETE (1:3:6)	= 1.24 Cu.M
REINFORCEMENT	= 571.74 Kgs.



TYPE OF TOWER : DA+0

TOWER SLOPE TAN ALPHA = 0.09760541						
LEVEL	STUB	CG OF STUB	P	M	N	CLEAT DETAILS
+0M	HT 90*90*6	24.2	4548	5041	7129	MS 80*80*6 NO. OF PAIRS 2 3 BOLTS/PAIR

NOTES:-

- DRAWING NOT TO SCALE.
- ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE STATED.
- REINFORCED BAR USED Fe 415 CONFORMING TO IS 1786-1985
- MIX PROPERTIES CONFORMING TO IS 456-2000
- CONCRETE MIX USED GRADE M-20 (NOMINAL MIX 1:1.5:3)
LEAN CONCRETE MIX USED GRADE M-10 (NOMINAL MIX 1:3:6)
- WHENEVER NECESSARY TO CLEAR STUB AND CLEAT STIRRUPS AND BARS ARE TO BE ADJUSTED AT SITE.
- CLEAR COVER TO THE MAIN REINFORCEMENT BARS SHALL BE 50MM UNLESS OTHERWISE SPECIFIED.
- FOR CLEAT AND STUB TEMPLATE DETAILS PLEASE REFER RESPECTIVE STUB DRG.

THE FOUNDATION HAS BEEN DESIGNED FOR THE FOLLOWING PARAMETERS:	
TYPE OF SOIL	: FS
UNIT WEIGHT	: 940 Kg/Cu.M
BEARING CAPACITY	: 13675 Kg/Sq.M
ANGLE OF REPOSE	: 15 Degrees
WATER TABLE	: 0M TO 0.75M BELOW G.L.

BIHAR STATE POWER TRANSMISSION COMPANY LTD

DRAWN BY	DESCRIPTION	132KV D/C "DA+0" TOWER FOUNDATION DRAWING OF TYPE - FS		SCALE
CHECKED BY				-
APPROVED BY	DRG NO	132KV-D/C-0-Fdn-FS-14	SHEET NO 1-1	REV. 0