



BAR BENDING SCHEDULE FOR FOUNDATION							
MARK No.	SHAPE OF THE BAR	DIA (mm)	LENGHT (mm)	Nos. Leg	Unit Wt. (Kg/m)	Wt./Leg. (Kg)	Wt./Tower (Kg)
A		10	3400	66	0.617	138.455	553.820
B		10	1930	16	0.617	19.053	76.212
C		10	3624	36	0.617	80.496	321.984
D		25	3350	8	3.854	103.260	413.040
E		8	1750	13	0.390	8.873	35.492
F		8	1278	13	0.390	6.479	25.916
TOTAL REINFORCEMENT							1426.464

TOWER SLOPE TAN ALPHA = 0.20035

EXCAVATION PLAN DETAILS						
LEVEL	STUB	CG OF STUB	P	M	N	CLEAT DETAILS
+0M	HT110*110*10	30.9	10295	11324	16015	MS 100*100*6 NO. OF PAIRS 2 4 BOLTS/PAIR
+3M	HT110*110*10	30.9	11526	12549	17747	
+6M	HT110*110*10	30.9	12720	13751	19447	

QUANTITIES/TOWER	
EXCAVATION VOLUME	= 173.28 Cu.M
CONCRETE ( 1:1.5:3)	= 17.16 Cu.M
CONCRETE ( 1:3:6)	= 2.45 Cu.M
REINFORCEMENT	= 1426.464 Kgs.

**NOTES:-**

- DRAWING NOT TO SCALE.
- ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE STATED.
- REINFORCED BAR USED Fe 415 CONFORMING TO IS 1786-1985
- MIX PROPERTIES CONFORMING TO IS 456-2000
- CONCRETE MIX USED GRADE M-20 (NOMINAL MIX 1:1.5:3)  
LEAN CONCRETE MIX USED GRADE M-10 (NOMINAL MIX 1:3:6)
- WHENEVER NECESSARY TO CLEAR STUB AND CLEAT STIRRUPS AND BARS ARE TO BE ADJUSTED AT SITE.
- CLEAR COVER TO THE MAIN REINFORCEMENT BARS SHALL BE 50MM UNLESS OTHERWISE SPECIFIED.
- FOR CLEAT AND STUB TEMPLATE DETAILS PLEASE REFER RESPECTIVE STUB DRG.

THE FOUNDATION HAS BEEN DESIGNED FOR THE FOLLOWING PARAMETERS:

TYPE OF SOIL : PS  
 UNIT WEIGHT : 1440/940 Kg/Cu.M  
 BEARING CAPACITY : 13675 Kg/Sq.M  
 ANGLE OF REPOSE : 30/15 Degrees  
 WATER TABLE : 0.75M TO 1.5M FROM G.L

**BIHAR STATE POWER TRANSMISSION COMPANY LTD**

DRAWN BY		DESCRIPTION	220KV D/C "DC+0/3/6" TOWER FOUNDATION DRAWING OF TYPE - PS		SCALE
CHECKED BY			DRG NO	220KV-D/C-+0/3/6-Fdn-PS-33	SHEET NO 1-1
APPROVED BY					