



NOTES:-

1. ALL DIMENSIONS ARE IN MM & LEVELS IN METERS.
2. $\pm 0.00M$ SHALL CORRESPOND TO FINISHED GROUND LEVEL OF SWITCHYARD.
3. STRUCTURAL CONCRETE SHALL BE OF GRADE M20 AS PER IS 456 & R/F STEEL OF GRADE Fe 415 AS PER IS 1786.
4. LAP LENGTH SHALL BE 47 TIMES THE DIAMETER OF BAR.
5. CLEAR COVER TO ALL REINFORCEMENT SHALL BE AS BELOW:
 - a) FOR FOUNDATIONS = 50MM
 - b) FOR PEDESTALS = 40MM

6. ALL HOOKS, BENDS, LAPS AND SPLICES SHALL BE AS PER IS:456(LATEST) & IS:2502 (LATEST) UNLESS NOTED OTHERWISE.
7. NO FOUNDATION SHALL REST ON FILLED UP SOIL, MINIMUM DEPTH OF FOUNDATION BELOW VIRGIN GROUND LEVEL SHALL BE 500mm.
8. FOUNDATION BOLT SHALL BE PLACED IN POSITION BEFORE THE CONCRETE IS CAST.
9. IF FOUNDATION BOLTS FOULS WITH STIRRUPS THE STIRRUPS CAN BE MODIFIED BY SITE TO SUIT THE REQUIREMENT.
10. NOT MORE THAN SIX BAR SHALL BE LAPPED AT ANY SECTION & LAP SHALL BE STAGGERED.
11. WHEN MINOR FOUNDATION OVER LAPPING WITH MAIN FOUNDATION, GAP SHOULD BE FILLED WITH WELL COMPACTED SAND.
12. FOR DETAIL OF FOUNDATION BOLT, REFER SEPARATE DRAWING.

CUSTOMER	BIHAR STATE POWER TRANSMISSION COMPANY LTD.				
CONTRACTOR					
LOA NO					
PROJECT					
DRG. TITLE	132KV TOWER TYPE "IT3" FOUNDATION				
DRG. NO	BSPTCL/132KV/06				
DRG. REF. NO.					
SCALE	N.T.S.	JOB NO.		SHEET	01 OF 01