

FINISHING SCHEDULE- CRB

S.NO	ITEM DESCRIPTION	AREA
1	METALLIC HANDREN FLOORING 12MM THICK	AREA
2	WHITENED TILES FLOORING	LOBBY, BATTERY ROOM, GUEST ROOM, LANDING, LOUNGE, DINING, WAITING, CONFERENCE ROOM, TEST LAB, A.E. ROOM, J.E. ROOM
3	ANTI SKID 300 mm x 300 mm TILES FLOORING	STORE, TOILET (H/S), PANTRY, KITCHEN & STAIRCASE
4	ACID PROOF FLOOR	BATTERY ROOM
1	CERAMIC GLAZED TILES 300mm x 300mm x 20mm, DADO 2.1 m HEIGHT.	KITCHEN, TOILET & PANTRY
1	BLACK GRANITE STONE 18mm	PLATFORM
1	PRIMER, CEILING PUTTER OR OTHER ROUGH COAT	KITCHEN PLATFORM
2	PAINT - OIL (CONT), WHITE COLOR	INTERNAL WALLS SURFACE & CEILING
2	EXTERNAL FINISHING	EXTERNAL WALL SURFACE & CEILING
1	2 COATS OF CEMENT BASED PAINT OVER A COAT OF PRIMER	EXTERNAL WALL


FE SCHEDULES OF DOORS & WINDOWS

SL. NO	TYPE	WIDTH	CHILL LVL.	HEIGHT	DESCRIPTION
1.	D	900	0.00	2013	SIN. LEAF DOOR
2.	D1	750	0.00	2013	SIN. LEAF DOOR
3.	W	2000	750	1220	FULLY GLA. WIN.
4.	W1	1500	750	1220	FULLY GLA. WIN.
5.	W2	1000	900	1000	FULLY GLA. WIN.
6.	V	450	1650	450	AWNING WIN.

GF SCHEDULES OF DOORS & WINDOWS

SL. NO	TYPE	WIDTH	CHILL LVL.	HEIGHT	DESCRIPTION
1.	D	2700	0.00	2100	DOUBLE DOOR
2.	D1	1200	0.00	2100	DOUBLE DOOR
3.	D2	1200	0.00	2013	DOUBLE DOOR
4.	D3	750	0.00	2013	SIN. LEAF DOOR
5.	W	2300	900	1200	FULLY GLA. WIN.
6.	W1	1800	900	1200	FULLY GLA. WIN.
7.	V	500	1650	500	AWNING WIN.

- NOTES:-**
1. ALL DIMENSIONS ARE IN mm. & ALL LEVELS IN M.
 2. FINISHED GROUND LEVEL (FGL) IS MARKED AS (+)0.00 M.
 3. ANTI TERMITTE TREATMENT SHALL BE PROVIDED.
 4. PROVIDE 1.0 M WIDE PLINTH PROTECTION ALL AROUND.
 5. DRAWING PREPARED BASED ON 230 THK. BRICK WORK.
 6. ALL EXTERIOR SURFACES SHALL BE PAINTED WITH WEATHER PROOF PAINT.



REFERENCE NO.	DESCRIPTION	LEGEND	REV. NO.	DESCRIPTION	DATE	DRAWN	REVIEW	ELE. CHECKED	MECH. APPROVED	STATUS
1			0		05.08.19	SS	SS/MS			APPROVAL

CLIENT:	PROJECT:	SUBSTATION	CONTRACT No.	TITLE:
BIHAR STATE POWER TRANSMISSION COMPANY LIMITED	CONSTRUCTION OF 132/33KV GRID SUB-STATIONS AT ARARIA (2x50 MVA), BARSOI (2x20 MVA), BASI (2x20 MVA) AND DHAMDAH (2x20 MVA)	132/33 KV GRID SUB-STATION - PKG-92	1.1331/TRANS/MISC/343/2014, DATED 21.03.15	ARCHITECTURAL DRAWING FOR SWITCHBOARD CONTROL ROOM BUILDING COMMON FOR ALL FOUR S/S UNDER, PKG-92

DATE	NAME	DATE	NAME
05.08.19	SS	05.08.19	SS/MS

DATE	NAME	DATE	NAME
05.08.19	SS	05.08.19	SS/MS

DATE	NAME	DATE	NAME
05.08.19	SS	05.08.19	SS/MS

DATE	NAME	DATE	NAME
05.08.19	SS	05.08.19	SS/MS

DATE	NAME	DATE	NAME
05.08.19	SS	05.08.19	SS/MS

DATE	NAME	DATE	NAME
05.08.19	SS	05.08.19	SS/MS

ALSTOM ARCHITECTURAL DRAWING FOR SWITCHBOARD CONTROL ROOM BUILDING COMMON FOR ALL FOUR S/S UNDER, PKG-92

ALSTOM INDIA LTD. DRAWING NO. 5427PK97-COMMON-C-3VD-SYS-0040-AR

TOTAL SH. 1 SH. NO. 1 REV. 0