

12th Plan

| Sl. No. | Executing Agency | Grid Sub-station | Transformation Capacity (MVA) | | Total Capacity in MVA at different voltage level | | | | | Remarks |
|--------------|------------------|-------------------------|-------------------------------|------------------------------|--|------------|-------------------|--------------------|----------------------|---------|
| | | | Existing Capacity | Augmented/ Final Capacity | 400/220 | 220/132 | 132/33 | | | |
| | | | | | | | Existing Capacity | Augmented Capacity | Increase in Capacity | |
| 1 | BSPTCL | 220/132/33 kV Laukahi | - | 2x160+2x50 | - | 320 | - | - | 100 | |
| 2 | | 220/132/33 kV Bihta | - | 2x160+2x50 | - | 320 | - | - | 100 | |
| 3 | | 220/132/33 kV Khagaria | - | 2x160+2x50 | - | 320 | - | - | 100 | |
| 4 | | 132/33 kV Banka | - | 3x50 | - | - | - | - | 150 | |
| 5 | | 132/33 kV Siwan (New) | - | 3x50 | - | - | - | - | 150 | |
| 6 | | 132/33 kV Jamui | - | 3x50 | - | - | - | - | 150 | |
| 7 | | 132/33 kV Warsaliganj | - | 3x50 | - | - | - | - | 150 | |
| 8 | | 132/33 kV Korha | - | 3x50 | - | - | - | - | 150 | |
| 9 | | 132/33 kV Nathnagar | - | 3x50 | - | - | - | - | 150 | |
| 10 | | 132/33 kV Pakridayal | - | 2x20 | - | - | - | - | 40 | |
| 11 | | 132/33 kV Sahpur Patori | - | 2x20 | - | - | - | - | 40 | |
| 12 | | 132/33 kV Barsoi | - | 2x20 | - | - | - | - | 40 | |
| 13 | | 132/33 kV Jhanjharpur | - | 2x10 | - | - | - | - | 20 | |
| 14 | | 132/33 kV Bakhri | - | 2x20 | - | - | - | - | 40 | |
| 15 | | 132/33 kV Benipur | - | 2x20 | - | - | - | - | 40 | |
| 16 | | 132/33 kV Paliganj | - | 2x50 | - | - | - | - | 100 | |
| TOTAL | | | | | - | 960 | - | - | 1520 | |