

602



BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
 A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
 CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
 Head Office, VidyutBhawan, Bailey Road, Patna - 800021

File No. slde/TAFM (Part-5)-26/2019

Date

Letter No.

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL

Sub: Transmission System Availability Certificate for BSPTCL for the month of March'2021
 Ref: CE Trans. (O&M) U.O.I No. 158 dated 16.04.21

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of March'21, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month March'21, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.686%**.

Yours faithfully

Sd/-

Chief Engineer (System Operation)
BSPTCL, Patna

Dated.....07/05/21

Memo No. 201

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.

R.Y

f SLTS
 07.05.21
Chief Engineer (System Operation)
BSPTCL, Patna

TNAI	
920	481.96
504	154.71
152	20
06	8



600 598

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidhut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - cc.trans664@gmail.com
Fax No. 0612-2504655 Website – www.bsptcl.in

File No. File No. slde/TAFM (Part-5)-26/2019

Letter No. 260

Date 07/05/21

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDCCL
2. Chief Engineer (Commercial)
SBPDCL

Sub: BSPTCL Transmission system availability Certification for the month March-2021 for FY-2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month March-2021 as detailed below :-

Month- March-2021	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDCCL	% Availability of BSPTCL Transmission system
220KV Trans. Line	98.22	99.25	98.90
220/132 Kv ICTs	99.84	99.96	99.89
132KV Trans. Line	99.82	99.48	99.62
132/33 Kv ICTs	99.90	99.98	99.94
220KV Trans. System	98.97	99.53	99.33
132KV Trans. System	99.86	99.74	99.78
Overall Trans. System	99.51	99.66	99.686

Yours faithfully

Sd/-

Chief Engineer (System Operation)
BSPTCL, Patna

Pu

Memo No.....**200**

Dated:.....**07/05/21**

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.

f ²⁻¹⁸
07-05-21
Chief Engineer (System Operation)
BSPTCL, Patna

2-4

(568)



BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889

[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, VidyutBhawan, Bailey Road, Patna - 800021

File No. slide TAFM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

- 1. Chief Engineer (Commercial)**
NBPDCL
- 2. Chief Engineer (Commercial)**
SBPDCL

Sub: Transmission System Availability Certificate for BSPTCL for the month of February 2021
Ref: CE Trans. (O&M) U.O.I No. 91 dated 18.02.21

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of February'21, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month February'21, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.624%**.

Yours faithfully

Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna


Dated.....

19-03-21

Memo No.....

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

R-u



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website – www.bsptcl.in

569

File No. File No. slide/TAEM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL

Sub: BSPTCL Transmission system availability Certification for the month February-2021 for FY-2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month February-2021 as detailed below :-

Month-February-2021	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDC	% Availability of BSPTCL Transmission system
220KV Trans. Line	99.43	99.68	99.51
220/132 Kv ICTs	99.22	99.82	99.55
132KV Trans. Line	99.72	99.80	99.75
132/33 Kv ICTs	99.95	99.91	99.93
220KV Trans. System	99.75	99.35	99.53
132KV Trans. System	99.86	99.83	99.84
Overall Trans. System	99.82	99.63	99.624

Yours faithfully

Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

P. 4

TNA:
340.633
144.017
61.03
141.65

19-03-21

Dated:.....

148

Memo No.....

Copy forwarded to

1. Secretary, BEREC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.



(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

Pa

(535)

M.C.L.
11
1111
1111
1111

BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, VidyutBhawan, Bailey Road, Patna - 800021

File No. slde TAFM (Part-5)-26-2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL

Sub: Transmission System Availability Certificate for BSPTCL for the month of January'2021
Ref: CE Trans. (O&M) U.O.I No. 91 dated 18.02.21

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of January'21, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month January'21, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.62%**.

Yours faithfully

Sd/-

(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

Dated.....

Memo No.

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F & A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL

for kind information and necessary action.

(A.K. Chaudhary)

Chief Engineer (System Operation)
BSPTCL, Patna

R.Y



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - cc.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptel.in

File No. File No. sldc/TAEM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDCCL
2. Chief Engineer (Commercial)
SBPDCL

Sub: BSPTCL Transmission system availability Certification for the month January-2021 for FY-2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month January-2021 as detailed below :-

Month- January-2021	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDCCL	% Availability of BSPTCL Transmission system
220KV Trans. Line	99.3	98.75	98.93
220/132 Kv ICTs	99.82	99.54	99.7
132KV Trans. Line	99.81	99.37	99.55
132/33 Kv ICTs	99.84	99.81	99.83
220KV Trans. System	99.54	99.06	99.3
132KV Trans. System	99.83	99.6	99.7
Overall Trans. System	99.71	99.38	99.62

Yours faithfully

Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna


97
Memo No.....

Dated:..... 01-03-21

Copy forwarded to

1. Secretary, BERC, Patna for kind information. ✓
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.

K-4


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

506

BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
 A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
 CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
 Head Office, VidyutBhawan, Bailey Road, Patna – 800021



File No. slde/TAFM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDCCL
2. Chief Engineer (Commercial)
SBPDCL

Sub: Transmission System Availability Certificate for BSPTCL for the month of December'2020
 Ref: CE Trans. (O&M) U.O.I No. 36 dated 15.01.21

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of December'20, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month December'2020, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.64%**.

Yours faithfully


Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

Memo No...58...

Dated...02/02/2021

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

P-4



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - cc.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptel.in

(504)

File No. File No. slide/TAEM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDCCL
2. Chief Engineer (Commercial)
SBPDCL

Sub: BSPTCL Transmission system availability Certification for the month December-2020 for FY-2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month December-2020 as detailed below :-

Month-	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDCCL	% Availability of BSPTCL Transmission system
December-2020			
220KV Trans. Line	99.33	98.89	99.03
220/132 Kv ICTs	99.77	99.84	99.80
132KV Trans. Line	99.45	99.39	99.41
132/33 Kv ICTs	99.81	99.88	99.84
220KV Trans. System	99.54	99.27	99.37
132KV Trans. System	99.65	99.64	99.64
Overall Trans. System	99.61	99.49	99.64

Yours faithfully

Sd/-

(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna


Ry

Dated: 02/02/2021

Memo No.....57...

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna



BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889

[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, VidyutBhawan, Bailey Road, Patna – 800021

File No. slde/TAFM (Part-5)-26/2019

Letter No. 02

Date 05/01/21

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,


1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL

Sub: Transmission System Availability Certificate for BSPTCL for the month of November'2020
Ref: CE Trans. (O&M) U.O.I No. 327 dated 18.12.20

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of November'20, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month November'2020, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.716%**.

Yours faithfully



(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

Dated..... 05/01/21

Memo No. 02

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna



File No. File No. sldo/TAFM (Part-5)-26/2019

Letter No. 1

Date 05/01/21

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL


Sub: BSPTCL Transmission system availability Certification for the month November-2020 for FY-2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month November-2020 as detailed below :-

Month- November- 2020	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDC	% Availability of BSPTCL Transmission system
220KV Trans. Line	99.41	99.53	99.49
220/132 Kv ICTs	99.97	100	99.98
132KV Trans. Line	99.69	99.63	99.66
132/33 Kv ICTs	99.96	99.99	99.97
220KV Trans. System	99.67	99.72	99.70
132KV Trans. System	99.84	99.81	99.82
Overall Trans. System	99.77	99.78	99.716

Yours faithfully


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

R.4

Memo No.....01

Dated: 05/01/21

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F & A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.

R. M.

(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna



BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
SAVE ENERGY FOR BENEFIT OF SELF AND NATION!
Head Office, VidyanBhawan, Bailey Road, Patna - 800021

File No. slide TAFM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDCL
2. Chief Engineer (Commercial)
SBPDCL

Sub: Transmission System Availability Certificate for BSPPTCL for the month of October'2020
Ref: CE Trans. (O&M) U.O.1 No. 386 dated 12.11.20

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of September'20, computed in accordance with the BERCL (Multi Year Transmission Tariff) Regulations, 2018.
The overall Transmission System Availability of the Transmission network for the month October'2020, computed in accordance with Appendix-II of the BERCL (MYT) Regulations, 2018, and after considering the provisions of BERCL (MYT) Regulations, 2018, is **99.71%**.

Yours faithfully

Sd/-

(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPPTCL, Patna

Dated...07/12/20

Memo No. 342

Copy forwarded to

1. Secretary, BERCL, Patna for kind information.
 2. GM (F & A), BSPPTCL, for kind information and necessary action.
 3. CE (PMC), BSPHCL
- for kind information and necessary action.

(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPPTCL, Patna

2/2



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CTN - U40102BR2012SGC 018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidya Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans@bptcl.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. 116-NB-TAN/Part-5/26/2019
Letter No. 341

Date 02/12/20

100

To,
Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

From
1. Chief Engineer (Commercial)
NBPDCL
2. Chief Engineer (Commercial)
SBPDCL
Sib: BSPTCL Transmission system availability Certification for the month October-2020 for
FY -2020-21

Sir,
With reference to above, Transmission system availability certification of BSPTCL
System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month
October-2020 as detailed below :-

Month-	%Availability of	% Availability of BSPTCL	% Availability of
October-2020	BSPTCL Transmission system under SBPDCL	Transmission system under NBPDCL	BSPTCL Transmission system
220KV Trans. Line	99.99	99.45	99.63
220/132 KV ICTs	99.93	99.89	99.91
132KV Trans. Line	99.67	99.78	99.73
132/33 KV ICTs	99.98	99.97	99.98
220KV Trans. System	99.96	99.63	99.75
132KV Trans. System	99.84	99.88	99.86
Overall Trans. System	99.89	99.77	99.71

Yours faithfully

Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

100

492


Memo No.: 341.....

Dated:.....07/12/20

Copy forwarded to

1. Secretary, BERG, Patna for kind information.
 2. GM (F & A), BSP TCL for kind information and necessary action.
 3. CE (PWC), BSPHCL
- for kind information and necessary action.

Ru


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSP TCL, Patna

BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889

ISAVE ENERGY FOR BENEFIT OF SELF AND NATION!
Head Office, VidyutBhawan, Banley Road, Patna - 800021

File No. side/TAFM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPPTCL, Patna

To,

- 1. Chief Engineer (Commercial)**
NBPPDCL
- 2. Chief Engineer (Commercial)**
SBPPDCL

Sub: Transmission System Availability Certificate for BSPPTCL for the month of September 2020
Ref: CE Trans. (O&M) U.O.I No. 328 dated 25.09.20

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of September'20, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month September'2020, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.72%**.

Yours faithfully

Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPPTCL, Patna

Dated...: 22 | 10 | 2020

Memo No...: 301

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
 2. GM (F & A), BSPPTCL for kind information and necessary action.
 3. CE (PMC), BSPHCL
- for kind information and necessary action.

(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPPTCL, Patna

R-V

108

108



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102HR2012SGC-018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce@trans664@gmail.com
Fax No. 0612-2504655 Website - www.bspdtcl.in

4/0

File No. File No. sdt/TAM/ Patn-5/-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPDTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDCL
2. Chief Engineer (Commercial)
SBPDCL

Sub: BSPDTCL Transmission system availability Certification for the month September-2020 for
FY-2020-21

Sir:

With reference to above, Transmission system availability certification of BSPDTCL
System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month
September-2020 as detailed below :-

Month-	%Availability of	% Availability of	% Availability of
September-2020	BSPDTCL Transmission system under SBPDCL	Transmission system under NBPDCL	BSPDTCL Transmission system
220KV Trans.	99.23	99.02	99.09
Line			
220/132 Kv	99.96	99.99	99.97
ICTs			
132KV Trans.	99.68	99.49	99.58
Line			
132/33 Kv	99.98	99.97	99.98
ICTs			
220K V Trans.	99.58	99.41	99.47
System			
132K V Trans.	99.84	99.74	99.79
System			
Overall Trans.	99.74	99.60	99.72
System			

Yours faithfully

Sd/-

(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPDTCL, Patna

fw

Memo No...207

Dated: 22/10/2020

- Copy forwarded to
1. Secretary, BERCL, Patna for kind information.
 2. GM (F & A), BSPPTCL for kind information and necessary action.
 3. CE (EMO), BSPPHCL for kind information and necessary action.



(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPPTCL, Patna

for



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889

[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

253

File No. File No. slide/TAEM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL

Sub: BSPTCL Transmission system availability Certification for the month April-2020 for FY-
2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month April-2020 as detailed below :-

Month-April-2020	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDC	% Availability of BSPTCL Transmission system
220KV Trans. Line	99.50	99.51	99.83
220/132 Kv ICTs	99.99	100	99.99
132KV Trans. Line	99.90	99.51	99.67
132/33 Kv ICTs	99.97	99.99	99.98
220KV Trans. System	99.73	99.32	99.83
132KV Trans. System	99.94	99.76	99.37
Overall Trans. System	99.86	99.58	99.51

Yours faithfully

Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

o/c


R

Memo No.....151

Dated:.....26.05.20

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F & A), BSPTCL for kind information and necessary action.
- 3 ✓ CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chandrahary)
Chief Engineer (System Operation)
BSPTCL, Patna

Ru



BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, VidyutBhawan, Bailey Road, Patna - 800021

File No. slide/TAFM (Part-5)-26/2019

Letter No. **152**

Date **26.05.20**

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,


1. Chief Engineer (Commercial)
NBPDCI.
2. Chief Engineer (Commercial)
SBPDCL.

Sub: Transmission System Availability Certificate for BSPTCL for the month of April 2020
Ref: CE Trans. (O&M) U.O.I No. 198 dated 20.05.2020

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of April'20, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month April'2020, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.51%**.

Yours faithfully


(A.K. Chaudhary)

Chief Engineer (System Operation)
BSPTCL, Patna

Dated..... **26.05.20**

Memo No. **152**

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chaudhary)

Chief Engineer (System Operation)
BSPTCL, Patna

R.M. 

R.M.

293

BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, VidyutBhawan, Bailey Road, Patna – 800021

File No. slde/TAFM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL

Sub: Transmission System Availability Certificate for BSPTCL for the month of May 2020
Ref: CE Trans. (O&M) U.O.I No. 230 dated 23.06.2020

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of May'20, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month May 2020, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.66%**.

Yours faithfully


Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

Dated..... 29/06/2020

Memo No..... 198

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

RW



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889

(292)

[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]

Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - cc.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. File No. slide/AFM (Part-5)-26/2019

Letter No.

197

Date

29/06/2020

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL

Sub: BSPTCL Transmission system availability Certification for the month May-2020 for FY-2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month May-2020 as detailed below :-

Month-	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDC	% Availability of BSPTCL Transmission system
May-2020			
220KV Trans. Line	99.58	98.05	98.54
220/132 Kv ICTs	99.91	99.61	99.78
132KV Trans. Line	99.00	99.00	99.00
132/33 Kv ICTs	99.90	99.94	99.92
220KV Trans. System	99.73	98.68	99.07
132KV Trans. System	99.48	99.49	99.48
Overall Trans. System	99.59	99.15	99.66

Yours faithfully

Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna


240

Memo No...199

Dated: 29/06/2020

Copy forwarded to

1. Secretary, BLRC, Patna for kind information.
2. GM (F & A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chandra)
Chief Engineer (System Operation)
BSPTCL, Patna

DFA-II

(34)

17601
8/20

BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, VidyutBhawan, Bailey Road, Patna – 800021

File No. sldc/TAFM (Part-5)-26/2019

Letter No. 220

Date 07/08/2020

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,


1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL

Sub: Transmission System Availability Certificate for BSPTCL for the month of June 2020
Ref: CE Trans. (O&M) email dated 24.07.2020

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of June'20, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month June'2020, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.51%**.

Yours faithfully,



(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

Dated..07/08/2020

Memo No. 220

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

R.K



DFA-1

1320

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889

[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. File No. sldc/TAFM (Part-5)-26/2019

Letter No. 221

Date 08/08/2020

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL


Sub: BSPTCL Transmission system availability Certification for the month June-2020 for FY-2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month June-2020 as detailed below :-

Month- June-2020	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDC	% Availability of BSPTCL Transmission system
220KV Trans. Line	99.72	97.88	98.5
220/132 Kv ICTs	99.89	99.98	99.93
132KV Trans. Line	99.70	99.31	99.47
132/33 Kv ICTs	99.80	99.96	99.87
220KV Trans. System	99.80	98.72	99.64
132KV Trans. System	99.75	99.65	99.17
Overall Trans. System	99.77	99.25	99.51

Yours faithfully


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna


P.22

Memo No. 221

Dated: 02/08/2020

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

2-4



(349)

BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, VidyutBhawan, Bailey Road, Patna – 800021

File No. slde/TAFM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. **Chief Engineer (Commercial)**
NBPDCL
2. **Chief Engineer (Commercial)**
SBPDCL

Sub: Transmission System Availability Certificate for BSPTCL for the month of July 2020
Ref: CE Trans. (O&M) email dated 26.08.2020

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of July'20, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month July 2020, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.71%**.

Yours faithfully

Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

Dated.....**31.08.20**

Memo No. **232**

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.

(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

R.4



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

398

File No. File No. slde/TAFM (Part-5)-26/2019

Letter No.

Date

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

- 1. Chief Engineer (Commercial)**
NBPDCL
- 2. Chief Engineer (Commercial)**
SBPDCL

Sub: BSPTCL Transmission system availability Certification for the month July-2020 for FY-2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month July-2020 as detailed below :-

Month- July-2020	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDCL	% Availability of BSPTCL Transmission system
220KV Trans. Line	98.54	99.06	98.89
220/132 Kv ICTs	99.93	99.94	99.93
132KV Trans. Line	99.24	99.30	99.27
132/33 Kv ICTs	99.98	99.98	99.98
220KV Trans. System	99.18	99.40	99.33
132KV Trans. System	99.64	99.65	99.65
Overall Trans. System	99.47	99.56	99.71

Yours faithfully

Sd/-
(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

2.14
Ae

Memo No. 231

Dated: 31.08.20

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL
for kind information and necessary action.



(A.K. Choudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

R-4

DFA-1

376

BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, VidyutBhawan, Bailey Road, Patna - 800021



File No. slde/TAFM (Part-5)-26/2019

Date

Letter No.

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,


1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL

Sub: Transmission System Availability Certificate for BSPTCL for the month of August 2020
Ref: CE Trans. (O&M) U.O.I No. 328 dated 25.09.20

With reference to the above, SLDC has received the computation of transmission system availability with interruption details of Transmission network for the month of August'20, computed in accordance with the BERC (Multi Year Transmission Tariff) Regulations, 2018.

The overall Transmission System Availability of the Transmission network for the month August 2020, computed in accordance with Appendix-II of the BERC (MYT) Regulations, 2018, and after considering the provisions of BERC (MYT) Regulations, 2018, is **99.72%**.

Yours faithfully,



(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

Dated..30/09/2020

Memo No.....271

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL for kind information and necessary action.


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

P.4



DPA - 2 (377)
Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. File No. sde/TAEM (Part-5)-26/2019

Letter No. 272

Date 30/09/2020

From

Sri. A.K. Chaudhary
Chief Engineer (System Operation)
BSPTCL, Patna

To,

1. Chief Engineer (Commercial)
NBPDC
2. Chief Engineer (Commercial)
SBPDCL


Sub: BSPTCL Transmission system availability Certification for the month August-2020 for FY-2020-21

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month August-2020 as detailed below :-

Month- August-2020	%Availability of BSPTCL Transmission system under SBPDCL	% Availability of BSPTCL Transmission system under NBPDC	% Availability of BSPTCL Transmission system
220KV Trans. Line	99.71	99.43	99.52
220/132 Kv ICTs	99.98	100.00	99.99
132KV Trans. Line	99.41	99.70	99.58
132/33 Kv ICTs	99.99	99.97	99.98
220KV Trans. System	99.85	99.65	99.72
132KV Trans. System	99.73	99.84	99.79
Overall Trans. System	99.78	99.76	99.72

Yours faithfully


(A.K. Chaudhary)
Chief Engineer (System Operation)
BSPTCL, Patna

2.0


Memo No. 272

Dated: 30/09/20

Copy forwarded to

1. Secretary, BEREC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL for kind information and necessary action.

pu


(A.K. Choudhary)
Chief Engineer (System Operation)
BSPTCL, Patna