

### Loading level of transmission elements for the month November 2020

| GSS Name              | Metering point of element       | Voltage | Element type | Peak load in MW | Date and time    | Base load in MW | Date and time    | Avg load in MW | Remarks           |
|-----------------------|---------------------------------|---------|--------------|-----------------|------------------|-----------------|------------------|----------------|-------------------|
| Ara 132 kv GSS        | ARA-PGCIL                       | 132     | Line         | 58.82           | 15-11-2020 18:00 | 13.64           | 01-11-2020 13:30 | 41.45          |                   |
| Ara 132 kv GSS        | TRF-3(LV)                       | 33      | Transformer  | 14.84           | 01-11-2020 18:45 | 2.25            | 01-11-2020 13:30 | 10.28          |                   |
| Ara 132 kv GSS        | TRF-2(LV)                       | 33      | Transformer  | 13.50           | 01-11-2020 18:45 | 2.89            | 01-11-2020 13:15 | 9.37           |                   |
| Ara 132 kv GSS        | TRF-4(LV)                       | 33      | Transformer  | 13.50           | 01-11-2020 18:45 | 2.89            | 01-11-2020 13:15 | 9.37           |                   |
| Ara 132 kv GSS        | TRF-1(LV)                       | 33      | Transformer  | 13.36           | 01-11-2020 18:45 | 2.86            | 01-11-2020 13:15 | 9.27           |                   |
| Ara 132 kv GSS        | Railway                         | 132     | Line         | 11.68           | 04-11-2020 12:15 | 0.08            | 10-11-2020 14:45 | 4.17           |                   |
| Ara 132 kv GSS        | Jagdishpur-2                    | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Ara 132 kv GSS        | Jagdishpur-1                    | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Araria 132 kv GSS     | Kishanganj                      | 132     | Line         | 51.67           | 19-11-2020 08:45 | 6.77            | 17-11-2020 14:30 | 20.35          |                   |
| Araria 132 kv GSS     | Forbesganj                      | 132     | Line         | 39.62           | 19-11-2020 08:30 | 0.02            | 12-11-2020 01:30 | 6.38           |                   |
| Araria 132 kv GSS     | TRF-1(LV)                       | 33      | Transformer  | 22.10           | 01-11-2020 20:00 | 0.14            | 21-11-2020 07:15 | 8.65           |                   |
| Araria 132 kv GSS     | TRF-2(LV)                       | 33      | Transformer  | 17.32           | 04-11-2020 18:15 | 1.45            | 18-11-2020 14:00 | 6.60           |                   |
| Areraj 132 kv GSS     | TRF-1(LV)                       | 33      | Transformer  | 8.35            | 01-11-2020 19:15 | 0.61            | 04-11-2020 11:45 | 5.09           |                   |
| Areraj 132 kv GSS     | TRF-2(LV)                       | 33      | Transformer  | 8.33            | 01-11-2020 19:15 | 0.00            | 13-11-2020 09:45 | 5.07           |                   |
| Areraj 132 kv GSS     | Bettiah                         | 132     | Line         | 16.75           | 01-11-2020 19:15 | 0.00            | 12-11-2020 20:00 | 2.22           |                   |
| Areraj 132 kv GSS     | Gopalganj                       | 132     | Line         | 16.33           | 16-11-2020 18:15 | 0.92            | 15-11-2020 23:00 | 8.22           |                   |
| Ataula 132 kv GSS     | TRF - 2                         | 33      | Transformer  | 22.75           | 15-11-2020 18:00 | 0.43            | 06-11-2020 12:00 | 14.26          |                   |
| Ataula 132 kv GSS     | TRF - 1                         | 33      | Transformer  | 22.36           | 04-11-2020 11:45 | 0.42            | 06-11-2020 12:00 | 12.75          |                   |
| Ataula 132 kv GSS     | Jehanabad-2                     | 132     | Line         | 22.88           | 15-11-2020 18:00 | 0.00            | 05-11-2020 11:45 | 14.18          |                   |
| Ataula 132 kv GSS     | Jehanabad-1                     | 132     | Line         | 22.57           | 04-11-2020 11:45 | 0.43            | 06-11-2020 12:00 | 12.77          |                   |
| Ataula 132 kv GSS     | Gohline-1                       | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Ataula 132 kv GSS     | Gohline-2                       | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Aurangabad 132 kv GSS | TRF 2                           | 33      | Transformer  | 36.86           | 25-11-2020 17:30 | 0.14            | 27-11-2020 15:15 | 11.60          |                   |
| Aurangabad 132 kv GSS | Sonenagar (Old)-1               | 132     | Line         | 34.23           | 27-11-2020 18:00 | 2.94            | 05-11-2020 15:15 | 20.64          |                   |
| Aurangabad 132 kv GSS | Sonenagar (Old)-2               | 132     | Line         | 34.15           | 27-11-2020 18:00 | 2.95            | 05-11-2020 15:15 | 20.76          |                   |
| Aurangabad 132 kv GSS | TRF 3                           | 33      | Transformer  | 22.52           | 05-11-2020 18:30 | 0.04            | 25-11-2020 15:45 | 4.30           |                   |
| Aurangabad 132 kv GSS | TRF 1                           | 33      | Transformer  | 9.47            | 05-11-2020 18:30 | 0.00            | 05-11-2020 12:45 | 5.71           |                   |
| Aurangabad 132 kv GSS | Shree Cement                    | 132     | Line         | 24.66           | 05-11-2020 01:15 | 0.18            | 03-11-2020 13:45 | 9.84           |                   |
| Baisi 132 kv GSS      | TRF-2(LV)                       | 33      | Transformer  | 11.67           | 02-11-2020 19:45 | 0.58            | 01-11-2020 12:00 | 4.07           |                   |
| Baisi 132 kv GSS      | Dalkola                         | 132     | Line         | 11.72           | 02-11-2020 19:45 | 0.60            | 01-11-2020 12:00 | 4.09           |                   |
| Baisi 132 kv GSS      | Kishanganj                      | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Bakhri 132 kv GSS     | TRF-1(LV)                       | 33      | Transformer  | 10.60           | 01-11-2020 21:30 | 0.07            | 20-11-2020 16:00 | 5.66           |                   |
| Bakhri 132 kv GSS     | TRF-2(LV)                       | 33      | Transformer  |                 |                  |                 |                  |                | Charge on no load |
| Bakhri 132 kv GSS     | Manjhaul                        | 132     | Line         | 10.72           | 01-11-2020 21:30 | 0.10            | 20-11-2020 16:30 | 5.72           |                   |
| Bakhri 132 kv GSS     | Balia                           | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Balia 132 kv GSS      | TRF-2(LV)                       | 33      | Transformer  | 23.09           | 01-11-2020 21:15 | 0.58            | 18-11-2020 12:30 | 13.31          |                   |
| Balia 132 kv GSS      | TRF-1(LV)                       | 33      | Transformer  | 4.67            | 26-11-2020 11:45 | 1.40            | 26-11-2020 11:30 | 0.00           |                   |
| Balia 132 kv GSS      | Begusarai                       | 132     | Line         | 23.36           | 01-11-2020 21:15 | 0.02            | 26-11-2020 11:15 | 13.17          |                   |
| Balia 132 kv GSS      | Bakhri                          | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Banjari 132 kv GSS    | TRF-3(LV)                       | 33      | Transformer  | 9.56            | 01-11-2020 07:00 | 0.34            | 20-11-2020 02:45 | 5.55           |                   |
| Banjari 132 kv GSS    | TRF-2(LV)                       | 33      | Transformer  | 8.97            | 01-11-2020 07:00 | 0.32            | 20-11-2020 02:45 | 5.24           |                   |
| Banjari 132 kv GSS    | TRF-1(LV)                       | 33      | Transformer  |                 |                  |                 |                  |                | Charge on no load |
| Banjari 132 kv GSS    | Kerpa                           | 132     | Line         | 20.22           | 26-11-2020 17:30 | 0.50            | 10-11-2020 12:30 | 8.40           |                   |
| Banjari 132 kv GSS    | Sasaram-2                       | 132     | Line         | 12.44           | 02-11-2020 07:30 | 0.01            | 24-11-2020 20:45 | 5.86           |                   |
| Banjari 132 kv GSS    | KCL                             | 132     | Line         | 9.70            | 28-11-2020 22:45 | 0.00            | 05-11-2020 12:15 | 3.21           |                   |
| Banjari 132 kv GSS    | Sasaram-1                       | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Banka 132 kv GSS      | BANKA-PGCIL-I                   | 132     | Line         | 45.26           | 28-11-2020 18:00 | 0.01            | 28-11-2020 16:45 | 20.06          |                   |
| Banka 132 kv GSS      | BANKA-PGCIL-II                  | 132     | Line         | 34.82           | 14-11-2020 18:30 | 0.65            | 28-11-2020 15:45 | 19.67          |                   |
| Banka 132 kv GSS      | TRF-3(LV)                       | 33      | Transformer  | 25.12           | 14-11-2020 18:30 | 0.08            | 05-11-2020 11:45 | 13.87          |                   |
| Banka 132 kv GSS      | TRF-1(LV)                       | 33      | Transformer  | 14.18           | 12-11-2020 15:45 | 0.02            | 05-11-2020 12:00 | 5.16           |                   |
| Banka 132 kv GSS      | TRF-2(LV)                       | 33      | Transformer  | 9.91            | 14-11-2020 18:30 | 0.02            | 05-11-2020 12:00 | 5.42           |                   |
| Banka 132 kv GSS      | Banka New-2                     | 132     | Line         | 24.96           | 20-11-2020 18:00 | 0.00            | 12-11-2020 16:45 | 17.11          |                   |
| Banka 132 kv GSS      | Banka New-1                     | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Banmankhi 132 kv GSS  | TRF-2(LV)                       | 33      | Transformer  | 19.09           | 01-11-2020 20:00 | 0.19            | 19-11-2020 12:45 | 9.59           |                   |
| Banmankhi 132 kv GSS  | TRF-1(LV)                       | 33      | Transformer  |                 |                  |                 |                  |                | Charge on no load |
| Banmankhi 132 kv GSS  | Dhamdaha                        | 132     | Line         | 19.38           | 01-11-2020 20:00 | 0.21            | 19-11-2020 12:45 | 9.71           |                   |
| Banmankhi 132 kv GSS  | Saharsa                         | 132     | Line         |                 |                  |                 |                  |                | Charge on no load |
| Barh 132 kv GSS       | Biharsharif CKT-1               | 132     | Line         | 31.26           | 11-11-2020 07:45 | 0.41            | 29-11-2020 17:00 | 17.53          |                   |
| Barh 132 kv GSS       | TRF-1(LV)                       | 33      | Transformer  | 15.51           | 11-11-2020 07:45 | 0.80            | 29-11-2020 10:45 | 8.69           |                   |
| Barh 132 kv GSS       | TRF-2(LV)                       | 33      | Transformer  | 15.42           | 11-11-2020 07:45 | 0.82            | 29-11-2020 10:45 | 8.64           |                   |
| Barh 132 kv GSS       | Hathidah(T at Mokamma TSS)      | 132     | Line         | 18.44           | 29-11-2020 12:45 | 0.74            | 29-11-2020 10:45 | 0.13           |                   |
| Baripahari 132 kv GSS | Biharsharif-1                   | 132     | Line         | 54.17           | 15-11-2020 18:00 | 15.35           | 27-11-2020 04:45 | 34.99          |                   |
| Baripahari 132 kv GSS | Biharsharif-2                   | 132     | Line         | 52.82           | 15-11-2020 18:00 | 14.94           | 27-11-2020 04:45 | 34.10          |                   |
| Baripahari 132 kv GSS | Harnaut                         | 132     | Line         | 45.42           | 09-11-2020 18:15 | 10.62           | 27-11-2020 04:30 | 26.83          |                   |
| Baripahari 132 kv GSS | TRF-2(LV)                       | 33      | Transformer  | 16.48           | 15-11-2020 18:00 | 3.29            | 27-11-2020 12:00 | 10.78          |                   |
| Baripahari 132 kv GSS | TRF-1(LV)                       | 33      | Transformer  | 16.00           | 15-11-2020 18:00 | 3.19            | 27-11-2020 12:00 | 10.46          |                   |
| Baripahari 132 kv GSS | TRF-3(LV)                       | 33      | Transformer  | 14.91           | 15-11-2020 18:00 | 1.14            | 27-11-2020 12:00 | 9.74           |                   |
| Baripahari 132 kv GSS | TRF-4(LV)                       | 33      | Transformer  | 14.91           | 15-11-2020 18:00 | 1.14            | 27-11-2020 12:00 | 9.74           |                   |
| Barsoi 132 kv GSS     | Purnea PG (Old Kishanganj(New)) | 132     | Line         | 32.20           | 01-11-2020 19:45 | 1.45            | 21-11-2020 06:45 | 12.56          |                   |
| Barsoi 132 kv GSS     | TRF-2(LV)                       | 33      | Transformer  | 16.17           | 01-11-2020 19:45 | 0.70            | 21-11-2020 06:45 | 6.35           |                   |
| Barsoi 132 kv GSS     | TRF-1(LV)                       | 33      | Transformer  | 15.90           | 01-11-2020 19:45 | 0.69            | 21-11-2020 06:45 | 6.24           |                   |
| Begusarai 220 kv GSS  | BTPS-2                          | 220     | Line         | 127.14          | 01-11-2020 22:00 | 0.35            | 16-11-2020 13:00 | 52.69          |                   |
| Begusarai 220 kv GSS  | BTPS-1                          | 220     | Line         | 126.28          | 01-11-2020 22:00 | 0.37            | 16-11-2020 13:00 | 50.63          |                   |
| Begusarai 220 kv GSS  | PURNEA-PGCIL-I                  | 220     | Line         | 66.86           | 29-11-2020 10:30 | 0.66            | 01-11-2020 15:15 | 26.51          |                   |
| Begusarai 220 kv GSS  | Khagarua New Ckt-2              | 220     | Line         | 65.54           | 29-11-2020 10:30 | 0.01            | 20-11-2020 12:15 | 27.58          |                   |
| Begusarai 220 kv GSS  | Dalsingh Sarai                  | 132     | Line         | 47.62           | 01-11-2020 20:30 | 3.27            | 18-11-2020 18:15 | 28.39          |                   |
| Begusarai 220 kv GSS  | Samastipur New-1                | 220     | Line         | 45.50           | 01-11-2020 00:30 | 0.31            | 06-11-2020 11:00 | 13.32          |                   |
| Begusarai 220 kv GSS  | Samastipur New-2                | 220     | Line         | 45.44           | 01-11-2020 00:30 | 0.36            | 06-11-2020 11:00 | 13.50          |                   |
| Begusarai 220 kv GSS  | Manjhaul                        | 132     | Line         | 33.60           | 01-11-2020 20:45 | 3.98            | 18-11-2020 13:30 | 18.37          |                   |
| Begusarai 220 kv GSS  | TRF-2 (LV)                      | 33      | Transformer  | 18.17           | 01-11-2020 19:45 | 4.46            | 04-11-2020 13:45 | 11.46          |                   |
| Begusarai 220 kv GSS  | BTPS-1                          | 132     | Line         | 27.67           | 01-11-2020 18:15 | 0.96            | 09-11-2020 01:45 | 15.93          |                   |
| Begusarai 220 kv GSS  | TRF-3 (LV)                      | 33      | Transformer  | 17.73           | 01-11-2020 19:45 | 3.66            | 18-11-2020 12:30 | 10.59          |                   |
| Begusarai 220 kv GSS  | BTPS-2                          | 132     | Line         | 27.27           | 01-11-2020 18:15 | 0.93            | 09-11-2020 01:45 | 15.71          |                   |
| Begusarai 220 kv GSS  | TRF-1 (LV)                      | 33      | Transformer  | 16.89           | 01-11-2020 19:45 | 3.81            | 18-11-2020 12:15 | 10.64          |                   |
| Begusarai 220 kv GSS  | Balia                           | 132     | Line         | 23.50           | 01-11-2020 21:00 | 0.01            | 18-11-2020 13:30 | 13.00          |                   |
| Begusarai 220 kv GSS  | Teghra                          | 132     | Line         | 11.93           | 18-11-2020 18:00 | 0.60            | 02-11-2020 08:00 | 4.22           |                   |



|                           |   |     |             |        |                  |       |                  |       |                                      |
|---------------------------|---|-----|-------------|--------|------------------|-------|------------------|-------|--------------------------------------|
| Bodhgaya 220 kV GSS       | Railway 1                                   | 132 | Line        | 8.76   | 12-11-2020 12:00 | 0.12  | 02-11-2020 02:30 | 3.31  |                                      |
| Bodhgaya 220 kV GSS       | Railway 2                                   | 132 | Line        | 4.36   | 09-11-2020 12:15 | 0.08  | 09-11-2020 16:30 | 0.01  |                                      |
| Bodhgaya 220 kV GSS       | Bodhgaya(Khizasarai,BGCL)                   | 132 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Bodhgaya 220 kV GSS       | Khizasarai(BGCL)-2                          | 220 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Bodhgaya 220 kV GSS       | Khizasarai(BGCL)-1                          | 220 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Buxar 132 kV GSS          | Dumraon Line-2                              | 132 | Line        | 32.44  | 01-11-2020 18:15 | 1.10  | 12-11-2020 12:15 | 22.04 |                                      |
| Buxar 132 kV GSS          | TRF-3(LV)                                   | 33  | Transformer | 16.21  | 01-11-2020 18:15 | 0.66  | 27-11-2020 20:45 | 11.06 |                                      |
| Buxar 132 kV GSS          | TRF-2(LV)                                   | 33  | Transformer | 15.92  | 01-11-2020 18:15 | 0.64  | 27-11-2020 20:45 | 10.89 |                                      |
| Buxar 132 kV GSS          | TRF-1(LV)                                   | 33  | Transformer |        |                  |       |                  |       | Charge on no load                    |
| Buxar 132 kV GSS          | Dumraon Line-1                              | 132 | Line        | 19.73  | 12-11-2020 12:30 | 0.00  | 17-11-2020 10:30 | 0.94  |                                      |
| Chakia 132 kV GSS         | TRF-1(LV)                                   | 33  | Transformer | 17.63  | 28-11-2020 17:30 | 0.07  | 23-11-2020 17:00 | 6.97  |                                      |
| Chakia 132 kV GSS         | TRF-2(LV)                                   | 33  | Transformer | 11.33  | 01-11-2020 18:15 | 0.00  | 09-11-2020 03:45 | 6.71  |                                      |
| Chakia 132 kV GSS         | Motipur                                     | 132 | Line        | 21.85  | 01-11-2020 18:15 | 0.13  | 23-11-2020 17:00 | 13.80 |                                      |
| Chandauti 132 kV GSS      | Bodhgaya-2                                  | 132 | Line        | 47.57  | 08-11-2020 17:15 | 6.78  | 20-11-2020 04:00 | 18.86 |                                      |
| Chandauti 132 kV GSS      | Bodhgaya-4                                  | 132 | Line        | 47.09  | 08-11-2020 17:45 | 10.66 | 20-11-2020 04:00 | 29.74 |                                      |
| Chandauti 132 kV GSS      | Tekari                                      | 132 | Line        | 45.48  | 15-11-2020 18:00 | 0.12  | 14-11-2020 12:30 | 30.46 |                                      |
| Chandauti 132 kV GSS      | Rafiganj                                    | 132 | Line        | 44.20  | 25-11-2020 18:15 | 1.82  | 11-11-2020 12:45 | 24.54 |                                      |
| Chandauti 132 kV GSS      | Bodhgaya-3                                  | 132 | Line        | 42.45  | 03-11-2020 18:00 | 4.56  | 24-11-2020 14:15 | 29.47 |                                      |
| Chandauti 132 kV GSS      | Bodhgaya-1                                  | 132 | Line        | 29.42  | 08-11-2020 17:45 | 0.51  | 26-11-2020 14:15 | 18.60 |                                      |
| Chandauti 132 kV GSS      | TRF 3                                       | 33  | Transformer | 26.59  | 06-11-2020 12:45 | 3.48  | 06-11-2020 12:30 | 16.50 |                                      |
| Chandauti 132 kV GSS      | TRF 1                                       | 33  | Transformer | 23.19  | 01-11-2020 11:30 | 3.40  | 13-11-2020 04:30 | 10.68 |                                      |
| Chandauti 132 kV GSS      | TRF 2                                       | 33  | Transformer | 14.79  | 01-11-2020 09:15 | 2.00  | 06-11-2020 16:15 | 9.59  |                                      |
| Chandauti 132 kV GSS      | Railway (Main)                              | 25  | Line        | 13.76  | 04-11-2020 07:45 | 0.24  | 15-11-2020 15:15 | 5.90  |                                      |
| Chandauti 132 kV GSS      | Gaurichak(Shorting in Tehta-Jehanabad line) | 132 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Chandauti 132 kV GSS      | Sonenagar                                   | 132 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Chandauti 132 kV GSS      | Belaganj                                    | 132 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Chhapra 132 kV GSS        | Amnour(BGCL)-1                              | 132 | Line        | 59.52  | 29-11-2020 18:15 | 0.00  | 11-11-2020 12:45 | 27.59 |                                      |
| Chhapra 132 kV GSS        | Hajipur                                     | 132 | Line        | 47.84  | 28-11-2020 18:15 | 4.10  | 16-11-2020 14:15 | 23.70 |                                      |
| Chhapra 132 kV GSS        | Raghnathpur (T at Ekma)                     | 132 | Line        | 45.08  | 18-11-2020 19:00 | 0.01  | 08-11-2020 11:30 | 17.97 | Ekma has T connectivity in this line |
| Chhapra 132 kV GSS        | Sheetalpur                                  | 132 | Line        | 28.31  | 28-11-2020 18:45 | 0.03  | 24-11-2020 07:00 | 3.99  |                                      |
| Chhapra 132 kV GSS        | TRF-1(LV)                                   | 33  | Transformer | 15.70  | 14-11-2020 19:00 | 3.13  | 11-11-2020 12:30 | 10.75 |                                      |
| Chhapra 132 kV GSS        | TRF-3(LV)                                   | 33  | Transformer | 15.44  | 14-11-2020 19:00 | 3.07  | 11-11-2020 12:30 | 10.56 |                                      |
| Chhapra 132 kV GSS        | TRF-2(LV)                                   | 33  | Transformer |        |                  |       |                  |       | Charge on no load                    |
| Chhapra 132 kV GSS        | Chhapra TSS                                 | 132 | Line        | 11.98  | 11-11-2020 13:00 | 0.16  | 02-11-2020 01:00 | 3.68  |                                      |
| Chhapra 132 kV GSS        | Amnour(BGCL)-2                              | 132 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Dalsingh sarai 132 kV GSS | Begusarai                                   | 132 | Line        | 47.02  | 01-11-2020 21:45 | 3.26  | 18-11-2020 18:15 | 28.06 |                                      |
| Dalsingh sarai 132 kV GSS | Samastipur                                  | 132 | Line        | 43.94  | 18-11-2020 17:45 | 0.00  | 18-11-2020 09:30 | 2.01  |                                      |
| Dalsingh sarai 132 kV GSS | Rosera                                      | 132 | Line        | 22.66  | 01-11-2020 20:45 | 1.61  | 18-11-2020 18:15 | 12.39 |                                      |
| Dalsingh sarai 132 kV GSS | TRF-1(LV)                                   | 33  | Transformer | 9.70   | 15-11-2020 18:00 | 0.37  | 25-11-2020 11:30 | 6.03  |                                      |
| Dalsingh sarai 132 kV GSS | TRF-2(LV)                                   | 33  | Transformer | 9.54   | 15-11-2020 18:00 | 0.36  | 25-11-2020 11:30 | 5.93  |                                      |
| Dalsingh sarai 132 kV GSS | TRF-3(LV)                                   | 33  | Transformer |        |                  |       |                  |       | Charge on no load                    |
| Dalsingh sarai 132 kV GSS | Railway                                     | 132 | Line        | 14.36  | 27-11-2020 18:30 | 0.36  | 18-11-2020 13:15 | 3.95  |                                      |
| Dalsingh sarai 132 kV GSS | Kusheshwarsthan                             | 132 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Darbhangha 132 kV GSS     | Madhubani 1 (OldPandaul)                    | 132 | Line        | 43.48  | 04-11-2020 18:30 | 0.18  | 28-11-2020 16:45 | 19.79 |                                      |
| Darbhangha 132 kV GSS     | Samastipur                                  | 132 | Line        | 42.71  | 01-11-2020 17:45 | 0.00  | 07-11-2020 14:00 | 7.74  |                                      |
| Darbhangha 132 kV GSS     | Gangwara-3                                  | 132 | Line        | 41.98  | 01-11-2020 17:45 | 0.99  | 07-11-2020 06:30 | 5.33  |                                      |
| Darbhangha 132 kV GSS     | Madhubani 2                                 | 132 | Line        | 41.96  | 04-11-2020 18:30 | 0.19  | 28-11-2020 16:45 | 19.11 |                                      |
| Darbhangha 132 kV GSS     | TRF-2(LV)                                   | 33  | Transformer | 17.38  | 01-11-2020 20:30 | 4.12  | 03-11-2020 14:15 | 10.05 |                                      |
| Darbhangha 132 kV GSS     | TRF-1(LV)                                   | 33  | Transformer | 17.17  | 03-11-2020 12:45 | 4.13  | 29-11-2020 15:15 | 8.88  |                                      |
| Darbhangha 132 kV GSS     | Gangwara-2                                  | 132 | Line        | 16.77  | 15-11-2020 16:15 | 0.00  | 05-11-2020 01:45 | 8.06  |                                      |
| Darbhangha 132 kV GSS     | Gangwara-1                                  | 132 | Line        | 16.72  | 15-11-2020 16:15 | 0.00  | 06-11-2020 03:30 | 8.04  |                                      |
| Darbhangha 220 kV GSS     | Mushahri-2                                  | 220 | Line        | 119.92 | 05-11-2020 17:45 | 7.00  | 27-11-2020 18:15 | 68.78 |                                      |
| Darbhangha 220 kV GSS     | DMTCL-1                                     | 220 | Line        | 116.96 | 15-11-2020 18:15 | 13.36 | 28-11-2020 14:00 | 68.15 |                                      |
| Darbhangha 220 kV GSS     | DMTCL-2                                     | 220 | Line        | 116.85 | 15-11-2020 18:15 | 13.36 | 28-11-2020 14:00 | 68.10 |                                      |
| Darbhangha 220 kV GSS     | Mushahri-1                                  | 220 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Dehri On Sone 220 kV GSS  | PUSAULI PGCIL                               | 220 | Line        | 140.97 | 24-11-2020 18:15 | 0.26  | 23-11-2020 13:30 | 31.73 |                                      |
| Dehri On Sone 220 kV GSS  | Sonenagar(Old)-1                            | 132 | Line        | 88.57  | 29-11-2020 11:15 | 23.34 | 29-11-2020 10:45 | 2.30  |                                      |
| Dehri On Sone 220 kV GSS  | GAYA PGCIL-II                               | 220 | Line        | 77.07  | 28-11-2020 07:45 | 11.30 | 20-11-2020 03:30 | 47.81 |                                      |
| Dehri On Sone 220 kV GSS  | GAYA PGCIL-I                                | 220 | Line        | 76.86  | 28-11-2020 07:45 | 0.01  | 24-11-2020 19:15 | 47.68 |                                      |
| Dehri On Sone 220 kV GSS  | Kochas                                      | 132 | Line        | 67.03  | 28-11-2020 18:15 | 0.00  | 26-11-2020 20:45 | 22.25 |                                      |
| Dehri On Sone 220 kV GSS  | Bikramganj                                  | 132 | Line        | 65.60  | 11-11-2020 18:00 | 0.83  | 29-11-2020 10:30 | 39.55 |                                      |
| Dehri On Sone 220 kV GSS  | Kudra                                       | 132 | Line        | 34.12  | 01-11-2020 18:30 | 0.47  | 20-11-2020 02:45 | 15.58 |                                      |
| Dehri On Sone 220 kV GSS  | Kerpa                                       | 132 | Line        | 33.71  | 02-11-2020 07:30 | 3.57  | 10-11-2020 12:30 | 12.15 |                                      |
| Dehri On Sone 220 kV GSS  | Sasaram                                     | 132 | Line        | 26.48  | 28-11-2020 11:00 | 1.12  | 10-11-2020 12:30 | 5.86  |                                      |
| Dehri On Sone 220 kV GSS  | TRF-1(LV)                                   | 33  | Transformer | 25.41  | 16-11-2020 07:30 | 0.07  | 20-11-2020 04:00 | 15.82 |                                      |
| Dehri On Sone 220 kV GSS  | TRF-3(LV)                                   | 33  | Transformer | 22.56  | 30-11-2020 08:30 | 0.04  | 24-11-2020 19:30 | 15.31 |                                      |
| Dehri On Sone 220 kV GSS  | TRF-2(LV)                                   | 33  | Transformer |        |                  |       |                  |       | Charge on no load                    |
| Dehri On Sone 220 kV GSS  | Sonenagar(Old)-2                            | 132 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Dhaka 132 kV GSS          | Motihari-1                                  | 132 | Line        | 43.31  | 01-11-2020 19:45 | 0.00  | 05-11-2020 04:00 | 4.29  |                                      |
| Dhaka 132 kV GSS          | Sitamarhi                                   | 132 | Line        | 37.72  | 18-11-2020 18:45 | 1.02  | 05-11-2020 04:30 | 20.67 |                                      |
| Dhaka 132 kV GSS          | TRF-1(LV)                                   | 33  | Transformer | 20.18  | 01-11-2020 19:15 | 0.13  | 23-11-2020 16:45 | 8.41  |                                      |
| Dhaka 132 kV GSS          | TRF-2(LV)                                   | 33  | Transformer | 12.67  | 17-11-2020 18:30 | 0.00  | 05-11-2020 04:30 | 7.05  |                                      |
| Dhaka 132 kV GSS          | TRF-3(LV)                                   | 33  | Transformer | 12.15  | 17-11-2020 18:30 | 0.13  | 23-11-2020 16:45 | 6.79  |                                      |
| Dhaka 132 kV GSS          | Pakridayal                                  | 132 | Line        | 3.58   | 01-11-2020 18:45 | 0.01  | 05-11-2020 04:30 | 2.25  |                                      |
| Dhaka 132 kV GSS          | Sheohar                                     | 132 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Dhaka 132 kV GSS          | Motihari-2                                  | 132 | Line        |        |                  |       |                  |       | Charge on no load                    |
| Dhamdaha 132 kV GSS       | Purnea                                      | 132 | Line        | 38.35  | 01-11-2020 20:00 | 2.07  | 11-11-2020 11:30 | 19.03 |                                      |
| Dhamdaha 132 kV GSS       | TRF-2(LV)                                   | 33  | Transformer | 18.82  | 01-11-2020 20:00 | 0.15  | 27-11-2020 13:00 | 6.73  |                                      |
| Dhamdaha 132 kV GSS       | TRF-1(LV)                                   | 33  | Transformer | 13.07  | 09-11-2020 18:15 | 0.18  | 13-11-2020 13:00 | 2.77  |                                      |
| Dhamdaha 132 kV GSS       | Banmankhi                                   | 132 | Line        | 19.43  | 01-11-2020 20:00 | 0.21  | 19-11-2020 12:45 | 9.59  |                                      |
| Digha 132 kV GSS          | Khagaul-2                                   | 132 | Line        | 29.82  | 27-11-2020 10:30 | 11.17 | 17-11-2020 14:00 | 21.22 |                                      |
| Digha 132 kV GSS          | Khagaul-1                                   | 132 | Line        | 29.60  | 27-11-2020 10:30 | 11.12 | 17-11-2020 14:00 | 21.11 |                                      |
| Digha 132 kV GSS          | TRF 2                                       | 33  | Transformer | 29.54  | 27-11-2020 10:30 | 7.38  | 17-11-2020 14:00 | 16.42 |                                      |
| Digha 132 kV GSS          | TRF 1                                       | 33  | Transformer | 29.31  | 27-11-2020 10:30 | 7.34  | 17-11-2020 14:00 | 16.33 |                                      |
| Digha 132 kV GSS          | TRF 3                                       | 33  | Transformer | 19.35  | 01-11-2020 20:15 | 7.34  | 17-11-2020 14:00 | 9.38  |                                      |
| Dumraon 132 kV GSS        | ARA-PGCIL                                   | 132 | Line        | 56.08  | 14-11-2020 18:15 | 3.50  | 15-11-2020 11:30 | 35.41 |                                      |
| Dumraon 132 kV GSS        | Buxar-2                                     | 132 | Line        | 32.44  | 01-11-2020 18:15 | 1.10  | 12-11-2020 12:15 | 22.04 |                                      |
| Dumraon 132 kV GSS        | TRF-1(LV)                                   | 33  | Transformer | 26.15  | 14-11-2020 18:00 | 1.79  | 15-11-2020 11:30 | 16.72 |                                      |



|                       |                              |     |             |        |                  |       |                  |       |  |
|-----------------------|------------------------------|-----|-------------|--------|------------------|-------|------------------|-------|--|
| Hajipur 220 kv GSS    | Amnour (BGCL) ckt 1          | 220 | Line        | 68.00  | 29-11-2020 18:00 | 32.00 | 29-11-2020 17:00 |       | Manual data incorporated. meter not installed. |
| Hajipur 220 kv GSS    | Amnour (BGCL) ckt 1          | 220 | Line        | 133.00 | 20-11-2020 19:00 | 32.00 | 29-11-2020 17:00 |       | Manual data incorporated. meter not installed. |
| Hajipur 220 kv GSS    | Hajipur(Old)-2               | 132 | Line        | 55.19  | 28-11-2020 18:15 | 21.20 | 20-11-2020 16:45 | 36.15 |  |
| Hajipur 220 kv GSS    | Hajipur(Old)-1               | 132 | Line        | 54.59  | 28-11-2020 18:15 | 20.96 | 20-11-2020 16:15 | 35.73 |  |
| Hajipur 220 kv GSS    | Jandaha                      | 132 | Line        | 36.37  | 15-11-2020 18:15 | 0.13  | 23-11-2020 16:45 | 21.46 |  |
| Hajipur 220 kv GSS    | Samastipur                   | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Hajipur 220 kv GSS    | BTPS-1                       | 220 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Harnaut 132 kv GSS    | Baripahari                   | 132 | Line        | 44.79  | 09-11-2020 18:15 | 10.40 | 27-11-2020 04:30 | 26.79 |  |
| Harnaut 132 kv GSS    | TRF-2(LV)                    | 33  | Transformer | 34.67  | 09-11-2020 18:15 | 6.70  | 27-11-2020 04:30 | 19.68 |  |
| Harnaut 132 kv GSS    | TRF-1(LV)                    | 33  | Transformer | 15.24  | 17-11-2020 19:00 | 0.06  | 11-11-2020 06:15 | 6.99  |  |
| Harnaut 132 kv GSS    | Ultratech                    | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Hathidah 132 kv GSS   | Biharsharif                  | 132 | Line        | 25.59  | 06-11-2020 19:00 | 0.06  | 25-11-2020 01:30 | 4.36  |  |
| Hathidah 132 kv GSS   | Mokama(New) ckt 1            | 132 | Line        | 20.75  | 29-11-2020 11:00 | 7.50  | 11-11-2020 01:00 | 12.00 | Manual data incorporated. meter not installed. |
| Hathidah 132 kv GSS   | Mokama(New) ckt 2            | 132 | Line        | 20.75  | 29-11-2020 11:00 | 7.50  | 11-11-2020 01:00 | 12.00 | Manual data incorporated. meter not installed. |
| Hathidah 132 kv GSS   | Barh(T at Mokamma TSS)       | 132 | Line        | 18.44  | 29-11-2020 12:45 | 0.74  | 29-11-2020 10:45 | 0.13  |  |
| Hathidah 132 kv GSS   | TRF-2(LV)                    | 33  | Transformer | 9.99   | 14-11-2020 17:30 | 0.70  | 06-11-2020 12:00 | 6.17  |  |
| Hathidah 132 kv GSS   | TRF-1(LV)                    | 33  | Transformer | 8.67   | 14-11-2020 17:30 | 0.60  | 06-11-2020 12:00 | 5.32  |  |
| Hathidah 132 kv GSS   | TRF-3(LV)                    | 33  | Transformer | 8.47   | 14-11-2020 17:30 | 0.60  | 06-11-2020 12:00 | 5.23  |  |
| Hathidah 132 kv GSS   | Sheikhpura                   | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Hathidah 132 kv GSS   | Lakhisarai                   | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Hathua 132 kv GSS     | Gopalganj                    | 132 | Line        | 64.50  | 29-11-2020 12:15 | 0.11  | 16-11-2020 14:15 | 25.34 |  |
| Hathua 132 kv GSS     | Siwan                        | 132 | Line        | 51.85  | 29-11-2020 12:15 | 0.00  | 17-11-2020 18:30 | 11.00 |  |
| Hathua 132 kv GSS     | TRF-3(LV)                    | 33  | Transformer | 25.77  | 16-11-2020 18:00 | 2.38  | 16-11-2020 12:45 | 15.84 |  |
| Hathua 132 kv GSS     | TRF-1(LV)                    | 33  | Transformer | 9.28   | 29-11-2020 13:15 | 3.53  | 29-11-2020 14:30 | 0.02  |  |
| Hathua 132 kv GSS     | TRF-2(LV)                    | 33  | Transformer | 6.40   | 29-11-2020 13:15 | 2.76  | 29-11-2020 14:30 | 0.01  |  |
| Hulasganj 132 kv GSS  | Biharsharif                  | 132 | Line        | 27.85  | 23-11-2020 18:00 | 0.06  | 06-11-2020 11:45 | 18.19 |  |
| Hulasganj 132 kv GSS  | TRF 2                        | 33  | Transformer | 13.09  | 29-11-2020 18:00 | 0.00  | 06-11-2020 11:45 | 6.24  |  |
| Hulasganj 132 kv GSS  | TRF 1                        | 33  | Transformer | 12.91  | 29-11-2020 18:00 | 0.00  | 13-11-2020 13:00 | 6.15  |  |
| Hulasganj 132 kv GSS  | TRF 3                        | 33  | Transformer | 13.09  | 29-11-2020 18:00 | 0.00  | 06-11-2020 11:45 | 6.24  | Manual data incorporated. meter not installed. |
| Hulasganj 132 kv GSS  | Ekangarsarai                 | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Hulasganj 132 kv GSS  | Khizarsarai BGCL             | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Imamganj 132 kv GSS   | Bodhgaya                     | 132 | Line        | 24.58  | 12-11-2020 16:30 | 0.28  | 12-11-2020 14:00 | 14.65 |  |
| Imamganj 132 kv GSS   | TRF 2                        | 33  | Transformer | 13.55  | 02-11-2020 16:30 | 0.30  | 13-11-2020 04:00 | 7.12  |  |
| Imamganj 132 kv GSS   | TRF 1                        | 33  | Transformer | 10.83  | 15-11-2020 18:00 | 0.18  | 02-11-2020 16:15 | 7.25  |  |
| Imamganj 132 kv GSS   | Sherghati                    | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jagdishpur 132 kv GSS | ARA-PGCIL-I                  | 132 | Line        | 21.02  | 24-11-2020 18:00 | 3.10  | 06-11-2020 10:15 | 12.07 |  |
| Jagdishpur 132 kv GSS | ARA-PGCIL-II                 | 132 | Line        | 20.68  | 24-11-2020 18:00 | 3.06  | 06-11-2020 10:15 | 11.86 |  |
| Jagdishpur 132 kv GSS | TRF-1(LV)                    | 33  | Transformer | 20.99  | 24-11-2020 18:00 | 3.08  | 06-11-2020 10:15 | 12.18 |  |
| Jagdishpur 132 kv GSS | TRF-2(LV)                    | 33  | Transformer | 20.57  | 24-11-2020 18:15 | 3.01  | 06-11-2020 10:15 | 11.93 |  |
| Jagdishpur 132 kv GSS | Ara Bspctcl Jagdishpur CKT-1 | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jagdishpur 132 kv GSS | Ara Bspctcl Jagdishpur CKT-2 | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jainagar 132 kv GSS   | Phulparas                    | 132 | Line        | 25.37  | 01-11-2020 19:15 | 0.00  | 12-11-2020 13:15 | 12.60 |  |
| Jainagar 132 kv GSS   | TRF-3(LV)                    | 33  | Transformer | 11.06  | 01-11-2020 00:00 | 1.20  | 13-11-2020 06:45 | 4.49  |  |
| Jainagar 132 kv GSS   | TRF-1(LV)                    | 33  | Transformer | 10.80  | 01-11-2020 00:00 | 1.16  | 13-11-2020 06:45 | 4.38  |  |
| Jainagar 132 kv GSS   | TRF-1(LV)                    | 33  | Transformer | 8.27   | 01-11-2020 19:15 | 0.84  | 01-11-2020 13:15 | 4.21  |  |
| Jainagar 132 kv GSS   | Jhanjharpur                  | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jainagar 132 kv GSS   | Benipatti                    | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jainagar 132 kv GSS   | Madhubani                    | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jakkanpur 132 kv GSS  | Gaurichak-2                  | 132 | Line        | 37.72  | 02-11-2020 18:00 | 11.18 | 29-11-2020 03:30 | 24.71 |  |
| Jakkanpur 132 kv GSS  | Gaurichak-1                  | 132 | Line        | 37.56  | 02-11-2020 18:00 | 0.01  | 29-11-2020 03:30 | 24.59 |  |
| Jakkanpur 132 kv GSS  | Karbigahiya                  | 132 | Line        | 28.71  | 04-11-2020 12:30 | 0.20  | 29-11-2020 03:30 | 9.19  |  |
| Jakkanpur 132 kv GSS  | TRF-4(LV)                    | 33  | Transformer | 19.24  | 17-11-2020 14:30 | 2.06  | 29-11-2020 03:30 | 6.06  |  |
| Jakkanpur 132 kv GSS  | TRF-2(LV)                    | 33  | Transformer | 16.12  | 07-11-2020 17:45 | 2.80  | 29-11-2020 03:30 | 9.12  |  |
| Jakkanpur 132 kv GSS  | TRF-1(LV)                    | 33  | Transformer | 15.90  | 07-11-2020 17:45 | 2.76  | 29-11-2020 03:30 | 8.97  |  |
| Jakkanpur 132 kv GSS  | TRF-5(LV)                    | 33  | Transformer | 13.78  | 02-11-2020 13:00 | 0.30  | 16-11-2020 13:00 | 6.86  |  |
| Jakkanpur 132 kv GSS  | TRF-3(LV)                    | 33  | Transformer | 12.90  | 17-11-2020 18:15 | 0.10  | 28-11-2020 07:30 | 4.83  |  |
| Jamalpur 132 kv GSS   | Lakhisarai                   | 132 | Line        | 40.44  | 01-11-2020 18:15 | 6.77  | 04-11-2020 11:15 | 26.09 |  |
| Jamalpur 132 kv GSS   | Tarapur                      | 132 | Line        | 20.32  | 04-11-2020 16:00 | 0.00  | 24-11-2020 14:00 | 2.29  |  |
| Jamalpur 132 kv GSS   | TRF-2(LV)                    | 33  | Transformer | 22.38  | 01-11-2020 18:30 | 6.02  | 06-11-2020 15:00 | 14.37 |  |
| Jamalpur 132 kv GSS   | TRF-1(LV)                    | 33  | Transformer | 17.64  | 02-11-2020 18:00 | 2.94  | 06-11-2020 15:00 | 11.39 |  |
| Jamalpur 132 kv GSS   | Haveli_KGP(BGCL)-1           | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jamalpur 132 kv GSS   | Haveli_KGP(BGCL)-2           | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jamui 132 kv GSS      | LAKHISARAI-PGCIL-II          | 132 | Line        | 53.42  | 28-11-2020 18:00 | 9.10  | 20-11-2020 07:00 | 29.46 |  |
| Jamui 132 kv GSS      | LAKHISARAI-PGCIL-I           | 132 | Line        | 53.14  | 28-11-2020 18:00 | 9.03  | 20-11-2020 07:00 | 29.29 |  |
| Jamui 132 kv GSS      | Sheikhpura CKT-1             | 132 | Line        | 30.94  | 22-11-2020 18:00 | 0.35  | 06-11-2020 12:00 | 10.59 |  |
| Jamui 132 kv GSS      | Jamui New-1                  | 132 | Line        | 25.56  | 28-11-2020 17:45 | 0.00  | 25-11-2020 02:15 | 2.09  |  |
| Jamui 132 kv GSS      | Sheikhpura CKT-2             | 132 | Line        | 16.60  | 25-11-2020 18:00 | 0.32  | 06-11-2020 12:00 | 10.51 |  |
| Jamui 132 kv GSS      | TRF-3(LV)                    | 33  | Transformer | 24.96  | 17-11-2020 18:15 | 2.08  | 21-11-2020 06:30 | 17.57 |  |
| Jamui 132 kv GSS      | TRF-1(LV)                    | 33  | Transformer | 24.72  | 14-11-2020 18:00 | 2.07  | 21-11-2020 06:30 | 17.43 |  |
| Jamui 132 kv GSS      | TRF-2(LV)                    | 33  | Transformer |        |                  |       |                  |       | Charge on no load                              |
| Jamui 132 kv GSS      | Railway                      | 132 | Line        | 10.48  | 07-11-2020 12:15 | 0.04  | 24-11-2020 11:45 | 3.86  |  |
| Jamui 132 kv GSS      | Jamui New-2                  | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jamui 132 kv GSS      | Lakhisarai                   | 132 | Line        |        |                  |       |                  |       | Charge on no load                              |
| Jandaha 132 kv GSS    | Hajipur New                  | 132 | Line        | 36.09  | 15-11-2020 18:15 | 0.12  | 23-11-2020 16:45 | 21.66 |  |
| Jandaha 132 kv GSS    | TRF-1(LV)                    | 33  | Transformer | 17.86  | 15-11-2020 18:15 | 0.51  | 17-11-2020 16:30 | 10.39 |  |
| Jandaha 132 kv GSS    | TRF-3(LV)                    | 33  | Transformer | 17.72  | 15-11-2020 18:15 | 0.95  | 13-11-2020 13:00 | 10.33 |  |
| Jandaha 132 kv GSS    | TRF-2(LV)                    | 33  | Transformer |        |                  |       |                  |       | Charge on no load                              |
| Jandaha 132 kv GSS    | Samastipur                   | 132 | Line        | 8.26   | 14-11-2020 20:15 | 0.00  | 30-11-2020 05:00 | 4.53  |  |
| Jandaha 132 kv GSS    | Mahanar                      | 132 | Line        | 6.41   | 27-11-2020 18:15 | 0.98  | 26-11-2020 09:30 | 0.67  |  |
| Jehanabad 132 kv GSS  | Khizarsarai( BGCL) ckt 1     | 132 | Line        | 83.00  | 08-09-2020 00:00 | 20.50 | 21-09-2020 08:00 | 50.00 | Meter not installed.manual data incorporated   |

|                        |                          |     |             |        |                  |       |                  |       |  |
|------------------------|--------------------------|-----|-------------|--------|------------------|-------|------------------|-------|--|
| Jehanabad 132 kv GSS   | Khizarsarai( BGCL) ckt 2 | 132 | Line        | 83.00  | 08-09-2020 00:00 | 20.50 | 21-09-2020 08:00 | 50.00 | Meter not installed.manual data incorporated   |
| Jehanabad 132 kv GSS   | Masaurhi                 | 132 | Line        | 38.09  | 28-11-2020 18:00 | 1.75  | 28-11-2020 11:00 | 2.22  |  |
| Jehanabad 132 kv GSS   | Tehta                    | 132 | Line        | 35.18  | 23-11-2020 18:15 | 0.31  | 13-11-2020 13:00 | 24.25 |  |
| Jehanabad 132 kv GSS   | Ataula-2                 | 132 | Line        | 23.06  | 15-11-2020 18:00 | 0.01  | 05-11-2020 13:00 | 14.25 |  |
| Jehanabad 132 kv GSS   | Ataula-1                 | 132 | Line        | 22.61  | 04-11-2020 11:45 | 0.01  | 05-11-2020 15:30 | 12.68 |  |
| Jehanabad 132 kv GSS   | TRF 1                    | 33  | Transformer | 25.33  | 28-11-2020 11:15 | 0.84  | 22-11-2020 10:00 | 12.83 |  |
| Jehanabad 132 kv GSS   | TRF 3                    | 33  | Transformer | 20.04  | 09-11-2020 12:00 | 0.61  | 28-11-2020 16:15 | 12.15 |  |
| Jehanabad 132 kv GSS   | TRF 2                    | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Jehanabad 132 kv GSS   | Railway                  | 132 | Line        | 6.03   | 01-11-2020 19:45 | 0.03  | 10-11-2020 16:00 | 2.76  |  |
| Jhanjharpur 132 kv GSS | TRF-1(LV)                | 33  | Transformer | 5.52   | 01-11-2020 20:15 | 0.00  | 12-11-2020 13:15 | 2.55  |  |
| Jhanjharpur 132 kv GSS | TRF-2(LV)                | 33  | Transformer | 5.48   | 01-11-2020 20:15 | 0.46  | 30-11-2020 14:45 | 2.51  |  |
| Jhanjharpur 132 kv GSS | Phulparas                | 132 | Line        | 11.08  | 01-11-2020 20:15 | 0.96  | 30-11-2020 14:45 | 5.10  |  |
| Jhanjharpur 132 kv GSS | Jainagar                 | 132 | Line        |        |                  |       |                  |       | Charge on no load  |
| Kahalgaon 132 kv GSS   | Kahalgaon (NTPC)         | 132 | Line        | 82.21  | 01-11-2020 19:30 | 15.69 | 06-11-2020 14:15 | 56.26 |  |
| Kahalgaon 132 kv GSS   | Lalmatia                 | 132 | Line        | 38.18  | 26-11-2020 09:00 | 0.01  | 06-11-2020 16:00 | 23.34 |  |
| Kahalgaon 132 kv GSS   | TRF-4(LV)                | 33  | Transformer | 33.61  | 10-11-2020 08:15 | 0.73  | 16-11-2020 09:30 | 15.52 |  |
| Kahalgaon 132 kv GSS   | TRF-3(LV)                | 33  | Transformer | 29.31  | 18-11-2020 13:15 | 0.40  | 25-11-2020 16:30 | 14.79 |  |
| Kahalgaon 132 kv GSS   | Trf-1(LV)                | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Kahalgaon 132 kv GSS   | TRF-2(LV)                | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Kahalgaon 132 kv GSS   | Goradih BGCL-2           | 132 | Line        | 1.56   | 29-11-2020 18:00 | 0.05  | 20-11-2020 17:00 | 1.42  |  |
| Kahalgaon 132 kv GSS   | Goradih BGCL-1           | 132 | Line        | 1.44   | 29-11-2020 18:00 | 0.01  | 21-11-2020 06:30 | 1.31  |  |
| Kahalgaon 132 kv GSS   | Sabour                   | 132 | Line        |        |                  |       |                  |       | Charge on no load  |
| Karbigahiya 132 kv GSS | Gaurichak                | 132 | Line        | 35.21  | 30-11-2020 18:00 | 6.30  | 11-11-2020 02:15 | 16.99 |  |
| Karbigahiya 132 kv GSS | Jakkanpur                | 132 | Line        | 28.71  | 04-11-2020 12:30 | 0.20  | 29-11-2020 03:30 | 9.19  |  |
| Karbigahiya 132 kv GSS | TRF-1 (LV)               | 33  | Transformer | 34.53  | 27-11-2020 09:00 | 0.25  | 25-11-2020 17:00 | 2.04  |  |
| Karbigahiya 132 kv GSS | TRF-3 (LV)               | 33  | Transformer | 33.75  | 14-11-2020 17:30 | 0.18  | 29-11-2020 03:30 | 8.85  |  |
| Karbigahiya 132 kv GSS | TRF-4 (LV)               | 33  | Transformer | 33.00  | 23-11-2020 11:00 | 0.80  | 13-11-2020 21:30 | 13.86 |  |
| Karbigahiya 132 kv GSS | TRF-2 (LV)               | 33  | Transformer | 8.93   | 11-11-2020 02:15 | 1.38  | 20-11-2020 17:15 | 0.01  |  |
| Karmnasha 132 kv GSS   | Kudra TSS                | 132 | Line        | 29.69  | 27-11-2020 08:45 | 0.06  | 07-11-2020 21:30 | 18.02 |  |
| Karmnasha 132 kv GSS   | Mohania                  | 132 | Line        | 25.45  | 21-11-2020 15:45 | 0.03  | 12-11-2020 14:15 | 1.68  |  |
| Karmnasha 132 kv GSS   | TRF-3(LV)                | 33  | Transformer | 22.48  | 08-11-2020 07:45 | 0.41  | 21-11-2020 13:15 | 7.46  |  |
| Karmnasha 132 kv GSS   | TRF-2(LV)                | 33  | Transformer | 11.68  | 03-11-2020 07:15 | 0.45  | 21-11-2020 13:15 | 7.14  |  |
| Karmnasha 132 kv GSS   | TRF-1(LV)                | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Karmnasha 132 kv GSS   | Railway(Check)           | 25  | Line        | 11.28  | 23-11-2020 03:45 | 0.04  | 17-11-2020 23:45 | 3.14  |  |
| Karmnasha 132 kv GSS   | Chandauli                | 132 | Line        |        |                  |       |                  |       | Charge on no load  |
| Karmnasha 132 kv GSS   | Sahupuri                 | 132 | Line        |        |                  |       |                  |       | Charge on no load  |
| Kataiya 132 kv GSS     | Duhabi                   | 132 | Line        | 114.92 | 29-11-2020 17:45 | 0.01  | 23-11-2020 10:00 | 27.92 |  |
| Kataiya 132 kv GSS     | Kushaha                  | 132 | Line        | 73.61  | 27-11-2020 17:45 | 0.00  | 15-11-2020 10:15 | 16.36 |  |
| Kataiya 132 kv GSS     | Forbisganj CKT-2         | 132 | Line        | 57.34  | 27-11-2020 17:30 | 0.00  | 20-11-2020 07:15 | 13.30 |  |
| Kataiya 132 kv GSS     | Forbisganj CKT-3         | 132 | Line        | 56.77  | 27-11-2020 17:30 | 0.00  | 19-11-2020 07:15 | 12.99 |  |
| Kataiya 132 kv GSS     | Forbisganj CKT-1         | 132 | Line        | 55.91  | 24-11-2020 07:30 | 0.02  | 28-11-2020 17:30 | 10.68 |  |
| Kataiya 132 kv GSS     | Supaul CKT-2             | 132 | Line        | 36.93  | 27-11-2020 17:45 | 0.00  | 22-11-2020 15:30 | 8.16  |  |
| Kataiya 132 kv GSS     | Supaul CKT-1             | 132 | Line        | 36.78  | 27-11-2020 17:45 | 0.00  | 15-11-2020 14:30 | 8.11  |  |
| Kataiya 132 kv GSS     | TRF-1(LV)                | 33  | Transformer | 17.98  | 01-11-2020 19:00 | 3.79  | 08-11-2020 13:00 | 9.38  |  |
| Kataiya 132 kv GSS     | TRF-2(LV)                | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Kataiya 132 kv GSS     | TRF-3(LV)                | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Kataiya 132 kv GSS     | TRF-4(LV)                | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Katihar 132 kv GSS     | Purnea (T at Manihari)   | 132 | Line        | 62.38  | 01-11-2020 21:30 | 15.84 | 20-11-2020 16:30 | 30.62 |  |
| Katihar 132 kv GSS     | TRF-4(LV)                | 33  | Transformer | 22.35  | 01-11-2020 20:00 | 5.73  | 20-11-2020 16:30 | 12.00 |  |
| Katihar 132 kv GSS     | TRF-3(LV)                | 33  | Transformer | 8.79   | 01-11-2020 20:00 | 2.26  | 20-11-2020 16:30 | 4.72  |  |
| Katihar 132 kv GSS     | TRF-2(LV)                | 33  | Transformer | 8.58   | 01-11-2020 20:00 | 2.19  | 20-11-2020 16:30 | 4.56  |  |
| Katihar 132 kv GSS     | TRF-1 (20MVA) LV         | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Katra 132 kv GSS       | Fatuha                   | 132 | Line        | 101.86 | 11-11-2020 17:45 | 39.80 | 23-11-2020 02:30 | 72.95 |  |
| Katra 132 kv GSS       | TRF 1                    | 33  | Transformer | 33.28  | 11-11-2020 17:45 | 13.01 | 03-11-2020 16:45 | 24.03 |  |
| Katra 132 kv GSS       | TRF 2                    | 33  | Transformer | 33.20  | 11-11-2020 17:45 | 12.90 | 03-11-2020 16:45 | 23.93 |  |
| Katra 132 kv GSS       | TRF 4                    | 33  | Transformer | 32.48  | 11-11-2020 17:45 | 12.60 | 03-11-2020 16:45 | 23.44 |  |
| Katra 132 kv GSS       | TRF 3                    | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Katra 132 kv GSS       | Gaighat                  | 132 | Line        |        |                  |       |                  |       | Charge on no load  |
| Khagaria 132 kv GSS    | BTPS                     | 132 | Line        | 38.00  | 01-11-2020 21:45 | 3.82  | 21-11-2020 06:45 | 20.26 |  |
| Khagaria 132 kv GSS    | TRF-1(LV)                | 33  | Transformer | 31.38  | 01-11-2020 21:45 | 1.20  | 21-11-2020 06:45 | 16.24 |  |
| Khagaria 132 kv GSS    | TRF-2(LV)                | 33  | Transformer | 6.60   | 17-11-2020 17:45 | 0.50  | 13-11-2020 07:30 | 3.84  |  |
| Khagaria 132 kv GSS    | TRF-3(LV)                | 33  | Transformer | 0.02   | 21-11-2020 06:30 | 0.01  | 01-11-2020 18:15 | 0.02  |  |
| Khagaria 132 kv GSS    | Khagaria New             | 132 | Line        |        |                  |       |                  |       | Charge on no load  |
| Khagaul 220 kv GSS     | PATNA-PGCIL-III          | 220 | Line        | 82.00  | 29-11-2020 10:00 | 28.50 | 11-11-2020 14:00 | 38.03 | Meter not installed.maintained by BGCL.This is estimated data as load sharing on each line is almost same. |
| Khagaul 220 kv GSS     | ARA-PGCIL-II             | 220 | Line        | 79.80  | 29-11-2020 09:45 | 1.50  | 20-11-2020 03:45 | 38.03 |  |
| Khagaul 220 kv GSS     | ARA-PGCIL-I              | 220 | Line        | 78.39  | 29-11-2020 09:45 | 1.45  | 20-11-2020 03:45 | 37.32 |  |
| Khagaul 220 kv GSS     | PATNA-PGCIL-II           | 220 | Line        | 75.37  | 29-11-2020 10:00 | 28.32 | 11-11-2020 14:00 | 69.78 | Meter not installed.maintained by BGCL.This is estimated data as load sharing on each line is almost same. |
| Khagaul 220 kv GSS     | PATNA-PGCIL-I            | 220 | Line        | 69.58  | 29-11-2020 09:45 | 22.37 | 20-11-2020 03:45 | 44.09 |  |
| Khagaul 220 kv GSS     | Gaurichak                | 220 | Line        | 66.02  | 29-11-2020 09:45 | 0.18  | 17-11-2020 13:15 | 41.42 |  |
| Khagaul 220 kv GSS     | Digha-2                  | 132 | Line        | 29.67  | 27-11-2020 10:30 | 11.10 | 17-11-2020 14:00 | 20.97 |  |
| Khagaul 220 kv GSS     | Digha-1                  | 132 | Line        | 29.44  | 27-11-2020 10:30 | 11.05 | 17-11-2020 14:00 | 20.84 |  |
| Khagaul 220 kv GSS     | TRF-5(LV)                | 33  | Transformer | 38.93  | 22-11-2020 18:00 | 2.06  | 25-11-2020 14:15 | 13.33 |  |
| Khagaul 220 kv GSS     | TRF-1(LV)                | 33  | Transformer | 37.68  | 27-11-2020 18:30 | 9.16  | 11-11-2020 13:15 | 15.78 |  |
| Khagaul 220 kv GSS     | TRF-4(LV)                | 33  | Transformer | 21.92  | 25-11-2020 09:15 | 5.52  | 04-11-2020 15:30 | 12.59 |  |
| Khagaul 220 kv GSS     | TRF-3(LV)                | 33  | Transformer | 21.75  | 25-11-2020 09:15 | 5.48  | 04-11-2020 15:30 | 12.50 |  |
| Khagaul 220 kv GSS     | TRF-2(LV)                | 33  | Transformer | 17.19  | 14-11-2020 18:15 | 5.48  | 04-11-2020 15:30 | 8.08  |  |
| Khagaul 220 kv GSS     | Railway                  | 132 | Line        | 8.96   | 18-11-2020 12:30 | 0.32  | 03-11-2020 01:00 | 3.80  |  |
| Khagaul 220 kv GSS     | Bihta-1                  | 132 | Line        |        |                  |       |                  |       | Charge on no load  |



|                        |                             |     |             |        |                  |       |                  |       |  |
|------------------------|-----------------------------|-----|-------------|--------|------------------|-------|------------------|-------|--|
| Mahnar 132 kv GSS      | TRF-2(LV)                   | 33  | Transformer | 4.03   | 14-11-2020 20:15 | 0.03  | 11-11-2020 17:15 | 2.27  |  |
| Mahnar 132 kv GSS      | TRF-1(LV)                   | 33  | Transformer | 4.03   | 14-11-2020 20:00 | 0.01  | 24-11-2020 09:15 | 2.27  |  |
| Mahnar 132 kv GSS      | Jandaha                     | 132 | Line        | 8.14   | 14-11-2020 20:15 | 0.00  | 18-11-2020 05:45 | 4.59  |  |
| Manihari 132 kv GSS    | T at Purnea-Katihar Tr line | 132 | Line        | 15.65  | 01-11-2020 20:15 | 1.56  | 04-11-2020 14:15 | 6.25  |  |
| Manihari 132 kv GSS    | TRF-1(LV)                   | 33  | Transformer | 7.78   | 01-11-2020 20:15 | 0.76  | 04-11-2020 14:15 | 3.10  |  |
| Manihari 132 kv GSS    | TRF-2(LV)                   | 33  | Transformer | 7.72   | 01-11-2020 20:15 | 0.76  | 04-11-2020 14:15 | 3.09  |  |
| Manjhaul 132 kv GSS    | Begusarai                   | 132 | Line        | 33.60  | 01-11-2020 20:45 | 3.98  | 18-11-2020 13:30 | 18.37 |  |
| Manjhaul 132 kv GSS    | TRF-2(LV)                   | 33  | Transformer | 22.56  | 01-11-2020 20:45 | 0.08  | 25-11-2020 11:30 | 12.86 |  |
| Manjhaul 132 kv GSS    | TRF-1(LV)                   | 33  | Transformer |        |                  |       |                  |       | Charge on no load  |
| Manjhaul 132 kv GSS    | Bakhri                      | 132 | Line        | 10.68  | 01-11-2020 21:30 | 0.07  | 20-11-2020 16:45 | 5.64  |  |
| Masaurhi 132 kv GSS    | Jehanabad                   | 132 | Line        | 37.89  | 28-11-2020 18:00 | 1.81  | 28-11-2020 11:00 | 2.25  |  |
| Masaurhi 132 kv GSS    | Gaurichak                   | 132 | Line        | 37.86  | 15-11-2020 18:00 | 2.38  | 06-11-2020 11:45 | 23.64 |  |
| Masaurhi 132 kv GSS    | TRF 3                       | 33  | Transformer | 25.17  | 27-11-2020 07:45 | 0.71  | 28-11-2020 11:00 | 10.19 |  |
| Masaurhi 132 kv GSS    | TRF 2                       | 33  | Transformer | 15.39  | 19-11-2020 15:45 | 0.70  | 28-11-2020 11:00 | 9.80  |  |
| Masaurhi 132 kv GSS    | TRF 1(LV)                   | 33  | Transformer | 8.77   | 09-11-2020 07:45 | 0.37  | 28-11-2020 11:00 | 5.32  |  |
| Mashrakh 132 kv GSS    | Gopalganj                   | 132 | Line        | 61.04  | 29-11-2020 17:15 | 0.17  | 16-11-2020 14:00 | 32.72 |  |
| Mashrakh 132 kv GSS    | Siwan                       | 132 | Line        | 29.75  | 29-11-2020 17:15 | 0.00  | 29-11-2020 18:30 | 0.43  |  |
| Mashrakh 132 kv GSS    | Maharajgnaj                 | 132 | Line        | 22.31  | 01-11-2020 19:45 | 0.00  | 30-11-2020 11:00 | 13.57 |  |
| Mashrakh 132 kv GSS    | TRF-1(LV)                   | 33  | Transformer | 15.78  | 13-11-2020 07:45 | 0.03  | 20-11-2020 16:45 | 8.97  |  |
| Mashrakh 132 kv GSS    | TRF-2(LV)                   | 33  | Transformer | 14.48  | 15-11-2020 18:15 | 0.00  | 13-11-2020 08:00 | 9.35  |  |
| Mashrakh 132 kv GSS    | DLF Marhaura-2              | 132 | Line        | 1.03   | 09-11-2020 19:00 | 0.00  | 16-11-2020 14:15 | 0.91  |  |
| Mashrakh 132 kv GSS    | DLF Marhaura-1              | 132 | Line        |        |                  |       |                  |       | Antitheft charged.   |
| Mithapur 132 kv GSS    | Gaurichak                   | 132 | Line        | 58.66  | 30-11-2020 19:15 | 17.07 | 29-11-2020 04:15 | 33.18 |  |
| Mithapur 132 kv GSS    | TRF-1(LV)                   | 33  | Transformer | 16.38  | 01-11-2020 18:30 | 3.83  | 29-11-2020 04:15 | 10.11 |  |
| Mithapur 132 kv GSS    | TRF-2(LV)                   | 33  | Transformer | 16.36  | 01-11-2020 18:30 | 3.82  | 29-11-2020 04:15 | 10.10 |  |
| Mohania 132 kv GSS     | Ramgarh                     | 132 | Line        | 31.10  | 21-11-2020 15:45 | 0.00  | 10-11-2020 08:15 | 9.92  |  |
| Mohania 132 kv GSS     | Karamnasa                   | 132 | Line        | 25.45  | 21-11-2020 15:45 | 0.03  | 12-11-2020 14:15 | 1.68  |  |
| Mohania 132 kv GSS     | PUSAULI-PGCIL-1             | 132 | Line        | 23.52  | 01-11-2020 18:15 | 5.79  | 28-11-2020 14:45 | 7.10  |  |
| Mohania 132 kv GSS     | TRF-1(LV)                   | 33  | Transformer | 17.16  | 01-11-2020 18:15 | 0.66  | 20-11-2020 02:15 | 12.12 |  |
| Mohania 132 kv GSS     | TRF-2(LV)                   | 33  | Transformer | 7.79   | 18-11-2020 18:00 | 0.00  | 24-11-2020 17:15 | 4.14  |  |
| Motihari 132 kv GSS    | Motipur                     | 132 | Line        | 44.23  | 01-11-2020 19:45 | 0.01  | 08-11-2020 17:45 | 8.01  |  |
| Motihari 132 kv GSS    | Dhaka-1                     | 132 | Line        | 43.31  | 01-11-2020 19:45 | 0.00  | 05-11-2020 04:00 | 4.29  |  |
| Motihari 132 kv GSS    | Bettiah                     | 132 | Line        | 39.58  | 30-11-2020 18:00 | 0.32  | 29-11-2020 17:30 | 0.59  |  |
| Motihari 132 kv GSS    | DMTCL-2                     | 132 | Line        | 27.25  | 01-11-2020 20:30 | 0.22  | 17-11-2020 05:30 | 16.92 |  |
| Motihari 132 kv GSS    | DMTCL-1                     | 132 | Line        | 26.92  | 01-11-2020 20:30 | 0.23  | 17-11-2020 05:30 | 16.71 |  |
| Motihari 132 kv GSS    | TRF-1(LV)                   | 33  | Transformer | 17.79  | 01-11-2020 20:30 | 0.01  | 11-11-2020 14:15 | 10.80 |  |
| Motihari 132 kv GSS    | TRF-2(LV)                   | 33  | Transformer | 17.58  | 01-11-2020 20:30 | 0.03  | 17-11-2020 05:30 | 10.53 |  |
| Motihari 132 kv GSS    | TRF-3(LV)                   | 33  | Transformer | 17.56  | 01-11-2020 20:30 | 0.11  | 29-11-2020 17:30 | 10.64 |  |
| Motihari 132 kv GSS    | Sugauli Sugar Mill          | 132 | Line        | 1.26   | 07-11-2020 16:00 | 0.00  | 30-11-2020 07:45 | 1.13  |  |
| Motihari 132 kv GSS    | Jivdhara_TSS_Main           | 132 | Line        | 0.80   | 08-11-2020 11:45 | 0.01  | 29-11-2020 10:00 | 0.24  |  |
| Motihari 132 kv GSS    | Dhaka-2                     | 132 | Line        |        |                  |       |                  |       | Charge on no load  |
| Motipur 220 kv GSS     | MTPS-2                      | 220 | Line        | 92.36  | 07-11-2020 17:45 | 25.62 | 29-11-2020 10:45 | 48.34 |  |
| Motipur 220 kv GSS     | MTPS-1                      | 220 | Line        | 81.80  | 28-11-2020 18:15 | 0.46  | 07-11-2020 01:15 | 45.02 |  |
| Motipur 220 kv GSS     | Mushahari CKT-2             | 220 | Line        | 75.20  | 28-11-2020 17:45 | 2.24  | 05-11-2020 15:30 | 25.53 |  |
| Motipur 220 kv GSS     | Mushahari CKT-1             | 220 | Line        | 71.24  | 28-11-2020 17:45 | 1.20  | 05-11-2020 08:15 | 24.25 |  |
| Motipur 220 kv GSS     | DMTCL-2                     | 220 | Line        | 52.93  | 05-11-2020 17:45 | 0.22  | 30-11-2020 16:15 | 17.35 |  |
| Motipur 220 kv GSS     | DMTCL-1                     | 220 | Line        | 52.91  | 05-11-2020 17:45 | 0.22  | 24-11-2020 16:45 | 17.35 |  |
| Motipur 220 kv GSS     | Motihari                    | 132 | Line        | 44.23  | 01-11-2020 19:45 | 0.01  | 08-11-2020 17:45 | 8.01  |  |
| Motipur 220 kv GSS     | Muzaffarpur-1               | 132 | Line        | 35.56  | 06-11-2020 01:30 | 0.01  | 09-11-2020 03:30 | 20.82 |  |
| Motipur 220 kv GSS     | Muzaffarpur -2              | 132 | Line        | 33.42  | 01-11-2020 18:00 | 3.07  | 05-11-2020 04:45 | 20.92 |  |
| Motipur 220 kv GSS     | Chakia                      | 132 | Line        | 21.88  | 01-11-2020 18:15 | 0.14  | 23-11-2020 17:00 | 13.67 |  |
| Motipur 220 kv GSS     | TRF-2(LV)                   | 33  | Transformer | 9.15   | 30-11-2020 19:00 | 0.43  | 09-11-2020 16:00 | 4.59  |  |
| Motipur 220 kv GSS     | TRF-1(LV)                   | 33  | Transformer | 9.08   | 30-11-2020 19:00 | 0.57  | 20-11-2020 16:15 | 4.56  |  |
| Motipur 220 kv GSS     | TRF-3(LV)                   | 33  | Transformer | 9.06   | 30-11-2020 19:00 | 0.45  | 09-11-2020 16:00 | 4.55  |  |
| Motipur 220 kv GSS     | Railway Main Meter          | 132 | Line        | 6.50   | 29-11-2020 17:45 | 0.02  | 08-11-2020 11:30 | 1.49  |  |
| Motipur 220 kv GSS     | MTPS                        | 132 | Line        |        |                  |       |                  |       | Charge on no load  |
| Mushahari 220 kv GSS   | Darbhanga-2                 | 220 | Line        | 119.29 | 05-11-2020 17:45 | 6.75  | 27-11-2020 18:15 | 66.34 |  |
| Mushahari 220 kv GSS   | Motipur-2                   | 220 | Line        | 74.71  | 28-11-2020 17:45 | 2.26  | 05-11-2020 15:30 | 29.14 |  |
| Mushahari 220 kv GSS   | Motipur-1                   | 220 | Line        | 70.61  | 28-11-2020 17:45 | 1.21  | 05-11-2020 08:15 | 27.72 |  |
| Mushahari 220 kv GSS   | Sitamari-2                  | 132 | Line        | 65.26  | 15-11-2020 17:45 | 6.58  | 03-11-2020 07:45 | 33.49 |  |
| Mushahari 220 kv GSS   | Sitamari-1                  | 132 | Line        | 65.14  | 15-11-2020 17:45 | 13.32 | 05-11-2020 03:45 | 33.38 |  |
| Mushahari 220 kv GSS   | SKMCH-2                     | 132 | Line        | 49.94  | 30-11-2020 17:00 | 0.00  | 06-11-2020 01:00 | 1.84  |  |
| Mushahari 220 kv GSS   | SKMCH-1                     | 132 | Line        | 30.16  | 01-11-2020 20:00 | 0.01  | 30-11-2020 10:30 | 15.10 |  |
| Mushahari 220 kv GSS   | TRF-2(LV)                   | 33  | Transformer | 26.90  | 03-11-2020 17:00 | 0.21  | 12-11-2020 14:00 | 7.87  |  |
| Mushahari 220 kv GSS   | TRF-3(LV)                   | 33  | Transformer | 24.02  | 16-11-2020 13:30 | 0.66  | 04-11-2020 12:45 | 4.12  |  |
| Mushahari 220 kv GSS   | TRF-1(LV)                   | 33  | Transformer | 22.68  | 17-11-2020 18:30 | 0.44  | 12-11-2020 14:15 | 12.77 |  |
| Mushahari 220 kv GSS   | Darbhanga-1                 | 220 | Line        |        |                  |       |                  |       | Charge on no load  |
| Muzaffarpur 132 kv GSS | Vaishali-2                  | 132 | Line        | 64.71  | 23-11-2020 19:00 | 5.09  | 08-11-2020 06:00 | 28.87 |  |
| Muzaffarpur 132 kv GSS | Motipur-1                   | 132 | Line        | 35.15  | 06-11-2020 01:30 | 0.02  | 09-11-2020 03:45 | 20.99 |  |
| Muzaffarpur 132 kv GSS | Motipur-2                   | 132 | Line        | 33.04  | 01-11-2020 18:00 | 0.01  | 08-11-2020 02:45 | 21.08 |  |
| Muzaffarpur 132 kv GSS | SKMCH                       | 132 | Line        | 18.83  | 01-11-2020 18:45 | 0.00  | 28-11-2020 14:15 | 6.36  | Power flows through T/B of Muzaffarpur data taken from SKMCH end |
| Muzaffarpur 132 kv GSS | Vaishali-1                  | 132 | Line        | 18.67  | 01-11-2020 18:45 | 0.00  | 12-11-2020 18:15 | 3.97  | Data is taken from Other end                                     |
| Muzaffarpur 132 kv GSS | TRF-2 (LV)                  | 33  | Transformer | 27.34  | 19-11-2020 18:00 | 3.74  | 09-11-2020 03:45 | 14.84 |  |
| Muzaffarpur 132 kv GSS | TRF-3 (LV)                  | 33  | Transformer | 26.65  | 21-11-2020 05:00 | 0.06  | 04-11-2020 12:30 | 15.90 |  |
| Muzaffarpur 132 kv GSS | TRF-1 (LV)                  | 33  | Transformer | 19.95  | 01-11-2020 18:00 | 1.04  | 09-11-2020 03:45 | 10.87 |  |
| Nalanda 132 kv GSS     | Biharsharif                 | 132 | Line        | 22.80  | 14-11-2020 08:15 | 2.22  | 28-11-2020 16:15 | 14.54 |  |
| Nalanda 132 kv GSS     | Barhi(DVC)                  | 132 | Line        | 16.68  | 29-11-2020 17:30 | 7.05  | 29-11-2020 17:45 | 0.20  |  |
| Nalanda 132 kv GSS     | TRF-2(LV)                   | 33  | Transformer | 8.93   | 01-11-2020 07:30 | 0.31  | 19-11-2020 11:45 | 3.02  |  |
| Nalanda 132 kv GSS     | TRF-1(LV)                   | 33  | Transformer | 8.91   | 01-11-2020 07:30 | 1.87  | 01-11-2020 13:15 | 0.13  |  |
| Nalanda 132 kv GSS     | TRF-3(LV)                   | 33  | Transformer | 18.70  | 14-11-2020 08:00 | 5.20  | 20-11-2020 18:00 | 12.00 |  |
| Narkatiaganj 132kv GSS | Bettiah-1                   | 132 | Line        | 12.51  | 01-11-2020 20:00 | 0.03  | 15-11-2020 14:15 | 6.74  |  |
| Narkatiaganj 132kv GSS | TRF-2(LV)                   | 33  | Transformer | 6.24   | 01-11-2020 20:00 | 0.50  | 04-11-2020 13:30 | 3.36  |  |
| Narkatiaganj 132kv GSS | TRF-1(LV)                   | 33  | Transformer | 6.22   | 01-11-2020 20:00 | 0.50  | 04-11-2020 13:30 | 3.35  |  |
| Naugachia 132 kv GSS   | Khagaria(New)               | 132 | Line        | 32.68  | 02-11-2020 01:45 | 0.20  | 13-11-2020 18:30 | 17.88 |  |
| Naugachia 132 kv GSS   | TRF-4(LV)                   | 33  | Transformer | 25.28  | 01-11-2020 20:15 | 0.11  | 13-11-2020 13:00 | 10.71 |  |



|                       |                            |     |             |        |                  |       |                  |       |   |
|-----------------------|----------------------------|-----|-------------|--------|------------------|-------|------------------|-------|---|
| Naugachia 132 kV GSS  | TRF-3(LV)                  | 33  | Transformer | 9.06   | 02-11-2020 19:45 | 0.04  | 13-11-2020 13:00 | 3.70  |   |
| Naugachia 132 kV GSS  | TRF-1(LV)                  | 33  | Transformer | 8.59   | 02-11-2020 19:45 | 0.03  | 18-11-2020 23:30 | 4.03  |   |
| Naugachia 132 kV GSS  | TRF-2(LV)                  | 33  | Transformer |        |                  |       |                  |       | Charge on no load                         |
| Naugachia 132 kV GSS  | Purnea                     | 132 | Line        |        |                  |       |                  |       | Charge on no load                         |
| Nawada 132 kV GSS     | Gis Narhat(BGCL) Line-1    | 132 | Line        | 35.43  | 29-11-2020 18:00 | 0.08  | 15-11-2020 06:45 | 18.24 |   |
| Nawada 132 kV GSS     | Gis Narhat(BGCL) Line-2    | 132 | Line        | 35.39  | 29-11-2020 18:00 | 0.08  | 15-11-2020 06:45 | 18.20 |   |
| Nawada 132 kV GSS     | Warsaliganj                | 132 | Line        | 23.05  | 29-11-2020 08:45 | 0.00  | 24-11-2020 19:30 | 10.30 |   |
| Nawada 132 kV GSS     | TRF-3(LV)                  | 33  | Transformer | 22.64  | 22-11-2020 16:45 | 1.90  | 27-11-2020 11:45 | 12.18 |   |
| Nawada 132 kV GSS     | TRF-1(LV)                  | 33  | Transformer | 20.03  | 15-11-2020 17:45 | 0.32  | 22-11-2020 17:00 | 11.45 |   |
| Nawada 132 kV GSS     | TRF-4(LV)                  | 33  | Transformer | 18.73  | 22-11-2020 16:45 | 0.10  | 30-11-2020 13:15 | 10.11 |   |
| Nawada 132 kV GSS     | TRF-2(LV)                  | 33  | Transformer |        |                  |       |                  |       | Charge on no load                         |
| Nawada 132 kV GSS     | Wazirganj                  | 132 | Line        |        |                  |       |                  |       | Charge on no load                         |
| Nawada 132 kV GSS     | Biharsharif                | 132 | Line        |        |                  |       |                  |       | Charge on no load                         |
| New Banka 132 kV GSS  | Banka-2                    | 132 | Line        | 24.71  | 20-11-2020 18:00 | 0.35  | 28-11-2020 12:15 | 16.78 |   |
| New Banka 132 kV GSS  | Jamui-2                    | 132 | Line        | 11.72  | 30-11-2020 10:15 | 0.02  | 24-11-2020 10:30 | 4.89  |   |
| New Banka 132 kV GSS  | Jamui New-1                | 132 | Line        | 10.53  | 28-11-2020 18:00 | 0.01  | 24-11-2020 11:00 | 4.96  |   |
| New Banka 132 kV GSS  | TRF-2(LV)                  | 33  | Transformer | 10.68  | 20-11-2020 18:00 | 0.13  | 28-11-2020 12:15 | 7.07  |   |
| New Banka 132 kV GSS  | TRF-3(LV)                  | 33  | Transformer |        |                  |       |                  |       | Charge on no load                         |
| New Banka 132 kV GSS  | Banka-1                    | 132 | Line        |        |                  |       |                  |       | Charge on no load                         |
| New Jamui 132 kV GSS  | Jamui Old-1                | 132 | Line        | 25.39  | 28-11-2020 17:45 | 0.01  | 28-11-2020 12:15 | 0.79  |   |
| New Jamui 132 kV GSS  | Banka New-2                | 132 | Line        | 11.68  | 30-11-2020 10:15 | 0.01  | 29-11-2020 10:15 | 4.75  |   |
| New Jamui 132 kV GSS  | Banka New-1                | 132 | Line        | 10.54  | 28-11-2020 18:00 | 0.00  | 29-11-2020 10:15 | 4.87  |   |
| New Jamui 132 kV GSS  | TRF-3(LV)                  | 33  | Transformer | 7.42   | 28-11-2020 17:45 | 0.11  | 28-11-2020 12:15 | 4.73  |   |
| New Jamui 132 kV GSS  | TRF-2(LV)                  | 33  | Transformer | 7.38   | 28-11-2020 17:45 | 0.10  | 28-11-2020 12:15 | 4.70  |   |
| New Jamui 132 kV GSS  | Jamui Old-2                | 132 | Line        |        |                  |       |                  |       | Charge on no load                         |
| Nirmali 132 kV GSS    | Supaul                     | 132 | Line        | 60.97  | 27-11-2020 17:00 | 1.13  | 05-11-2020 06:00 | 22.14 |   |
| Nirmali 132 kV GSS    | Phulparas                  | 132 | Line        | 58.66  | 27-11-2020 17:00 | 0.00  | 05-11-2020 18:15 | 20.12 |   |
| Nirmali 132 kV GSS    | TRF-2(LV)                  | 33  | Transformer | 5.33   | 01-11-2020 19:30 | 0.99  | 17-11-2020 09:00 | 1.30  |   |
| Nirmali 132 kV GSS    | TRF-1(LV)                  | 33  | Transformer | 4.38   | 19-11-2020 18:00 | 0.00  | 17-11-2020 09:00 | 1.01  |   |
| Pakridayal 132 kV GSS | TRF-1(LV)                  | 33  | Transformer | 2.79   | 05-11-2020 18:15 | 0.01  | 07-11-2020 00:00 | 1.51  |   |
| Pakridayal 132 kV GSS | TRF-2(LV)                  | 33  | Transformer | 2.77   | 04-11-2020 17:45 | 0.02  | 05-11-2020 14:45 | 1.22  |   |
| Pakridayal 132 kV GSS | Dhaka                      | 132 | Line        | 3.57   | 01-11-2020 18:45 | 0.01  | 09-11-2020 09:30 | 2.12  |   |
| Pandaul 132 kV GSS    | Phulparas 1                | 132 | Line        | 56.03  | 27-11-2020 17:00 | 2.12  | 23-11-2020 16:45 | 20.32 |   |
| Pandaul 132 kV GSS    | Madhubani-2                | 132 | Line        | 48.85  | 29-11-2020 11:15 | 1.29  | 29-11-2020 15:45 | 0.63  |   |
| Pandaul 132 kV GSS    | Madhubani-1                | 132 | Line        | 34.80  | 27-11-2020 10:45 | 3.60  | 05-11-2020 22:15 | 1.08  |   |
| Pandaul 132 kV GSS    | Gangwara                   | 132 | Line        | 14.79  | 15-11-2020 16:15 | 0.00  | 07-11-2020 13:30 | 0.06  |   |
| Pandaul 132 kV GSS    | TRF-3(LV)                  | 33  | Transformer | 20.67  | 01-11-2020 20:15 | 0.02  | 23-11-2020 16:45 | 10.01 |   |
| Pandaul 132 kV GSS    | TRF-1(LV)                  | 33  | Transformer | 18.82  | 01-11-2020 20:15 | 0.00  | 23-11-2020 16:45 | 9.02  |   |
| Pandaul 132 kV GSS    | Sakari_TSS_Check           | 132 | Line        | 3.97   | 13-11-2020 14:45 | 0.00  | 04-11-2020 05:00 | 0.98  |   |
| Pandaul 132 kV GSS    | Phulparas 2(Old Darbhanga) | 132 | Line        |        |                  |       |                  |       | Charge on no load                         |
| Phulparas 132 kV GSS  | Pandaul1                   | 132 | Line        | 57.83  | 27-11-2020 17:00 | 0.00  | 05-11-2020 08:45 | 20.10 |   |
| Phulparas 132 kV GSS  | Nirmali                    | 132 | Line        | 57.17  | 27-11-2020 17:00 | 0.00  | 04-11-2020 18:15 | 19.86 |   |
| Phulparas 132 kV GSS  | Supaul                     | 132 | Line        | 55.35  | 01-11-2020 20:45 | 0.32  | 12-11-2020 13:15 | 28.82 |   |
| Phulparas 132 kV GSS  | Jainagar                   | 132 | Line        | 25.37  | 01-11-2020 19:15 | 0.00  | 12-11-2020 13:15 | 12.60 | Data is taken from Jainagar end.          |
| Phulparas 132 kV GSS  | Jhanjharpur                | 132 | Line        | 11.20  | 01-11-2020 20:15 | 0.00  | 12-11-2020 13:15 | 4.92  |   |
| Phulparas 132 kV GSS  | TRF-1(LV)                  | 33  | Transformer | 11.09  | 14-11-2020 19:15 | 0.15  | 12-11-2020 13:15 | 6.03  |   |
| Phulparas 132 kV GSS  | TRF-2(LV)                  | 33  | Transformer | 11.02  | 14-11-2020 19:15 | 0.00  | 26-11-2020 09:30 | 6.00  |   |
| Phulparas 132 kV GSS  | Pandaul 2(Old Madhubani)   | 132 | Line        |        |                  |       |                  |       | Charge on no load                         |
| Piro 132 kV GSS       | Bikramganj                 | 132 | Line        | 14.02  | 11-11-2020 17:45 | 0.12  | 29-11-2020 10:30 | 7.43  |   |
| Piro 132 kV GSS       | TRF-2(LV)                  | 33  | Transformer | 6.90   | 11-11-2020 17:45 | 0.06  | 29-11-2020 10:30 | 3.70  |   |
| Piro 132 kV GSS       | TRF-1(LV)                  | 33  | Transformer | 6.89   | 11-11-2020 17:45 | 0.06  | 29-11-2020 10:30 | 3.94  |   |
| Pupri 132 kV GSS      | Benipatti                  | 132 | Line        | 16.33  | 01-11-2020 19:30 | 0.01  | 05-11-2020 05:30 | 8.56  |   |
| Pupri 132 kV GSS      | TRF-2(LV)                  | 33  | Transformer | 14.36  | 01-11-2020 19:30 | 0.11  | 13-11-2020 13:00 | 7.55  |   |
| Pupri 132 kV GSS      | TRF-1(LV)                  | 33  | Transformer | 4.25   | 29-11-2020 11:15 | 0.00  | 17-11-2020 09:30 | 0.87  |   |
| Purnea 132 kV GSS     | PURNEA-PGCIL-III           | 132 | Line        | 82.24  | 01-11-2020 18:45 | 23.20 | 04-11-2020 12:15 | 42.33 |   |
| Purnea 132 kV GSS     | PURNEA-PGCIL-II            | 132 | Line        | 71.40  | 01-11-2020 18:45 | 20.23 | 04-11-2020 12:15 | 36.87 |   |
| Purnea 132 kV GSS     | PURNEA-PGCIL-I             | 132 | Line        | 70.78  | 01-11-2020 18:45 | 20.02 | 04-11-2020 12:15 | 36.55 |   |
| Purnea 132 kV GSS     | Katihar                    | 132 | Line        | 62.38  | 01-11-2020 21:30 | 15.84 | 20-11-2020 16:30 | 30.62 | Manihari also avails power from this line |
| Purnea 132 kV GSS     | Dhamdaha                   | 132 | Line        | 38.67  | 01-11-2020 20:00 | 3.87  | 20-11-2020 16:45 | 18.98 |   |
| Purnea 132 kV GSS     | Triveniganj                | 132 | Line        | 34.10  | 24-11-2020 17:15 | 0.09  | 14-11-2020 10:45 | 12.73 |   |
| Purnea 132 kV GSS     | Naugachia                  | 132 | Line        | 33.31  | 01-11-2020 20:15 | 0.16  | 13-11-2020 13:00 | 17.84 |   |
| Purnea 132 kV GSS     | TRF-3(LV)                  | 33  | Transformer | 34.88  | 03-11-2020 13:30 | 7.70  | 18-11-2020 15:15 | 14.44 |   |
| Purnea 132 kV GSS     | TRF-1(LV)                  | 33  | Transformer | 30.05  | 01-11-2020 19:00 | 8.30  | 18-11-2020 15:15 | 15.99 |   |
| Purnea 132 kV GSS     | TRF-2(LV)                  | 33  | Transformer | 18.80  | 01-11-2020 19:45 | 0.80  | 04-11-2020 12:00 | 7.52  |   |
| Purnea 132 kV GSS     | Khagaria (New)             | 132 | Line        |        |                  |       |                  |       | Charge on no load                         |
| Pusauli 220 kV GSS    | Pusauli (PG)-1             | 220 | Line        | 131.63 | 14-11-2020 17:45 | 31.87 | 05-11-2020 15:00 | 82.17 |   |
| Pusauli 220 kV GSS    | Pusauli (PG)-2             | 220 | Line        | 92.57  | 14-11-2020 17:45 | 22.63 | 05-11-2020 15:00 | 58.00 |   |
| Pusauli 220 kV GSS    | Kochas                     | 132 | Line        | 65.14  | 27-11-2020 07:30 | 0.00  | 30-11-2020 14:45 | 24.12 |   |
| Pusauli 220 kV GSS    | Kudra TSS                  | 132 | Line        | 47.50  | 01-11-2020 18:15 | 0.14  | 09-11-2020 13:15 | 29.50 |   |
| Pusauli 220 kV GSS    | Ara (PG)-2                 | 220 | Line        | 42.85  | 11-11-2020 20:15 | 0.25  | 08-11-2020 07:30 | 17.81 |   |
| Pusauli 220 kV GSS    | Ara (PG)-1                 | 220 | Line        | 42.79  | 11-11-2020 20:15 | 0.25  | 18-11-2020 09:45 | 17.82 |   |
| Pusauli 220 kV GSS    | Sasaram                    | 132 | Line        | 36.94  | 14-11-2020 18:00 | 0.06  | 18-11-2020 15:45 | 26.35 |   |
| Pusauli 220 kV GSS    | Ramgarh                    | 132 | Line        | 36.52  | 21-11-2020 15:45 | 0.12  | 06-11-2020 12:00 | 17.53 |   |
| Pusauli 220 kV GSS    | Bhabua(Mundeshwari)        | 132 | Line        | 16.40  | 23-11-2020 18:15 | 0.00  | 13-11-2020 14:15 | 8.97  |   |
| Pusauli 220 kV GSS    | TRF-1(LV)                  | 33  | Transformer | 3.50   | 01-11-2020 18:30 | 0.18  | 21-11-2020 16:30 | 2.14  |   |
| Pusauli 220 kV GSS    | TRF-2(LV)                  | 33  | Transformer | 3.49   | 01-11-2020 18:30 | 0.11  | 21-11-2020 16:30 | 2.14  |   |
| Rafiganj 132 kV GSS   | Chandauti                  | 132 | Line        | 44.94  | 25-11-2020 18:15 | 1.87  | 11-11-2020 12:45 | 25.13 |   |
| Rafiganj 132 kV GSS   | Solar (Main)               | 132 | Line        | 15.92  | 21-11-2020 12:15 | 0.03  | 26-11-2020 17:00 | 4.02  |   |
| Rafiganj 132 kV GSS   | Railway-2                  | 132 | Line        | 13.14  | 24-11-2020 02:30 | 0.00  | 05-11-2020 19:45 | 2.41  |   |
| Rafiganj 132 kV GSS   | Railway-1                  | 132 | Line        | 12.36  | 22-11-2020 19:45 | 0.01  | 17-11-2020 13:30 | 2.71  |   |
| Rafiganj 132 kV GSS   | TRF 2                      | 33  | Transformer | 25.43  | 29-11-2020 18:15 | 1.32  | 06-11-2020 11:45 | 17.22 |   |
| Rafiganj 132 kV GSS   | TRF 1                      | 33  | Transformer | 12.70  | 22-11-2020 09:00 | 0.00  | 11-11-2020 06:30 | 6.60  |   |
| Rafiganj 132 kV GSS   | Sonenagar                  | 132 | Line        |        |                  |       |                  |       | Charge on no load                         |
| Raghopur 132 kV GSS   | Laukahi                    | 132 | Line        | 37.05  | 02-11-2020 18:00 | 5.27  | 04-11-2020 12:15 | 18.01 |   |
| Raghopur 132 kV GSS   | Supaul                     | 132 | Line        | 36.77  | 02-11-2020 18:00 | 5.26  | 04-11-2020 12:15 | 17.43 |   |
| Raghopur 132 kV GSS   | TRF-3(LV)                  | 33  | Transformer | 12.46  | 01-11-2020 19:00 | 0.00  | 24-11-2020 17:00 | 6.69  |   |
| Raghopur 132 kV GSS   | TRF-1(LV)                  | 33  | Transformer |        |                  |       |                  |       | Charge on no load                         |
| Raghopur 132 kV GSS   | TRF-2(LV)                  | 33  | Transformer |        |                  |       |                  |       | Charge on no load                         |

|                          |  |     |             |       |                  |       |                  |       |  |
|--------------------------|--|-----|-------------|-------|------------------|-------|------------------|-------|--|
| Raghunathpur 132 kv GSS  | Chhapra(T at Ekma)                       | 132 | Line        | 45.08 | 18-11-2020 19:00 | 0.01  | 08-11-2020 11:30 | 17.97 | Data is taken from Chhapra end.  |
| Raghunathpur 132 kv GSS  | Siwan                                    | 132 | Line        | 29.04 | 29-11-2020 17:15 | 0.28  | 13-11-2020 13:00 | 10.64 |  |
| Raghunathpur 132 kv GSS  | TRF-2(LV)                                | 33  | Transformer | 13.89 | 01-11-2020 18:15 | 0.02  | 23-11-2020 14:30 | 9.06  |  |
| Raghunathpur 132 kv GSS  | TRF-3(LV)                                | 33  | Transformer | 13.60 | 01-11-2020 18:15 | 0.02  | 23-11-2020 14:30 | 8.85  |  |
| Rajgir 132 kv GSS        | Biharsharif                              | 132 | Line        | 21.85 | 17-11-2020 18:15 | 3.26  | 20-11-2020 05:15 | 15.23 |  |
| Rajgir 132 kv GSS        | Barhi(DVC)                               | 132 | Line        | 18.76 | 29-11-2020 17:30 | 3.32  | 29-11-2020 17:45 | 0.19  |  |
| Rajgir 132 kv GSS        | TRF-3(LV)                                | 33  | Transformer | 18.71 | 17-11-2020 18:15 | 0.85  | 20-11-2020 05:15 | 13.40 |  |
| Rajgir 132 kv GSS        | TRF-1(LV)                                | 33  | Transformer | 2.43  | 17-11-2020 18:00 | 0.04  | 13-11-2020 14:30 | 1.45  |  |
| Rajgir 132 kv GSS        | TRF-2(LV)                                | 33  | Transformer |       |                  |       |                  |       | Charge on no load  |
| Rajgir 132 kv GSS        | Nalanda(T at Nalanda-Barhi)              | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Ramgarh 132 kv GSS       | Pusauli                                  | 132 | Line        | 36.52 | 21-11-2020 15:45 | 0.12  | 06-11-2020 12:00 | 17.53 |  |
| Ramgarh 132 kv GSS       | Mohanua                                  | 132 | Line        | 31.21 | 21-11-2020 15:45 | 0.00  | 05-11-2020 21:00 | 10.22 |  |
| Ramgarh 132 kv GSS       | TRF-1(LV)                                | 33  | Transformer | 6.40  | 01-11-2020 18:30 | 0.02  | 06-11-2020 12:00 | 4.00  |  |
| Ramgarh 132 kv GSS       | TRF-2(LV)                                | 33  | Transformer | 6.36  | 01-11-2020 18:30 | 0.03  | 06-11-2020 12:00 | 3.97  |  |
| Ramnagar 132 kv GSS      | Bettiah                                  | 132 | Line        | 63.35 | 01-11-2020 19:30 | 0.58  | 30-11-2020 14:15 | 30.28 |  |
| Ramnagar 132 kv GSS      | Harinagar Sugar                          | 132 | line        | 13.72 | 30-11-2020 14:00 | 0.00  | 02-11-2020 00:00 | 5.40  |  |
| Ramnagar 132 kv GSS      | TRF-1(LV)                                | 33  | Transformer | 31.75 | 04-11-2020 17:30 | 0.10  | 30-11-2020 13:15 | 10.35 |  |
| Ramnagar 132 kv GSS      | TRF-3(LV)                                | 33  | Transformer | 21.48 | 01-11-2020 19:15 | 0.02  | 04-11-2020 17:30 | 11.22 |  |
| Ramnagar 132 kv GSS      | TRF-2(LV)                                | 33  | Transformer | 15.11 | 27-11-2020 19:15 | 0.23  | 27-11-2020 13:30 | 0.56  |  |
| Ramnagar 132 kv GSS      | Valmiki Nagar                            | 132 | Line        | 6.03  | 29-11-2020 20:00 | 2.60  | 05-11-2020 03:30 | 1.74  |  |
| Ramnagar 132 kv GSS      | Narkatiaganj Sugar (Swadeshi Sugar Mill) | 132 | Line        | 5.94  | 29-11-2020 10:00 | 0.00  | 01-11-2020 00:00 | 2.00  |  |
| Ramnagar 132 kv GSS      | Harinagar_TSS_Main                       | 132 | Line        | 4.02  | 03-11-2020 15:30 | 0.06  | 09-11-2020 13:00 | 0.83  |  |
| Ramnagar 132 kv GSS      | Louria Sugar                             | 132 | Line        | 2.30  | 20-11-2020 17:00 | 0.00  | 01-11-2020 00:00 | 1.50  |  |
| Raxaul 132 kv GSS        | Parwanipur (Nepal)                       | 132 | Line        | 80.42 | 10-11-2020 18:15 | 0.00  | 18-11-2020 13:00 | 7.70  |  |
| Raxaul 132 kv GSS        | DMTCL-I                                  | 132 | Line        | 52.22 | 10-11-2020 18:15 | 1.74  | 23-11-2020 18:15 | 13.32 |  |
| Raxaul 132 kv GSS        | DMTCL-II                                 | 132 | Line        | 52.19 | 10-11-2020 18:15 | 1.74  | 23-11-2020 18:15 | 13.32 |  |
| Raxaul 132 kv GSS        | Bettiah-II                               | 132 | Line        | 8.47  | 01-11-2020 19:15 | 0.00  | 29-11-2020 12:15 | 2.60  |  |
| Raxaul 132 kv GSS        | Bettiah-I                                | 132 | Line        | 8.45  | 01-11-2020 19:15 | 0.00  | 06-11-2020 17:00 | 2.60  |  |
| Raxaul 132 kv GSS        | TRF-2(LV)                                | 33  | Transformer | 15.83 | 01-11-2020 20:15 | 1.11  | 13-11-2020 13:00 | 10.34 |  |
| Raxaul 132 kv GSS        | TRF-1(LV)                                | 33  | Transformer | 15.14 | 01-11-2020 20:15 | 0.04  | 24-11-2020 10:45 | 9.12  |  |
| Rosera 132 kv GSS        | Dalsingh Sarai                           | 132 | Line        | 22.52 | 01-11-2020 20:45 | 1.62  | 18-11-2020 18:15 | 11.99 |  |
| Rosera 132 kv GSS        | TRF-1(LV)                                | 33  | Transformer | 11.08 | 01-11-2020 20:45 | 0.81  | 18-11-2020 18:15 | 6.14  |  |
| Rosera 132 kv GSS        | TRF-2(LV)                                | 33  | Transformer | 10.99 | 01-11-2020 20:45 | 0.79  | 18-11-2020 18:15 | 5.80  |  |
| Rosera 132 kv GSS        | Hasanpur Sugar mill                      | 132 | Line        | 4.22  | 27-11-2020 01:15 | 0.00  | 30-11-2020 17:45 | 0.92  |  |
| Rosera 132 kv GSS        | Kusheshawarsthan                         | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Runni Saidpur 132 kv GSS | Belsand                                  | 132 | Line        | 22.49 | 01-11-2020 20:15 | 0.60  | 23-11-2020 16:45 | 10.88 |  |
| Runni Saidpur 132 kv GSS | Sitamarihi                               | 132 | Line        | 20.62 | 15-11-2020 17:45 | 0.00  | 11-11-2020 18:15 | 2.45  |  |
| Runni Saidpur 132 kv GSS | TRF-2(LV)                                | 33  | Transformer | 16.68 | 01-11-2020 20:00 | 0.40  | 23-11-2020 16:45 | 9.29  |  |
| Runni Saidpur 132 kv GSS | TRF-1(LV)                                | 33  | Transformer | 5.36  | 01-11-2020 20:15 | 0.00  | 15-11-2020 07:45 | 2.66  |  |
| Sabour 132 kv GSS        | NTPC                                     | 132 | Line        | 53.67 | 30-11-2020 08:30 | 14.24 | 07-11-2020 13:00 | 32.14 |  |
| Sabour 132 kv GSS        | Goradih BGCL-1                           | 132 | Line        | 41.96 | 30-11-2020 17:45 | 7.19  | 08-11-2020 13:30 | 20.56 |  |
| Sabour 132 kv GSS        | Goradih BGCL-2                           | 132 | Line        | 41.84 | 30-11-2020 17:45 | 7.18  | 08-11-2020 13:30 | 20.51 |  |
| Sabour 132 kv GSS        | BANKA-PGCIL-I                            | 132 | Line        | 38.46 | 30-11-2020 17:45 | 1.16  | 28-11-2020 15:45 | 21.62 |  |
| Sabour 132 kv GSS        | BANKA-PGCIL-II                           | 132 | Line        | 38.28 | 30-11-2020 17:45 | 9.59  | 27-11-2020 14:30 | 21.51 |  |
| Sabour 132 kv GSS        | Jagdishpur New                           | 132 | Line        | 12.71 | 26-11-2020 09:15 | 0.30  | 04-11-2020 11:45 | 5.50  |  |
| Sabour 132 kv GSS        | TRF-2(LV)                                | 33  | Transformer | 22.03 | 01-11-2020 10:30 | 0.13  | 05-11-2020 13:30 | 9.54  |  |
| Sabour 132 kv GSS        | TRF-3(LV)                                | 33  | Transformer | 21.28 | 05-11-2020 14:45 | 0.13  | 05-11-2020 13:30 | 8.88  |  |
| Sabour 132 kv GSS        | TRF-1(LV)                                | 33  | Transformer | 18.46 | 01-11-2020 18:15 | 0.36  | 16-11-2020 23:30 | 11.30 |  |
| Sabour 132 kv GSS        | Kahalgaoon                               | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Sabour 132 kv GSS        | Sultanganj-2                             | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Saharsa 132 kv GSS       | Madhepura-3                              | 132 | Line        | 54.23 | 01-11-2020 00:00 | 2.56  | 01-11-2020 06:00 | 22.01 |  |
| Saharsa 132 kv GSS       | Sonebarsa                                | 132 | Line        | 38.88 | 01-11-2020 00:00 | 0.00  | 19-11-2020 16:15 | 4.79  |  |
| Saharsa 132 kv GSS       | Madhepura-1                              | 132 | Line        | 36.90 | 01-11-2020 00:00 | 0.10  | 02-11-2020 10:00 | 14.80 |  |
| Saharsa 132 kv GSS       | Udakishanganj-1                          | 132 | Line        | 32.34 | 01-11-2020 20:00 | 0.18  | 01-11-2020 06:00 | 16.97 |  |
| Saharsa 132 kv GSS       | TRF-2(LV)                                | 33  | Transformer | 14.76 | 01-11-2020 20:15 | 0.59  | 01-11-2020 06:00 | 8.09  |  |
| Saharsa 132 kv GSS       | TRF-1(LV)                                | 33  | Transformer | 13.94 | 01-11-2020 20:30 | 0.32  | 08-11-2020 12:00 | 7.85  |  |
| Saharsa 132 kv GSS       | Banmankhi                                | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Saharsa 132 kv GSS       | Madhepura-2                              | 132 | Line        |       |                  |       |                  |       | Charged at no load<br>Charged up to Gantry end of Saharsa from Udakishanganj end |
| Saharsa 132 kv GSS       | Udakishanganj-2                          | 132 | Line        |       |                  |       |                  |       |  |
| Samastipur 132 kv GSS    | Samastipur New-2                         | 132 | Line        | 54.76 | 18-11-2020 17:45 | 2.93  | 18-11-2020 05:45 | 26.02 |  |
| Samastipur 132 kv GSS    | Samastipur New-1                         | 132 | Line        | 54.62 | 18-11-2020 17:45 | 2.55  | 18-11-2020 05:45 | 25.96 |  |
| Samastipur 132 kv GSS    | Dalsingh Sarai                           | 132 | Line        | 43.94 | 18-11-2020 17:45 | 0.00  | 18-11-2020 09:30 | 2.01  |  |
| Samastipur 132 kv GSS    | Darbhanga                                | 132 | Line        | 42.71 | 01-11-2020 17:45 | 0.00  | 07-11-2020 14:00 | 7.74  |  |
| Samastipur 132 kv GSS    | Railway                                  | 132 | Line        | 11.51 | 10-11-2020 19:15 | 0.01  | 27-11-2020 20:15 | 4.01  |  |
| Samastipur 132 kv GSS    | MTPS-1                                   | 132 | Line        | 9.24  | 29-11-2020 15:45 | 0.05  | 02-11-2020 14:00 | 5.34  |  |
| Samastipur 132 kv GSS    | Jandaha                                  | 132 | Line        | 8.26  | 14-11-2020 20:15 | 0.00  | 30-11-2020 05:00 | 4.53  |  |
| Samastipur 132 kv GSS    | TRF-2(LV)                                | 33  | Transformer | 37.06 | 14-11-2020 19:30 | 1.12  | 11-11-2020 17:15 | 19.16 |  |
| Samastipur 132 kv GSS    | TRF-3(LV)                                | 33  | Transformer | 21.50 | 01-11-2020 18:45 | 0.28  | 18-11-2020 05:45 | 8.70  |  |
| Samastipur 132 kv GSS    | TRF-1(LV)                                | 33  | Transformer | 20.37 | 01-11-2020 18:45 | 0.26  | 18-11-2020 05:45 | 8.23  |  |
| Samastipur 132 kv GSS    | Hajipur                                  | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Samastipur 132 kv GSS    | Begusarai                                | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Samastipur 132 kv GSS    | MTPS-2                                   | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Samastipur 220 kv GSS    | DMTCL                                    | 220 | Line        | 80.23 | 06-11-2020 19:00 | 0.44  | 22-11-2020 17:00 | 40.85 |  |
| Samastipur 220 kv GSS    | Samastipur Old-1                         | 132 | Line        | 54.68 | 18-11-2020 17:45 | 0.00  | 11-11-2020 17:15 | 25.97 |  |
| Samastipur 220 kv GSS    | Samastipur Old-2                         | 132 | Line        | 54.65 | 18-11-2020 17:45 | 2.92  | 18-11-2020 05:45 | 26.01 |  |
| Samastipur 220 kv GSS    | MTPS-2                                   | 220 | Line        | 46.92 | 24-11-2020 07:15 | 0.00  | 13-11-2020 16:15 | 19.75 |  |
| Samastipur 220 kv GSS    | MTPS-1                                   | 220 | Line        | 46.85 | 24-11-2020 07:15 | 0.01  | 12-11-2020 18:15 | 19.70 |  |
| Samastipur 220 kv GSS    | Begusarai-1                              | 220 | Line        | 45.39 | 01-11-2020 00:30 | 0.30  | 06-11-2020 11:00 | 16.98 |  |
| Samastipur 220 kv GSS    | Begusarai-2                              | 220 | Line        | 45.27 | 01-11-2020 00:30 | 0.34  | 06-11-2020 18:15 | 17.13 |  |
| Samastipur 220 kv GSS    | Shahpur Patori                           | 132 | Line        | 7.02  | 01-11-2020 21:45 | 0.36  | 12-11-2020 14:30 | 4.00  |  |
| Samastipur 220 kv GSS    | TRF-1(LV)                                | 33  | Transformer | 7.59  | 14-11-2020 19:15 | 0.78  | 04-11-2020 15:00 | 4.68  |  |
| Samastipur 220 kv GSS    | TRF-2(LV)                                | 33  | Transformer | 7.52  | 14-11-2020 19:15 | 0.78  | 04-11-2020 15:00 | 4.63  |  |
| Sasaram 132 kv GSS       | Pusaui                                   | 132 | Line        | 37.24 | 14-11-2020 18:00 | 0.04  | 18-11-2020 15:45 | 26.74 |  |
| Sasaram 132 kv GSS       | Dehri                                    | 132 | Line        | 26.32 | 28-11-2020 11:00 | 0.00  | 24-11-2020 19:30 | 5.72  |  |
| Sasaram 132 kv GSS       | Banjari-2                                | 132 | Line        | 12.51 | 02-11-2020 07:30 | 0.01  | 24-11-2020 21:30 | 5.45  |  |
| Sasaram 132 kv GSS       | TRF-3(LV)                                | 33  | Transformer | 24.74 | 14-11-2020 18:00 | 0.72  | 21-11-2020 14:15 | 15.29 |  |
| Sasaram 132 kv GSS       | TRF-2(LV)                                | 33  | Transformer | 12.02 | 14-11-2020 18:00 | 0.00  | 18-11-2020 15:45 | 7.42  |  |
| Sasaram 132 kv GSS       | TRF-1(LV)                                | 33  | Transformer | 9.03  | 28-11-2020 18:30 | 0.75  | 09-11-2020 13:00 | 3.89  |  |



|                          |                    |     |             |       |                  |       |                  |       |  |
|--------------------------|--------------------|-----|-------------|-------|------------------|-------|------------------|-------|--|
| Sultanganj 132 kv GSS    | Haveli Kharagpur-2 | 132 | Line        | 35.71 | 30-11-2020 17:45 | 2.41  | 30-11-2020 16:15 | 0.32  |  |
| Sultanganj 132 kv GSS    | Deoghar            | 132 | Line        | 30.65 | 09-11-2020 06:45 | 0.00  | 27-11-2020 04:45 | 20.38 |  |
| Sultanganj 132 kv GSS    | Tarapur            | 132 | Line        | 27.31 | 04-11-2020 15:45 | 0.05  | 23-11-2020 18:15 | 10.63 |  |
| Sultanganj 132 kv GSS    | TRF-3 (LV)         | 33  | Transformer | 30.76 | 21-11-2020 04:15 | 2.00  | 21-11-2020 12:15 | 14.89 |  |
| Sultanganj 132 kv GSS    | TRF-1 (LV)         | 33  | Transformer | 16.43 | 01-11-2020 19:15 | 0.64  | 08-11-2020 13:45 | 6.47  |  |
| Sultanganj 132 kv GSS    | TRF-2 (LV)         | 33  | Transformer |       |                  |       |                  |       | Charge on no load  |
| Sultanganj 132 kv GSS    | Jagdishpur(New)    | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Sultanganj 132 kv GSS    | Goradih BGCL-1     | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Sultanganj 132 kv GSS    | Goradih BGCL-2     | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Sultanganj 132 kv GSS    | Sabour-2           | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Supaul 132 kv GSS        | Madhepura-2        | 132 | Line        | 68.54 | 04-11-2020 18:00 | 1.91  | 26-11-2020 00:30 | 23.14 |  |
| Supaul 132 kv GSS        | Nirmali            | 132 | Line        | 61.95 | 27-11-2020 17:00 | 1.20  | 05-11-2020 13:45 | 22.29 |  |
| Supaul 132 kv GSS        | Laukahi            | 132 | Line        | 61.16 | 26-11-2020 17:00 | 1.19  | 15-11-2020 17:15 | 28.41 | Data is taken from Laukahi end.                            |
| Supaul 132 kv GSS        | Phulparas          | 132 | Line        | 55.68 | 01-11-2020 20:45 | 0.30  | 12-11-2020 13:15 | 29.26 |  |
| Supaul 132 kv GSS        | Madhepura-1        | 132 | Line        | 54.14 | 26-11-2020 17:15 | 0.87  | 05-11-2020 10:30 | 22.44 |  |
| Supaul 132 kv GSS        | Katariya-2         | 132 | Line        | 37.61 | 27-11-2020 17:45 | 0.00  | 14-11-2020 16:00 | 10.00 |  |
| Supaul 132 kv GSS        | Katariya-1         | 132 | Line        | 37.44 | 27-11-2020 17:45 | 0.00  | 18-11-2020 12:45 | 9.95  |  |
| Supaul 132 kv GSS        | Raghopur           | 132 | Line        | 36.77 | 02-11-2020 18:00 | 5.26  | 04-11-2020 12:15 | 17.43 |  |
| Supaul 132 kv GSS        | TRF-2 (LV)         | 33  | Transformer | 13.99 | 18-11-2020 21:00 | 0.34  | 15-11-2020 13:45 | 5.89  |  |
| Supaul 132 kv GSS        | TRF-1 (LV)         | 33  | Transformer | 13.72 | 01-11-2020 20:00 | 0.07  | 19-11-2020 10:45 | 6.69  |  |
| Supaul 132 kv GSS        | TRF-3 (LV)         | 33  | Transformer | 12.65 | 18-11-2020 21:00 | 0.48  | 13-11-2020 09:00 | 5.33  |  |
| Tarapur 132 kv GSS       | Sultanganj         | 132 | Line        | 27.32 | 04-11-2020 15:45 | 0.23  | 04-11-2020 11:00 | 10.80 |  |
| Tarapur 132 kv GSS       | Jamalpur           | 132 | Line        | 20.56 | 04-11-2020 16:00 | 13.91 | 04-11-2020 14:45 | 0.13  |  |
| Tarapur 132 kv GSS       | TRF-2(LV)          | 33  | Transformer | 9.51  | 29-11-2020 18:30 | 0.00  | 01-11-2020 13:00 | 5.09  |  |
| Tarapur 132 kv GSS       | TRF-1(LV)          | 33  | Transformer | 9.39  | 01-11-2020 19:30 | 0.22  | 04-11-2020 11:00 | 5.62  |  |
| Teghra 132 kv GSS        | Begusarai          | 132 | Line        | 11.86 | 18-11-2020 18:00 | 0.67  | 02-11-2020 08:00 | 4.40  |  |
| Teghra 132 kv GSS        | TRF-2(LV)          | 33  | Transformer | 5.97  | 18-11-2020 18:00 | 0.29  | 03-11-2020 12:30 | 2.18  |  |
| Teghra 132 kv GSS        | TRF-1(LV)          | 33  | Transformer | 5.89  | 18-11-2020 18:00 | 0.30  | 02-11-2020 08:00 | 2.15  |  |
| Tehta 132 kv GSS         | Jehanabad          | 132 | Line        | 35.45 | 23-11-2020 18:15 | 0.31  | 13-11-2020 13:00 | 24.60 |  |
| Tehta 132 kv GSS         | Belaganj           | 132 | Line        | 18.92 | 23-11-2020 18:15 | 0.06  | 13-11-2020 13:00 | 13.11 |  |
| Tehta 132 kv GSS         | TRF 1(LV)          | 33  | Transformer | 14.17 | 18-11-2020 17:00 | 0.00  | 06-11-2020 11:45 | 5.53  |  |
| Tehta 132 kv GSS         | TRF 2(LV)          | 33  | Transformer | 10.57 | 18-11-2020 16:15 | 0.10  | 13-11-2020 13:00 | 5.58  |  |
| Tekari 132 kv GSS        | Chandauti          | 132 | Line        | 45.48 | 15-11-2020 18:00 | 0.12  | 14-11-2020 12:30 | 30.46 |  |
| Tekari 132 kv GSS        | Goh                | 132 | Line        | 22.40 | 01-11-2020 18:15 | 0.14  | 03-11-2020 08:15 | 14.57 |  |
| Tekari 132 kv GSS        | TRF 3              | 33  | Transformer | 22.99 | 15-11-2020 18:15 | 0.10  | 14-11-2020 12:30 | 15.84 |  |
| Tekari 132 kv GSS        | TRF 1              | 33  | Transformer |       |                  |       |                  |       | Charge on no load  |
| Tekari 132 kv GSS        | TRF 2              | 33  | Transformer |       |                  |       |                  |       | Charge on no load  |
| Triveniganj 132 kv GSS   | Purnea             | 132 | Line        | 33.36 | 24-11-2020 17:15 | 0.10  | 16-11-2020 06:30 | 10.43 |  |
| Triveniganj 132 kv GSS   | Forbesganj         | 132 | Line        | 27.44 | 19-11-2020 08:30 | 0.05  | 27-11-2020 03:30 | 7.89  |  |
| Triveniganj 132 kv GSS   | TRF-2(LV)          | 33  | Transformer | 4.49  | 01-11-2020 18:15 | 0.60  | 04-11-2020 12:15 | 2.11  |  |
| Triveniganj 132 kv GSS   | TRF-1(LV)          | 33  | Transformer | 4.31  | 01-11-2020 18:15 | 0.61  | 04-11-2020 12:15 | 2.04  |  |
| Udakishanganj 132 kv GSS | Saharsa-1          | 132 | Line        | 31.86 | 01-11-2020 20:00 | 0.13  | 01-11-2020 06:00 | 16.29 |  |
| Udakishanganj 132 kv GSS | TRF-3 (LV)         | 33  | Transformer | 31.36 | 01-11-2020 20:00 | 0.10  | 01-11-2020 06:00 | 16.16 |  |
| Udakishanganj 132 kv GSS | TRF-2 (LV)         | 33  | Transformer |       |                  |       |                  |       | Charge on no load  |
| Udakishanganj 132 kv GSS | TRF-1 (LV)         | 33  | Transformer |       |                  |       |                  |       | Charge on no load  |
| Udakishanganj 132 kv GSS | Saharsa-2          | 132 | Line        |       |                  |       |                  |       | Charged up to Gantry end of Saharsa from Udakishanganj end |
| Udakishanganj 132 kv GSS | Sonebarsa-1        | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Udakishanganj 132 kv GSS | Sonebarsa-2        | 132 | Line        |       |                  |       |                  |       | Charge on no load  |
| Vaishali 132 kv GSS      | Muzaffarpur-2      | 132 | Line        | 64.71 | 23-11-2020 19:00 | 5.09  | 08-11-2020 06:00 | 28.87 |  |
| Vaishali 132 kv GSS      | Sheetalpur         | 132 | Line        | 24.82 | 23-11-2020 18:00 | 0.00  | 13-11-2020 09:30 | 4.54  |  |
| Vaishali 132 kv GSS      | Muzaffarpur-1      | 132 | Line        | 18.67 | 01-11-2020 18:45 | 0.00  | 12-11-2020 18:15 | 3.97  |  |
| Vaishali 132 kv GSS      | Bela Rail          | 132 | Line        | 2.34  | 30-11-2020 23:00 | 0.10  | 29-11-2020 15:30 | 0.06  |  |
| Vaishali 132 kv GSS      | TRF-3              | 33  | Transformer | 30.90 | 28-11-2020 18:45 | 0.74  | 01-11-2020 14:15 | 17.06 |  |
| Vaishali 132 kv GSS      | TRF-1(LV)          | 33  | Transformer | 10.93 | 03-11-2020 18:30 | 1.37  | 17-11-2020 11:45 | 5.40  |  |
| Vaishali 132 kv GSS      | TRF-2(LV)          | 33  | Transformer | 10.90 | 03-11-2020 18:30 | 0.23  | 03-11-2020 14:30 | 5.93  |  |
| Warisaliganj 132 kv GSS  | Biharsharif        | 132 | Line        | 24.71 | 15-11-2020 17:45 | 0.07  | 13-11-2020 13:00 | 13.10 |  |
| Warisaliganj 132 kv GSS  | Nawada             | 132 | Line        | 22.92 | 29-11-2020 08:45 | 8.87  | 28-11-2020 14:45 | 2.43  |  |
| Warisaliganj 132 kv GSS  | TRF-1(LV)          | 33  | Transformer | 13.25 | 26-11-2020 10:00 | 1.01  | 04-11-2020 13:15 | 7.55  |  |
| Warisaliganj 132 kv GSS  | TRF-3(LV)          | 33  | Transformer | 12.52 | 30-11-2020 16:30 | 0.00  | 13-11-2020 13:00 | 7.37  |  |
| Warisaliganj 132 kv GSS  | TRF-2(LV)          | 33  | Transformer |       |                  |       |                  |       | Charge on no load  |
| Wazirganj 132 kv GSS     | Khijarsarai(BGCL)  | 132 | Line        | 38.69 | 18-11-2020 18:00 | 0.05  | 06-11-2020 11:45 | 25.87 |  |
| Wazirganj 132 kv GSS     | TRF 1              | 33  | Transformer | 12.59 | 18-11-2020 18:00 | 0.00  | 06-11-2020 11:45 | 8.48  |  |
| Wazirganj 132 kv GSS     | TRF 3              | 33  | Transformer | 12.58 | 18-11-2020 18:00 | 0.85  | 25-11-2020 11:30 | 8.48  | meter not installed. Manual data incorporated.             |
| Wazirganj 132 kv GSS     | TRF 2              | 33  | Transformer | 12.58 | 18-11-2020 18:00 | 0.85  | 25-11-2020 11:30 | 8.48  |  |
| Wazirganj 132 kv GSS     | Nawada             | 132 | Line        |       |                  |       |                  |       | Charge on no load  |

**NOTE: Loading level of following GSSs and transmission elements have not been prepared due to non-installation of ABT Meter.**

- 220/132/33 kv Khagaria (New) , 132/33kv Kerpa GSS, 132/33kv Jagdishpur(new) GSS and 132/33kv Benipur(Alinagar) GSS.
- 220/132kv ICT at 220/132/33kv Dehri-on-sona GSS, Gaurichak GSS, Khagaul GSS, Bihta (new) GSS, Fatuha GSS , Biharsharif GSS , Nadokhar GSS, Bodhgaya GSS, Sonenagar (new) GSS, Hajipur (new) GSS , Ujijarpur GSS ,Laukahi GSS , Mushari GSS, Motipur GSS , Madhepura GSS, Kishanganj (new) GSS, Gopalganj GSS , Darbhanga GSS and Begusarai GSS.