



(2/0)

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - sldc.bseb@gmail.com
Fax No. 0612-2504655 Website - www.bsptel.in

Letter No. _____

From,

Date _____

Uttam Kumar
Director (Operations)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month April-2018 for FY-2018-19.

Ref: - SBPDCL letter no.217 dated 21.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for April-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
Apr-18	98.28	99.51	99.03	98.35	99.56	99.09

Yours faithfully

sd/-

(Uttam Kumar)
Director (Operations)

Dated 28/05/2018

MemoNo. 29/...../

Copy forwarded to

1. Secretary, BERC, Patna for kind information
2. GM (F & A), BSPTCL for kind information and necessary action.
3. ESE (IS), BSPTCL for kind information and necessary action.

Uttam Kumar
28/05/2018

(Uttam Kumar)
Director (Operations)

*



— — — — —

25

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - slde.bsptcl@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

Letter No. _____

Date _____

From,

Uttam Kumar
Director (Operations)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month April-2018 for FY-2018-19

Ref: - NBPDC letter no.218 dated 20.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for April-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
Apr-18	98.43	99.62	99.16	98.35	99.56	99.09

Yours faithfully

sd/-

(Uttam Kumar)
Director (Operations)

Dated 08/05/2018...../

MemoNo. 98...../

Copy forwarded to

1. Secretary, BERC, Patna for kind information
2. GM (F & A), BSPTCL for kind information and necessary action.
3. ESE (IS), BSPTCL for kind information and necessary action.

(Uttam Kumar)
Director (Operations)



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website – www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No. 45

Date 2/6/18

From,

J.P. Singh
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBDCL

Sub: BSPTCL Transmission system availability Certification for the month May-2018 for FY-2018-19

Ref: - NBDCL letter no.218 dated 20.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for May-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
Apr-18	98.43	99.62	99.16	98.35	99.56	99.09
May-18	99.73	99.77	99.76	99.03	99.62	99.39

Yours faithfully

Sd/-
J.P. Singh
Chief Engineer (System Operation)

Dated

MemoNo.

Copy forwarded to

1. Secretary, BERC, Patna for kind information
2. GM (F & A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPHCL for kind information and necessary action.

J.P. Singh
J.P. Singh
Chief Engineer (System Operation)



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website – www.bsptcl.in

File no. sldc/2016/part-4/TAFM

Letter No.

Date

From,

J. P. Singh
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month May-2018 for FY-2018-19.


Ref: - SBPDCL letter no.217 dated 21.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for May-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
Apr-18	98.28	99.51	99.03	98.35	99.56	99.09
May-18	98.43	99.49	99.08	99.03	99.62	99.39

Yours faithfully


2/6/18
(J.P. Singh)


Chief Engineer (System Operations)

Dated 2/6/18...../

Memo No. H6

Copy forwarded to

1. Secretary, BERC, Patna for kind information
2. GM (F & A), BSPTCL for kind information and necessary action.
3. ESE (IS), BSPTCL for kind information and necessary action.


2/6/18
(J.P. Singh)

Chief Engineer (System Operation)



- DPA - I -

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidhut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

Letter No. 89

From,

Date 6-7-2018

J. P. Singh
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month June-2018 for FY-2018-19.

Ref: - SBPDCL letter no.217 dated 21.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for June-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
June-18	98.48	99.74	99.24	99.07	99.73	99.46

Yours faithfully


6-7-18
(J.P.Singh)


Chief Engineer (System Operations)

Dated6-7-2018/

Memo No.89/

Copy forwarded to

1. Secretary, BERC, Patna for kind information
2. GM (F & A), BSPTCL for kind information and necessary action.
3. ESE (IS), BSPTCL for kind information and necessary action.


6-7-18
(J.P.Singh)

Chief Engineer (System Operations)





73

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website – www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No.

Date

From,

J.P. Singh
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month June-2018 for FY-2018-19

Ref: - NBPDC letter no.218 dated 20.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for June-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
June-18	99.72	99.73	99.73	99.07	99.73	99.46

Yours faithfully

Sd/-

J.P. Singh
Chief Engineer (System Operation)

Dated.....6/7/2018

Memo No.....88

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPTCL for kind information and necessary action.


06.7.18

J.P. Singh
Chief Engineer (System Operation)

-DFA -II-



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No. 128

Date 06/8/2018

From,

J.P. Singh
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month July-2018 for FY-2018-19

Ref: - NBPDC letter no.218 dated 20.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month July-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
July-18	99.29	99.51	99.41	98.47	99.72	99.20

Yours faithfully

J.P. Singh
Chief Engineer (System Operation)

Dated. 06/8/2018

Memo No. 128

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPCL for kind information and necessary action.

J.P. Singh
Chief Engineer (System Operation)

-DFA-T-



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Balley Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. slde/2016/part-4/TAFM

Letter No. 129

Date 06/8/2018

From,

J. P. Singh
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month July-2018 for FY-2018-19.


Ref: - SBPDCL letter no.217 dated 21.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month July-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
July-18	97.71	99.91	99.04	98.47	99.72	99.20

Yours faithfully


6/8/18
(J.P.Singh)


Chief Engineer (System Operations)

Memo No.129...../

Dated ..06/8/2018...../

Copy forwarded to

1. Secretary, BEREC, Patna for kind information
2. GM (F & A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPTCL for kind information and necessary action.


6/8/18
(J.P.Singh)

Chief Engineer (System Operations)



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month August-2018 for FY-2018-19.

Ref: - SBPDCL letter no.217 dated 21.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month August-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
August-18	98.60	99.82	99.35	98.35	99.71	98.74

Yours faithfully

Sd/-

(G.K.Choubey)

Chief Engineer (System Operations)

Dated..19/9/2018

Memo No. 169.

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPTCL for kind information and necessary action.

G.K.Choubey
19/9/2018

(G.K.Choubey)

Chief Engineer (System Operation)

G.K.Choubey



-DFA II-

CL
11
08
18
11
11
11

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsntcl.in

File No. sldc/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month August-2018 for
FY-2018-19

Ref: - NBPDC letter no.218 dated 20.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL
System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the
month August-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
August-18	96.13	99.60	98.08	98.35	99.71	98.74

Yours faithfully

G.K.Choubey
07.9.2018
(G.K.Choubey)

Chief Engineer (System Operation)
Dated..10/09/2018

Memo No. 1.6.8

Copy forwarded to

1. Secretary, BEREC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPTCL for kind information and necessary action.

G.K.Choubey
07.9.2018
(G.K.Choubey)

Chief Engineer (System Operation)



- DPA - II -

CL

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptel.in

File No. sldc/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month September-2018 for FY-2018-19.

Ref: - SBPDCL letter no.217 dated 21.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month September-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
September-18	98.37	99.27	98.95	97.27	99.36	98.49

Yours faithfully

G.K.Choubey
15/10/2018

(G.K.Choubey)

Chief Engineer (System Operations)

Dated..16/10/18

Memo No. 208

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. SE (PMC), BSPTCL for kind information and necessary action.

G.K.Choubey
15/10/2018

(G.K.Choubey)

Chief Engineer (System Operation)

ks



DRAFT

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidhut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month September-2018 for FY-2018-19

Ref: - NBPDC letter no.218 dated 20.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month September-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
September-2018	96.25	99.42	97.97	97.27	99.36	98.49

Yours faithfully

G.K.Choubey
15/10/2018

(G.K.Choubey)

Chief Engineer (System Operation)

Dated..16/10/18

Memo No. 207

Copy forwarded to

1. Secretary, BEREC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPTCL for kind information and necessary action.

G.K.Choubey
15/10/2018

(G.K.Choubey)

Chief Engineer (System Operation)

de



-DFA -I -

(166)

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. slde/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month October-2018 for FY-2018-19

Ref: - NBPDC letter no.218 dated 20.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month October-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
October-2018	99.67	98.59	99.16	99.67	98.56	99.20

Yours faithfully

G.K.Choubey
30/11/2018

(G.K.Choubey)

Chief Engineer (System Operation)

Dated. 30/11/2018

Memo No..255

Copy forwarded to

1. Secretary, BERG, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPTCL for kind information and necessary action.

G.K.Choubey
30/11/2018

(G.K.Choubey)

Chief Engineer (System Operation)



-BPA-II-

(167)

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - cc.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month October-2018 for FY-2018-19.

Ref: - SBPDCL letter no.217 dated 21.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month October-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
October-18	98.53	99.69	99.25	99.67	98.56	99.20

Yours faithfully

G.K.Choubey
30/11/2018

(G.K.Choubey)

Chief Engineer (System Operations)

Dated 30.11/2018

Memo No..256

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPTCL for kind information and necessary action.

G.K.Choubey
30/11/2018

(G.K.Choubey)

Chief Engineer (System Operation)

See

-DFA-T-



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889

[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No. 276

Date 19-12-2018

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month November-2018 for FY-2018-19.

Ref: - SBPDCL letter no.217 dated 21.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month November-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
November-18	97.97	99.64	99.01	98.74	99.79	99.36

Yours faithfully

G.K.Choubey
19/12/2018

(G.K.Choubey)

Chief Engineer (System Operations)

Dated...19-12-2018

Memo No. 276

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPTCL for kind information and necessary action.

G.K.Choubey
19/12/2018

(G.K.Choubey)

Chief Engineer (System Operation)

Ac.



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No. 275

Date 19-12-2018

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBDCL

Sub: BSPTCL Transmission system availability Certification for the month November-2018 for FY-2018-19

Ref: - NBDCL letter no.218 dated 20.03.2018

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month November-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
November-2018	99.48	99.92	99.73	98.74	99.79	99.36

Yours faithfully

G.K.Choubey
19/12/2018

(G.K.Choubey)

Chief Engineer (System Operation)

Dated....19-12-2018

Memo No. 275

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPTCL for kind information and necessary action.

G.K.Choubey
19/12/2018

(G.K.Choubey)

Chief Engineer (System Operation)

- D F A I -



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. slide 2016/part-4/TAFM

36

Letter No.

Date 21/01/19

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month December-2018 for FY-2018-19

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month December-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
December-2018	98.54	99.44	98.99	98.22	99.71	99.06

Yours faithfully
G.K.Choubey
19/1/2019

(G.K.Choubey)

Chief Engineer (System Operation)

Dated...21/01/19

Memo No...36

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPHCL for kind information and necessary action.

G.K.Choubey
19/1/2019

(G.K.Choubey)

Chief Engineer (System Operation)

-DFA-I-



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

2016

File No. slide 2016 part-I TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month December-2018 for FY-2018-19.

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month December-2018 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
December-18	97.99	99.93	99.20	98.22	99.71	99.06

Yours faithfully

G.K.Choubey
19/11/2019

(G.K.Choubey)

Chief Engineer (System Operations)

Dated..21/01/19

Memo No....37

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. ESE (PMC), BSPTCL for kind information and necessary action.

G.K.Choubey
19/11/2019

(G.K.Choubey)

Chief Engineer (System Operation)

↓



— DFA —

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. slde/2016/part-4/TAFM

Letter No.

Date

From,

Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month January-2019 for FY-2018-19

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month January-2019 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
January-2019	98.41	99.88	98.46	97.95	99.73	98.95

Yours faithfully

[Signature]
25/2/2019

Chief Engineer (System Operation)
Dated.....

Memo No.....

Copy forwarded to

1. Secretary, BERG, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (Comm. & Regulatory affairs), BSPTCL for kind information and necessary action.

[Signature]
25/2/2019

Chief Engineer (System Operation)



— DFA —

280
18/12
103.32
170/
11

29

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No.

Date

From,

Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month January-2019 for FY-2018-19.

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV, and 132 KV system computed as per CERC regulation 2014 for the month January-2019 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
January-19	97.6	99.6	98.85	97.95	99.73	98.95

Yours faithfully

G. K. Choubey
25/2/2019

Chief Engineer (System Operations)

Dated.....

Memo No.....

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (Comm. & Regulatory affairs), BSPTCL for kind information and necessary action.

G. K. Choubey
25/2/2019

Chief Engineer (System Operation)



—DFA—

(253)

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. slde/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month February-2019 for FY-2019-20

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month February-2019 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
February-2019	99.7	99.66	99.76	99.76	99.45	99.57

Yours faithfully

G.K.Choubey
30/3/2019
(G.K.Choubey)

Chief Engineer (System Operation)

Copy forwarded to

1. Secretary, BEREC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL

for kind information and necessary action.

G.K.Choubey
30/3/2019
(G.K.Choubey)

Chief Engineer (System Operation)



1254

N
Σ
26
18:15

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website – www.bsptcl.in

File No. sldc/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month February-2019 for FY-2018-19.

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month February-2019 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
February-19	99.88	99.24	99.48	99.76	99.45	99.57

Yours faithfully

G.K.Choubey
30/3/2019

(G.K.Choubey)

Chief Engineer (System Operations)

Dated.....

Memo No.....

Copy forwarded to

1. Secretary, BERCL, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL for kind information and necessary action.

G.K.Choubey
30/3/2019

(G.K.Choubey)

Chief Engineer (System Operation)



27

Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN – U40102BR2012SGC018889
[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptcl.in

File No. slde/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
NBPDC

Sub: BSPTCL Transmission system availability Certification for the month March-2019 for FY-2019-20

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month March-2019 as detailed below :-

Month	% Availability of BSPTCL Transmission system under NBPDC			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
March-2019	99.88	99.83	99.84	99.79	99.84	99.80

Yours faithfully

Sd/-

(G.K.Choubey)

Chief Engineer (System Operation)

Dated...11/04/19

Memo No..161.

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F &A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL

for kind information and necessary action.

G.K.Choubey
11/4/2019

(G.K.Choubey)

Chief Engineer (System Operation)



Bihar State Power Transmission Company Ltd., Patna
A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna
CIN - U40102BR2012SGC018889

[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]
Head Office, Vidyut Bhawan, Bailey Road, Patna -800021,
Telephone No. 0612-2504655, Email address - ce.trans664@gmail.com
Fax No. 0612-2504655 Website - www.bsptel.in

File No. slde/2016/part-4/TAFM

Letter No.

Date

From,

G.K.Choubey
Chief Engineer (System Operation)

To,

Chief Engineer (Commercial)
SBPDCL

Sub: - BSPTCL Transmission system availability Certification for the month March-2019 for FY-2019-20.

Sir,

With reference to above, Transmission system availability certification of BSPTCL System for 220 KV and 132 KV system computed as per CERC regulation 2014 for the month March-2019 as detailed below :-

Month	% Availability of BSPTCL Transmission system under SBPDCL			% Availability of BSPTCL Transmission system		
	220 KV	132 KV	Overall	220 KV	132 KV	Overall
March-19	99.67	99.86	99.78	99.79	99.84	99.80

Yours faithfully

Sd/-

(G.K.Choubey)

Chief Engineer (System Operations)

Dated..11/04/19

Memo No..165.

Copy forwarded to

1. Secretary, BERC, Patna for kind information.
2. GM (F & A), BSPTCL for kind information and necessary action.
3. CE (PMC), BSPHCL for kind information and necessary action.

(G.K.Choubey)

Chief Engineer (System Operation)

RW