


S.No.	DESCRIPTION	QTY	MATL
1	H.T TERMINAL 12 mm THREADED	1	BRASS
2	OIL LEVEL INDICATOR	1	Al+Glass
3	BUSHING CLAMP	1	M.S
4	BUSHING	1	HV PORCELAIN
5	LIFTING PLUG	2	M.S
6	NAME AND RATING PLATE	1	AL-Anodised
7	TANK WITH COVER	1	M.S
8	OIL DRAIN PLUG	1	M.S
9	EARTHING TERMINAL	2	M.S
10	SECONDARY TERMINAL BOX	1	M.S
11	OIL FILLING PLUG	2	M.S
12	EARTHING TERMINAL BOX	1	M.S


NOTE :-

1. Make of Bushing : IEC/WSI/CJI

ALL FERROUS PARTS EXPOSED TO THE ATMOSPHERE SHALL BE HOT DIP GALVANISED AND THEN EPOXY PAINTED HAVING LIGHT GREY CONFIRMING TO SHADE 631 OF IS5



4 NOS. MOUNTING
HOLE Ø17



MOUNTING DETAILS

CREEPAGE DISTANCE 900mm MIN
OIL QUANTITY 20 LITRES APPROX.
TOTAL WEIGHT 75 KG APPROX.

CUSTOMER	BIHAR STATE POWER TRANSMISSION CO. LTD.		
THIS DRAWING IS THE PROPERTY OF ABE TECHNICAL ELECTRIC & ENGINE CO. LTD. AND NOT TO BE COPIED OR USED WITHOUT THEIR PRIOR PERMISSION.			
SUPPLY LOI NO.			
ERECTION LOI NO.			
PROJECT			
SUBSTATION			
VENDORS NAME			
DRG. TITLE	GENERAL ARRANGEMENT OF 33 KV PT		
DRG. NO.	33-KV-PT-GA		
SCALE:	NTS	JOB NO:	SHEET