


1. SPRING CHARGE MOTOR
2. TRIPPING COIL
3. TRIPPING COIL
4. CIRCUIT BREAKER AUX. S/W
5. TERMINAL BLOCKS
6. VBF 33KV CIRCUIT BREAKER
7. MICRO SWITCH
8. MICRO SWITCH

NOTE: *

THIS WILL OPERATE WHEN CLOSING SPRING IS CHARGED

ALL WIRING WILL BE IN 1.5 sqmm COPPER WIRE

WIRE	COLOUR CODE
DC CKT	GREY
AC CKT	BLACK
EARTH CONNECTION	GREEN



33KV, OUTDOOR VCB		CIRCUIT BREAKER OPERATION		CUSTOMER BREAKSTATE POWER TRANSMISSION CO. LTD.						
Rev	Revision	Appd	For Work	DWG. NO. 33-KV-VCB-OPR						
1	2	3	4	5						
				<table border="1" style="float: right; border-collapse: collapse;"> <tr> <td>Rev</td> <td>Sheet</td> <td>1</td> </tr> <tr> <td>EmLSh</td> <td></td> <td>1</td> </tr> </table>	Rev	Sheet	1	EmLSh		1
Rev	Sheet	1								
EmLSh		1								

PTMVO 13 32