



NOTE:

1. Secondary terminal box shall be provided removable gland plate without hole.
2. Secondary Terminal Box shall be provided with Cover.
3. MS Sheet thickness for terminal box 3 mm & for Cover 2 mm.
4. Degree of Protection :- IP 55



CUSTOMER	 BIHAR STATE POWER TRANSMISSION CO. LTD		
THIS DRAWING IS THE PROPERTY OF M/S TECHNICAL ELECTRIC & ENGG. CO. LTD AND NOT TO BE COPIED OR USED WITHOUT THEIR PRIOR PERMISSION.			
SUPPLY LOI NO.			
ERECTION LOI NO.			
PROJECT			
SUBSTATION			
VENDORS NAME			
DRG. TITLE	DRG. FOR SECONDARY TERMINAL BOX FOR 220kV CT(120%&150%)		
DRG. NO.	220-KV-CT-120-150-STB		
SCALE:	NTS	JOB NO:	SHEET