



A


B

C

E



SPARE 10 NO / 10 NC CONTACTS OF CIRCUIT BREAKER AUX. SWITCH



- F16 - MCB FOR SPRING CHARGING MOTOR
- F20 - AC MCB
- F11 - ON/OFF SWITCH FOR ILLUMINATION
- B1 - THERMOSTAT
- E2 - PANEL ILLUMINATION
- R1 - SPACE HEATER
- X20 - RECEPTACLE
- M1 - UNIVERSAL MOTOR
- S1, S16 - AUXILIARY SWITCHES
- K10 - DENSITY MONITOR CONTACT MULTIPLIER

NOTES :-

1. ALL AUXILIARY CONTACTS SHOWN WITH CIRCUIT DE-ENERGISED.
2. ALL CONTACTS OF PR. SWITCH SHOWN WITH THE SWITCH IN LOW PR. CONDITION.
3. CONTACTS OF LIMIT SWITCH OF SPRING CHARGING MOTOR SHOWN WITH SPRING DISCHARGED.

Date	18.09.13	Customer:	Bihar State Power Transmission Corporation Limited.	Desar :	145KV,40KA,3150A SF6 CB	SAP No :		Qty :-	25 Nos	ALL DIMENSION ARE IN mm
Prep	CRB	Project :		Details :	WIRING_DRAWING					NOT TO SCALE
Ckd.	JFR	Original/Replacement for/Replaced by :-								
Issue	Remarks	Date	Name	Norm.						
G					G1					
					G2					
					G3					
					G4					
					G5					
					G6					
					G7					
										Sh. 1
										1 Sh.