



NOTES:-

1. ALL DIMENSIONS ARE IN M.M.
2. ALL HOLES ARE 17.5MM DIA TO SUIT 16MM DIA BOLTS.
3. BLANK HOLES AT GATE ARE TO RECEIVE BARBED WIRE.
4. ONE 3 MM SPRING WASHER TO BE PROVIDED UNDER EACH NUT.
5. BARBED WIRE SHALL BE CONFORM TO IS-278-1978.
6. STEEL WT. 31.08 KG.
7. B/N WT. 3.7 KG.

BIHAR STATE POWER TRANSMISSION COMPANY LTD

DRAWN BY		DESCRIPTION	132 KV D/C TOWER DETAILS OF ANTICLIMBING DEVICE	SCALE	-
CHECKED BY		DRG NO	132KV-Anticlimb-01	SHEET NO 1-1	REV. 0
APPROVED BY					