

33KV B/C energy 1.728MU fed by 33KV Mathurapur feeder.

21	132 KV BUS COUPLER	Q0200854	Export	26415	26415	0.000	1	0	.000041	-	
			Import	256	256	0		0	.000024	-	

Whether Bus Coupler was used for Energy Accounting : No

AEE/JEE

Electric Supply Sub-Division:

NBPDCL

AEE/JEE/SD

132/33 Samastipur

BSPTCL

Handwritten: 13.08.25
AEE/SD (n)
AEE/JEE/SD
13/08/2025
AEE/SD Samastipur

[illegible]

BIHAR STATE POWER TRANSMISSION CO.LTD.
GSS: 132/33KV Bihta
ENERGY METER READING FOR THE MONTH OF Jul 2025

Sl. No	Name of the Bay/feeders.	Energy Meter Sl No.	Flow	Initial reading (taken at 00:00 hrs of 1st date of current month) (H2)	Final reading (taken at 24:00 hrs of last date of current month) (H1)	Difference (H1-H2)	MF	Energy Calculated from H1-H2 Parameters (Difference * MF /1000) (MU)	Actual Energy received in SAMAST system (MU)	Corrected Reading (MU)	Remarks
1	50 MVA 132/33KV TRANSFORMER 1 (LV)	Q0323662	Export	553157.98 426	565476.98 278	12318.998 52	1	12.318999	12.318221	-	
			Import	0	0	0		0	.000001	-	
2	50 MVA 132/33KV TRANSFORMER 2 (LV)	Q0323609	Export	576658.99 725	588386.99 213	11727.994 88	1	11.727995	11.720585	-	
			Import	0	0	0		0	.000183	-	
3	50 MVA 132/33KV TRANSFORMER 3 (LV)	Q0323581	Export	609928.01 997	622684.99 558	12756.975 61	1	12.756976	12.757839	-	
			Import	0	0	0		0	.000001	-	
4	50 MVA 132/33KV TRANSFORMER 4 (LV)	Q0323584	Export	506592.98 509	519343.01 389	12750.028 8	1	12.750029	12.75047	-	
			Import	0	0	0		0	.000001	-	
5	33 KV Neora(GIS)	Q0332934	Export	8501.6002 6	9036.8	535.19974	1	.5352	.53518	-	
			Import	0	0	0		0	0	-	
6	33 KV Rustamganj(GIS)	Q0332965	Export	25248.399 36	28825.200 64	3576.8012 8	1	3.576801	3.579251	-	
			Import	0	0	0		0	0	-	
7	33 KV BIHTA FEEDER NO. 8(SPARE)	Q0323582	Export	0	0	0.000	1	0	0	-	
			Import	0	0	0		0	0	-	
8	33 KV BIHTA FEEDER NO. 9(UB)	Q0323656	Export	22.8	22.8	0.000	1	0	0	-	
			Import	0	0	0		0	0	-	
9	33 KV BIHTA FEEDER NO. 7(IIT)	Q0323624	Export	38161.301 5	39315.800 06	1154.4985 6	1	1.154499	1.154523	-	
			Import	2	2	0		0	.000001	-	
10	33 KV BIHTA FEEDER NO. 1	Q0200863	Export	20957.700 1	28637.200 38	7679.5002 8	1	7.6795	7.67946	-	
			Import	2	3	1.4		.0014	.001433	-	
11	33 KV BIHTA FEEDER NO. 2	Q0323612	Export	305468.89 933	311677.38 675	6208.4874 2	1	6.208487	6.208564	-	
			Import	0	0	0		0	0	-	
12	33 KV BIHTA FEEDER NO. 3	Q0323657	Export	766389.97 709	780683.96 851	14293.991 42	1	14.293991	14.294419	-	
			Import	0	0	0		0	.000005	-	
13	33 KV BIHTA FEEDER NO. 4	Q0323615	Export	347074.00 294	353517.99 398	6443.9910 4	1	6.443991	6.443502	-	
			Import	0	0	0		0	0	-	
14	33 KV BIHTA FEEDER NO. 5	Q0323586	Export	129321.30 406	131768.09 882	2446.7947 6	1	2.446795	2.443035	-	
			Import	0	0	0		0	0	-	
15	33 KV BIHTA FEEDER NO. 6	Q0323591	Export	334174.48 653	341369.19 245	7194.7059 2	1	7.194706	7.194679	-	
			Import	0	0	0		0	0	-	
16	Auxilliary Consumption (i)	SST1	Export	646.246	660.634	14.388	1	.014388	.014388	-	
17	Auxilliary Consumption (II)	SST2	Export	151.135	163.4	12.265	1	.012265	.012265	-	
18	33KV BUS COUPLER	Q0323626	Export	3172	3172	0,000	1	0	0	-	
			Import	215	215	0		0	0	-	
Whether Bus Coupler was used for Energy Accounting : No											
19	132 KV BUS COUPLER	Q0323605	Export	1	1	0,000	1	0	0	-	
			Import	14	14	0		0	0	-	
Whether Bus Coupler was used for Energy Accounting : No											

AEE/JEE

Electric Supply Sub-Division: 114/18/Bihta

SBPDCL

AEE/JEE/USD

132/33KV Bihta

BSPTCL

BIHAR STATE POWER TRANSMISSION CO.LTD.
GSS: 220/132 KV Jamalpur GIS
ENERGY METER READING FOR THE MONTH OF Jul 2025

Sl. No	Name of the Bay/feeders.	Energy Meter Sl No.	Flow	Initial reading (taken at 00:00 hrs of 1st date of current month) (H2)	Final reading (taken at 24:00 hrs of last date of current month) (H1)	Difference (H1-H2)	MF	Energy Calculated from H1-H2 Parameters (Difference * MF /1000) (MU)	Actual Energy received in SAMAST system (MU)	Corrected Reading (MU)	Remarks
1	50 MVA 132/33 KV TRANSFORMER No.-1 (LV)	Q0426659	Export	170734.92	176285.2	5550.28	1	5.55028	5.550191	-	
			Import	3	3	0		0	0	-	
2	50 MVA 132/33 KV TRANSFORMER No.-2 (LV)	Q0426605	Export	113169.09	116565.4	3396.31	1	3.39631	3.395911	-	
			Import	1	1	0		0	0	-	
3	33 KV BANHARA	Q0426647	Export	32980.29	34113.09	1132.8	1	1.1328	1.132591	-	
			Import	47	47	0		0	.000003	-	
4	33 KV H. KHARAGPUR (NEW)	Q0426627	Export	75747.09	77036	1288.91	1	1.28891	1.288852	-	
			Import	47	47	0		0	0	-	
5	33 KV PIPRA	Q0426648	Export	18487.4	18815.1	327.7	1	.3277	.327663	-	
			Import	0	0	0		0	.000012	-	
6	33 KV BAGESHWARI	Q0426632	Export	58280.7	60125.29	1844.59	1	1.84459	1.844568	-	
			Import	0	0	0		0	0	-	
7	33 KV KHARAGPUR	Q0426623	Export	39215.89	41624.8	2408.91	1	2.40891	2.408828	-	
			Import	0	0	0		0	0	-	
8	33 KV TATIA BAMBER	Q0426658	Export	58020.9	59934.29	1913.39	1	1.91339	1.913252	-	
			Import	0	0	0		0	0	-	
9	Auxilliary Consumption (i)	Q0426612	Export	371.54	380.39	8.85	1	.00885	.00885	-	
10	Auxilliary Consumption (ii)	Q0426591	Export	225.86	246.01	20.15	1	.02015	.02015	-	

For Sl no - 1, 5

For Sl nos 3, 4, 6, 7, 8

AEE/JEE

Dilip Kumar
Assistant Electrical Engineer
Electric Supply Sub-Division
JAMALPUR

Electric Supply Sub-Division: *Jamalphur*

SBPDCL

08/08/2025
Assistant Electrical Engineer
Electric Supply Sub-division
Kharagpur

Rajnish
220/132 KV Jamalpur GIS
06/08/25

रजनीश कुमार रोशन/Rajnish Kumar Roshan
अभियंता (विद्युत)/Engineer (Elect.)
बिहार ग्रिड कं लि०/Bihar Grid Co. Ltd.
हवेली खरगपुर/Haveli Kharagpur

08/08/2025
अमन कुमार सिंह/Aman Kumar Singh
उप महाप्रबंधक/Deputy General Manager
बिहार ग्रिड कं लि०/Bihar Grid Co. Ltd.
Haveli Kharagpur/Goradih
हवेली खड़गपुर/गोराडीह

BIHAR STATE POWER TRANSMISSION CO.LTD.
GSS: 220/132 KV Khisersarai GIS(BGCL)
ENERGY METER READING FOR THE MONTH OF Jul 2025

Sl. No	Name of the Bay/feeders.	Energy Meter Sl No.	Flow	Initial reading (taken at 00.00 hrs of 1st date of current month) (H2)	Final reading (taken at 24.00 hrs of last date of current month) (H1)	Difference (H1-H2)	MF	Energy Calculated from H1-H2 Parameters (Difference * MF /1000) (MU)	Actual Energy received in SAMAST system (MU)	Corrected Reading (MU)	Remarks
1	50 MVA 132/33 KV TRANSFORMER No.-2 (LV)	Q0426579	Export	178688.99	184661.99	5973	1	5.973	5.972955	-	
			Import	33	33	0		0	0	-	
2	50 MVA 132/33 KV TRANSFORMER No.-3 (LV)	Q0426661	Export	187077.77	194086.63	7008.86	1	7.00886	7.008679	-	
			Import	0	0	0		0	0	-	
3	33 KV NAUGARH	Q0426601	Export	78710.7	81641.1	2930.4	1	2.9304	2.930214	-	
			Import	0	0	0		0	0	-	
4	33 KV ATRI	Q0426614	Export	171183.6	175423.7	4240.1	1	4.2401	4.239585	-	
			Import	0	0	0		0	0	-	
5	33 KV ALIPUR FEEDER	Q0426617	Export	101610.39	104663.09	3052.7	1	3.0527	3.052499	-	
			Import	1	1	0		0	.000009	-	
6	MAHAKAR FEEDER	Q0426611	Export	94459.5	97200.89	2741.39	1	2.74139	2.741379	-	
			Import	0	0	0		0	.000001	-	
7	33 KV Khizersarai Feeder	XB426799	Export	15915.52	15915.52	0.000	2	0	0	-	
			Import	0	0	0		0	0	-	
8	Auxilliary Consumption (i)	Q0426599	Export	1477.85	1517.05	39.2	1	.0392	.0392	-	
9	Auxilliary Consumption (ii)	Q0426593	Export	.54	.54	0	1	0	0	-	

[Signature]
AEE/JEE
Assistant Electrical Engineer
Electric Supply Sub-Division
SBPDCL

जयप्रकाश नारायण
220/132 KV Khisersarai GIS(BGCL)
Bihar State Power Transmission Co. Ltd.
Bhagalpur, Bihar /Khizersarai, BGCL

BIHAR STATE POWER TRANSMISSION CO.LTD.
GSS: 220/132 KV Sheikhpura GIS(BGCL)
ENERGY METER READING FOR THE MONTH OF Jul 2025

Sl. No	Name of the Bay/feeders.	Energy Meter Sl No.	Flow	Initial reading (taken at 00:00 hrs of 1st date of current month) (H2)	Final reading (taken at 24:00 hrs of last date of current month) (H1)	Difference (H1-H2)	MF	Energy Calculated from H1-H2 Parameters (Difference * MF /1000) (MU)	Actual Energy received in SAMAST system (MU)	Corrected Reading (MU)	Remarks
1	50 MVA 132/33 kV TRANSFORMER No.-1 (LV)	Q0426664	Export	23057.59	23890.13	832.54	1	.83254	.832175	-	
			Import	1737	1737	0		0	0	-	
2	50 MVA 132/33 kV TRANSFORMER No.-2 (LV)	Q0426640	Export	317442.78	326625.88	9183.1	1	9.1831	9.181186	-	
			Import	0	0	0		0	0	-	
3	33 KV PANCHI FEEDER	Q0426637	Export	18427.19	19168.1	740.91	1	.74091	.740651	-	
			Import	0	0	0		0	.000001	-	
4	33 KV ONAMA FEEDER	Q0426650	Export	110625.2	113752.89	3127.69	1	3.12769	3.126956	-	
			Import	1	1	0		0	.00001	-	
5	33 KV KATRISARAI(MAY APURI) FEEDER	Q0426653	Export	207262.59	213305.9	6043.31	1	6.04331	6.042264	-	
			Import	0	0	0		0	.000005	-	
6	Auxilliary Consumption (i)	Q0426586	Export	111.75	132.97	21.22	1	.02122	.02122	-	
7	Auxilliary Consumption (ii)	Q0426603	Export	608.57	626.68	18.11	1	.01811	.01811	-	

AEE/JEE

Electric Supply Sub-Division:

SBPDCL

Bar 6/08/2025

BARBIGHA

Assistant Electrical Engineer

Electric Supply Subdivision

Barbigha (Sheikhpura)

Suman 06.08/2025

220/132 KV Sheikhpura GIS(BGCL)

Suman BGCL / SUMAN SAURABH

क्षेत्रीय अभियन्ता (विद्युत) / Field Engineer (Elect.)

बिहार ग्रिड कंपनी लि. / Bihar Grid Co. Ltd.

शेखोपुर सराय / Sheikhpura Surai

BIHAR STATE POWER TRANSMISSION CO.LTD.
GSS: Bhusaula (BGCL)
ENERGY METER READING FOR THE MONTH OF Jul 2025

Sl. No	Name of the Bay/Feeders.	Energy Meter Sl No.	Flow	Initial reading (taken at 00:00 hrs of 1st date of current month) (H2)	Final reading (taken at 24:00 hrs of last date of current month) (H1)	Difference (H1-H2)	MF	Energy Calculated from H1-H2 Parameters (Difference * MF /1000) (MU)	Actual Energy received in SAMAST system (MU)	Corrected Reading (MU)	Remarks
1	100 MVA 220/33 KV ICT-1 (LV)	20004178	Export	103296	112035	8739	2	17.478	17.478	-	
			Import	0	0	0		0	0	-	
2	100 MVA 220/33 KV ICT-2 (LV)	20004179	Export	59224	59224	0.000	2	0	0	-	
			Import	0	0	0		0	0	-	
3	33 KV BHUSAULA	Q0759963	Export	5361.6	10447.2	5085.6	1	5.0856	5.085285	-	
			Import	24	24	0		0	.000001	-	
4	33kv AIIMS (PSS) FEEDER	20004186	Export	25318.8	26583	1264.2	2	2.5284	2.5284	-	
			Import	0	0	0		0	0	-	
5	33kv WALMI (PSS) Feeder	20004193	Export	76710.6	78926.1	2215.5	2	4.431	4.431	-	
			Import	0	0	0		0	0	-	
6	33 kv Bhusaula (GIS) Feeder	20004190	Export	52505.58	55233.4	2727.82	2	5.45564	5.45564	-	
			Import	0	0	0		0	0	-	
7	Auxilliary Consumption (i)	Q0759955	Export	386.68	410.16	23.48	1	.02348	.02348	-	
8	Auxilliary Consumption (ii)	Q0759965	Export	0	0	0	1	0	0	-	

8184
13/08/25
AEE/JEE

Electric Supply Sub-Division: Phulwari Sherif
SBPDCL

307
15/08/25
AEE/JEE/TSD
Bhusaula (BGCL)

रुद्र कुमार
उप महाप्रबंधक / Dy. GENERAL MANAGER
बिहार ग्रिड कंपनी लिमिटेड / BIHAR GRID COMPANY LIMITED
220/33 को-वी, जीआईएस, भुसाउला, पटना-801507
220/33 KV GIS, Bhusaula, Patna - 801507

BIHAR STATE POWER TRANSMISSION CO.LTD.
GSS: Dumraon New(BGCL)
ENERGY METER READING FOR THE MONTH OF Jul 2025

Sl. No	Name of the Bay/feeders.	Energy Meter Sl No.	Flow	Initial reading (taken at 00:00 hrs of 1st date of current month) (H2)	Final reading (taken at 24:00 hrs of last date of current month) (H1)	Difference (H1-H2)	MF	Energy Calculated from H1-H2 Parameters (Difference * MF /1000) (MU)	Actual Energy received in SAMAST system (MU)	Corrected Reading (MU)	Remarks
1	80 MVA 132/33 kV TRANSFORMER No.-1 (LV)	Q0426630	Export	126480.99	126480.99	0.000	1	0	0	-	
			Import	54	54	0		0	0	-	
2	80 MVA 132/33 kV TRANSFORMER No.-2 (LV)	Q0759979	Export	174721.71	192092.45	17370.74	1	17.37074	17.370745	-	
			Import	0	0	0		0	0	-	
3	SHAHPUR FEEDER	Q0426606	Export	157324.8	166463.89	9139.09	1	9.13909	9.138462	-	
			Import	0	0	0		0	.000001	-	
4	33 KV BRAHMPUR FEEDER	Q0201047	Export	64048.39	72204.69	8156.3	1	8.1563	8.155579	-	
			Import	0	0	0		0	0	-	
5	Auxilliary Consumption (i)	Q0426649	Export	131.69	131.69	0	1	0	0	-	
6	Auxilliary Consumption (ii)	Q0426619	Export	297.76	324.47	26.71	1	.02671	.02671	-	

AEE/JEE

Anish
14/08/2025

Electric Supply Sub-Division:

SBPDCL

JUNIOR ELECTRICAL ENGINEER
ELECTRIC SUPPLY SECTION
BRAHMPUR (BUXAR)

21/02/25 hr
14/08/2025
Rajesh Kumar
Engineer (Elect.)

Bihar Grid Company Limited
220/132/33KV GIS S/s Dumraon (Bihar)

BIHAR STATE POWER TRANSMISSION CO.LTD.
GSS: Mokama BGCL
ENERGY METER READING FOR THE MONTH OF Jul 2025

Sl. No	Name of the Bay/feeders.	Energy Meter Sl No.	Flow	Initial reading (taken at 00:00 hrs of 1st date of current month) (H2)	Final reading (taken at 24:00 hrs of last date of current month) (H1)	Difference (H1-H2)	MF	Energy Calculated from H1-H2 Parameters (Difference * MF /1000) (MU)	Actual Energy received in SAMAST system (MU)	Corrected Reading (MU)	Remarks
1	50 MVA 132/33 kV TRANSFORMER No.-1 (LV)	Q0426588	Export	46240.3	50424.59	4184.29	1	4.18429	4.184065	-	
			Import	0	0	0		0	0	-	
2	80 MVA 132/33 kV TRANSFORMER No.-2 (LV)	Q0759981	Export	38895.02	42154.23	3259.21	1	3.25921	3.259203	-	
			Import	0	0	0		0	0	-	
3	33kV Mokama (GIS) - Khushalchak (PSS)	Q0426610	Export	15693.5	16472.09	778.59	1	.77859	.778565	-	
			Import	0	0	0		0	0	-	
4	33 KV MOKAMA PSS FEEDER	Q0426609	Export	68874.1	75513	6638.9	1	6.6389	6.638531	-	
			Import	12	12	0		0	.000018	-	
5	Auxilliary Consumption (i)	Q0426596	Export	427.38	448.28	20.9	1	.0209	.0209	-	
6	Auxilliary Consumption (ii)	Q0426594	Export	208.57	217.51	8.94	1	.00894	.00894	-	

AEE/JEE

Electric Supply Sub-Division: Mokama

SBPDCL


रमेश महली / Ramesh Mahli
अभिियंता / Engineer
बिहार ग्रिड / Bihar Grid
220/132/33KV GIS, MOKAMA

RECEIVED
Date 07/08/25
ESSD mok