



BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA

A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna

CIN – U40102BR2012SGC018889

[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]

Head Office, Vidyut Bhawan, Bailey Road, Patna – 800021

E-mail address – project.2@bsptcl.bihar.gov.in Website - www.bsptcl.in

Office Order No. :19.....

Date : 14/05/2026....

Trans./P- II/64/2021-Part-I

Sub:- Conditional withdrawal of Debarment of M/s Kanohar Electricals Limited in JV with M/s. Aquarian Enterprises for participating in future tenders of BSPTCL and subsidiary companies of BSP(H)CL against NIT No. 38/PR/BSPTCL/2021.

Ref:-

- 1) NIT No. 38/PR/BSPTCL/2021
- 2) NOA No. 21 (S) & 22 (E), both dated 08.12.2021
- 3) This office Order No. 11 dated 23.02.2026
- 4) M/s KEL letter no. KEL/EPC-023/NIT-038/101/001 dated 06.05.2026
- 5) ESE/TC/ Patna (East) letter no. 616 dated 04.05.2026.

Sir,

The work of construction of 132/33 KV GIS GSS Mithapur and associated works including construction of 132 KV transmission line through XLPE underground cable was awarded to M/s Kanohar Electricals Limited in JV with M/s Aquarian Enterprises on turnkey basis against NIT No. 38/PR/BSPTCL/2021. The above said GSS was energise & taken into service on dated 20.01.2024. However, the total power failure in GSS was observed on dated 11.06.2025. Prior to this there were numerous failures in the GSS, which severely affect the reliable power supply to state capital. On examining all such issues, it was concluded that these failures was occurred only due to the bad workmanship & poor quality of work executed by M/s Kanohar Electricals Limited.

Various opportunities were given to M/s Kanohar Electricals Limited to address / rectify all such issues, but M/s KEL miserably failed to attend it. Due to the non- serious approach by M/s KEL, it compelled BSPTCL to take action in terms of the condition of the contract wherein M/s Kanohar Electricals Limited in JV with M/s Aquarian Enterprises was debarred for 03 years from participating in future tenders in BSPTCL and subsidiary companies of BSP(H)CL vide this office Order No. 11 dated 23.02.2026.

Thereafter, M/s Kanohar Electricals Limited vide letters under reference (IV) requested for withdrawal/revocation of the debarment order and informed that major punch point works have been completed at site. As reported by the field official vide reference (v), there are considerable balance point which needs to be addressed on immediate basis. Apart from other point, the major issue are as below:-

- 1) SST tripping without any fault related to GSS Mithapur.
- 2) 250V Battery Charger Defect/DC Grounding issues.
- 3) Commissioning of 33KV Feeder No.15 is pending due to incomplete erection work of isolators etc.
- 4) All Isolator drop pipe needs replacement in 132 KV Side.
- 5) Supply & installation of Lift in main control room building.
- 6) Non-functioning of offline fault locator kit.
- 7) Maintenance /Service of SF6 gas handling device.
- 8) Epoxy coating on damaged floor of GIS building.

In view of the completed work for the non- OEM part and the above balance work, the debarment of M/s Kanohar Electricals Limited in JV with M/s Aquarian Enterprises imposed vide this office Order No. 11 dated 23.02.2026 is hereby withdrawn from the date of issuance of this order against NIT No. 38/PR/BSPTCL/2021 with a condition to complete all balance work in totality by 30th June 2026, failing which the debarment for participating in future tender of BSPTCL and subsidiary company of BSP(H)CL shall be reinstated without any prejudice and prior notice.

Further, this withdrawal of debarment shall not absolve M/s Kanohar Electricals Limited in JV with M/s Aquarian Enterprises from any contractual responsibility/liability as per terms and conditions of instant NIT.

Sd/-
(Premjeet Kumar)
Chief Engineer (Project-II)

Memo No...../

Dated...../

Copy forwarded to M/s Kanohar Electricals Limited in JV with M/s Aquarian Enterprises, Rithani, Delhi Road, Meerut, UP-250103

Sd/-
(Premjeet Kumar)
Chief Engineer (Project-II)

Memo No...../

Dated...../

Copy forwarded to all GM-cum-CE/CEs/ESEs of BSPTCL for kind information

Sd/-
(Premjeet Kumar)
Chief Engineer (Project-II)

Memo No...../

Dated...../

Copy forwarded to Director (Projects), BSPTCL/NBPDCL/SBPDCL and Director (Operation), BSPTCL/NBPDCL/SBPDCL/BSPGCL for kind information.

Sd/-
(Premjeet Kumar)
Chief Engineer (Project-II)

Memo No...../

Dated...../

Copy forwarded to OSD to MD, BSPTCL/NBPDCL/SBPDCL/BSPGCL for kind information.

Sd/-
(Premjeet Kumar)
Chief Engineer (Project-II)

Memo No...../

Dated...../

Copy forwarded to DBA (IT), BSPTCL to upload this office order on website of BSPTCL and all subsidiary companies of BSP(H)CL ✓

Sd/-
(Premjeet Kumar)
Chief Engineer (Project-II)

Project
14-05-26