

➤ ATC/TTC Declaration of BSPTCL System for the following months is as mentioned below:-

Month	TTC (MW)	ATC(TTC-RM)(MW)	RM(MW) (2% of peak demand)
November-2023(Revised)	5215	5113	102
December-2023	5450	5343	107
January-2024	6240	6118	122
February-2024	5690	5578	112
March-2024	6175	6054	121

TTC-Total Transfer capability

ATC-Available Transfer capability

RM-Reliability Margin

RM-Reliability Margin (2% of peak demand or maximum generation in the state)

Taking 2% of Peak demand as reliability margin.

ATC=TTC-RM

Assumptions			
Month	Generation (MW) (Including Thermal & Hydro generator of central sector & Sate sectors)	Peak Load(MW)	Remarks
November-2023(Revised)	6715	5113	Total LTA of BSPHCL with Thermal & Hydro generator of central sector & Sate sectors is of 6715 MW.
December-2023	6715	5343	
January-2024	6715	6118	
February-2024	6715	5578	
March-2024	6715	6054	
Constraints			
No any constraints at this loading.			